

November 21, 2016

Mr. Edwin Martin
Facilities Coordinator
Ballston Spa School District
70 Malta Ave
Ballston Spa, NY 12020

**RE: Water Sampling for Lead Content
Ballston Spa Elementary Schools:**

Wood Road Elementary - 300 Wood Rd, Ballston Spa, NY 12020
Malta Ave Elementary - 70 Malta Ave, Ballston Spa, NY 12020
Milton Terrace Elementary - 100 Wood Rd, Ballston Spa, NY 12020
Gordon Creek Elementary - 50 Wood Rd, Ballston Spa, NY 12020

PSI Project Number: 08212368

Dear Mr. Martin,

In accordance with your request, Professional Service Industries, Inc. (PSI), conducted initial first-draw lead-in-water testing of potable water sources at the above referenced elementary school facilities. The sample's lead concentrations were compared to the New York State action limit established by emergency regulation enacted on September 6, 2016 and included in the Subpart 67-4 of Title 10 Official Compilation of Codes, Rules and Regulations of New York, establishing an action level for lead in public school drinking water of 0.015 milligrams per liter (mg/L).

PSI was authorized to conduct the lead-in-water sampling and analysis on 9/7/2016 by Mr. Edwin Martin, Facilities Coordinator of the Ballston Spa School District, by signed Purchase Order No. 17-01101. The associated PSI Proposal number is 0921-195606

SCOPE

Initial first draw water samples were collected from potable water outlets at the Wood Road, Malta Avenue, Milton Terrace, and Gordon Creek Elementary Schools. The samples were collected from accessible potable water sources in the subject elementary schools, including kitchen sinks, bathroom sinks, water fountains (bubblers) and other outlets that were indicated by the school district on sample location maps provided to PSI prior to sampling. The total number of samples to be collected and the sample locations to be collected from were provided by the school district.

METHODOLOGY

The following samples were collected by PSI:

School Name	Number of Samples	Date Collected	PSI Technician
Malta Avenue	90	9/17/16	Daniel Gerke
Gordon Creek	132	9/19/16	Daniel Gerke
Wood Road	141	9/24/16	Daniel Gerke
Milton Terrace	95	9/25/16	Daniel Gerke
Malta Avenue (additional sampling)	5	9/25/16	Daniel Gerke
Total Samples Collected	463		

The 'first draw' water samples were collected from water fountains, classroom sinks, bathroom sinks (cold-water faucets and spigots) and other locations of interest. The sampled outlets had been isolated from service by school district personnel for more than 8 hours but less than 18 hours. The samples were collected directly into laboratory-supplied 250 ml bottles containing a HNO₃ preservative solution.

The samples were delivered and transferred under chain of custody to Pace Analytical Services Inc laboratory facility at 2190 Technology Drive, Schenectady NY. Analysis for Lead was performed at Pace Analytical Inc. Laboratories in Minneapolis, MN (NYS-DOH Lab Cert # 11647 and Melville, NY (NYS-DOH Lab Cert # 10478).

All samples were analyzed for lead content by EPA Method 200.8, Inductively Coupled Plasma Mass-Spectrometry.

RESULTS

Sample locations may be found in the attached site maps A through D, analytical results, and chain-of-custody paperwork, may be found in the attached Appendices E through H. Analytical results indicating concentrations at or exceeding the New York State Action Level drinking water standard for lead of 0.015 milligrams per liter (mg/L) (also 15 ppb) are displayed on the tables below.

Malta Avenue Elementary School

The table presented below identifies the potable water sample locations whose lead (Pb) concentration results were at or above the 15 PPB (0.015 mg/L) action level. Seven (7) of the 95 samples collected at this facility exceeded the NYS DOH Action Level for lead-in-drinking water.

Notes: No sample was collected during the first sampling event from sample locations #1 Gym North Rm 21, #2 Gym South Rm 19 and #63 Boys Sink N. on 9/19/16 these locations were non-functional at the time of sampling.

Samples from locations #1 Gym North Rm 21, #2 Gym South Rm 19 were collected during the second sampling event on 9/25/16.

Malta Avenue School samples collected 9-17-16 and 9-25-16

Sample Location (Malta Avenue)	Lab Sample ID No.	Lead (Pb) Analytical Result (ug/L)
45 RM 213 CLASS SINK	1609M16-045	15.5
47 RM 210 CLASS SINK	1609M16-047	39.0
88 RM 315 CLASS SINK	1609M16-088	32.7
92 RM 313 CLASS SINK	1609M16-092	42.0
93 RM 311 CLASS SINK	1609M16-093	17.7
MA001 Gym RM 19	10364811001	15.3
MA002 Gym RM 21	10364811002	20.4

See Site Map in Appendix A for outlet locations

Gordon Creek Elementary School

None of the 132 sample locations collected exceeded the NYS-DOH action level for Lead at the Gordon Creek Elementary School. Please see Site Map in Appendix B for outlet locations

Notes: No sample was collected from sample location #31 *Class 110 bubbler* and location #32 *Room 109 bubbler*; no bubbler fountains were found in these rooms. No sample was collected from sample location # 104 *Boys Bath Sink* ent this location was non-functional at the time of sampling.

Wood Road Elementary School

The table presented below identifies the potable water sample locations whose lead (Pb) concentration results were at or above the 15 PPB (0.015 mg/L) action level. Three (3) of the 141 samples collected at this facility exceeded the NYS DOH Action Level for lead-in-drinking water.

Notes: No sample was collected from sample location # WR120 no sink was found in room J33. No sample was collected from sample location #WR137 no second water fountain was found.

Wood Road Elementary School samples collected 9-24-16

Sample Location (Wood Road)	Lab Sample ID No.	Lead (Pb) Analytical Result (ug/L)
WR009	10364697009	18.7
WR010	10364697010	22.6
WR011	10364697011	30.0

See Site Map in Appendix C for outlet locations

Milton Terrace Elementary School

The table presented below identifies the potable water sample locations whose lead (Pb) concentration results were at or above the 15 PPB (0.015 mg/L) action level. Three (3) of the 95 samples collected at this facility exceeded the NYS DOH Action Level for lead-in-drinking water.

Milton Terrace Elementary School samples collected 9-25-16

Sample Location (Milton Terrace)	Lab Sample ID No.	Lead (Pb) Analytical Result (ug/L)
MT024	10364690024	16.5
MT038	10364690038	34.5
MT045	10364690045	22.5

See Site Map in Appendix D for outlet locations

Notes: No sample was collected from sample location MT068, no second bathroom was found in media center 68.

CONCLUSIONS

A total of thirteen (13) sampled outlets at the elementary schools had Pb water concentrations that exceeded the NYS-DOH action level of 15 ppb or µg/L (0.015 mg/L) at the time of PSI's sampling.

Additionally, 13 of the 463 sampled outlets had Pb concentrations between approximately 10 ppb to 15 ppb, which is below, but close to the action level.

Please find the Laboratory analytical results attached for your review.

RECOMMENDATIONS

Per NYS-DOH Regulations, where the initial first-draw water sample lead concentration exceeds the action level, the school shall:

- a. prohibit use of the outlet until:
 1. a lead remediation plan is implemented to mitigate the lead level of such outlet; and

2. test results indicate that the lead levels are at or below the action level;
- b. provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed.
- c. report the test results to the local health department as soon as possible, but no more the 1 business day after the school receives the laboratory report; and
- d. notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but not more than 10 business days after the school receives the laboratory report.

The School District may also want to consider conducting re-testing or remediation of the 13 other outlets where Pb concentrations were determined to be between approximately 10 to 15 µg/L, which is below but near the action level.

WARRANTY

The field observations, measurements, and research reported herein are considered sufficient in detail and scope to form for the analysis of the selected water quality parameters. The investigation and conclusions presented herein are based upon the subjective evaluation of limited data. They may not represent all conditions at the subject site as they reflect the information gathered from specific locations. PSI warrants that the findings and conclusions contained herein have been promulgated in accordance with generally accepted environmental investigation methodology and only for the site described in this report.

The water quality sampling and analysis has been developed to provide the client with information regarding select parameter concentrations in the water samples collected at the subject property. It is necessarily limited to the conditions observed and to the information available at the time of the work.

Due to the limited nature of the work, there is a possibility that there may exist conditions which could not be identified within the scope of the assessment or which were not apparent at the time of report preparation. It is also possible that the testing methods employed at the time of the report may later be superseded by other methods. PSI does not accept responsibility for changes in the state of the art, nor for changes in the regulations. PSI believes that the findings and conclusions provided in this report are reasonable. However, no other warranties are implied or expressed.

This report for the above referenced property represents the product of PSI's professional expertise and judgment in the environmental and industrial hygiene consulting industry. This report is certified to, can be relied upon by, and has been prepared for the exclusive use of the client.


PSI appreciates you selecting our services for your needs. Please contact us at 518-377-9841 should you have any questions regarding this report.

Respectfully,

PROFESSIONAL SERVICE INDUSTRIES, INC.



John J. Tranter
District Manager



William A. Kotas
Project Manager



Joseph L. Kuchnicki, CIE, CHMM
Principal Consultant

Appendices:

- A through D: Site Location Maps
- E through H: Laboratory Analysis Reports & Chain-of-Custody

Appendix A


Sampling Site Location Maps for:

Malta Ave Elementary


70 Malta Ave, Ballston Spa, NY 12020

Malta Ave - 1st floor

A red circular stamp, likely a library or archival mark, is located in the upper right corner of the page.



Classroom Sink ●
 Classroom Bubbler ●
 Bathroom Sink ●
 Water Fountain ●




Appendix B

Sampling Site Location Maps for:


Gordon Creek Elementary

50 Wood Rd, Ballston Spa, NY 12020

Classroom Sink ●
Classroom Bubbler ●
Bathroom Sink ●
Water Fountain ●



Gordon Creek - 2nd Floor



Classroom Sink

Classroom Bubbler

Bathroom Sink

Water Fountain

Appendix C


Sampling Site Location Maps for:

Wood Road Elementary

300 Wood Rd, Ballston Spa, NY 12020


Wood Road

- Classroom Sink
- Classroom Budder
- Bathroom Sink
- Water Fountain



Wood Road Kitchen

Sink - ●
Bathroom Sink ●



Appendix D


Sampling Site Location Maps for:

Milton Terrace Elementary

100 Wood Rd, Ballston Spa, NY 12020






Milton Terrace

D-61 92	D-59 91	D-57 90	D-55 89
D-60 93	D-58 94	D-56 95	Bathroom 85 82 83 84



Classroom Sink
Classroom Bubble
Bathroom Sink
Water Fountain

Courtyard



Appendix E

Laboratory Analysis Results for:

Malta Ave Elementary

70 Malta Ave, Ballston Spa, NY 12020

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 7:33 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-003

Client Sample ID. : BOYS L.R. NORTH

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.25		1	ug/L	15	10/19/2016 8:56 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 7:34 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-004

Client Sample ID. : BOYS L.R. SOUTH

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:01 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 7:37 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-005

Client Sample ID. : GIRLS L.R. NORTH

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.64		1	ug/L	15	10/19/2016 9:07 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 7:39 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-006

Client Sample ID. : GIRLS L.R. SOUTH

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.48		1	ug/L	15	10/19/2016 9:33 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 7:46 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-007

Client Sample ID. : HALLWAY W.C.

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:38 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 7:42 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-008

Client Sample ID. : WC EAST GIRLS BATH

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:43 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 7:44 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-009

Client Sample ID. : WC WEST BOYS BATH

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:48 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 7:53 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-010

Client Sample ID. : RM 006 BATH SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:54 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 7:55 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-011

Client Sample ID. : RM 006 CLASS BUBBLER

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:59 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 7:56 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-012

Client Sample ID. : RM 006 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 10:04 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:03 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-013

Client Sample ID. : 13 CLASS 002 BUBBLER

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.03		1	ug/L	15	10/19/2016 10:09 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:04 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-014

Client Sample ID. : 14 CLASS 002 SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.32		1	ug/L	15	10/19/2016 10:36 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:06 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-015

Client Sample ID. : 15 CLASS 001 SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.38		1	ug/L	15	10/19/2016 10:41 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:07 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-016

Client Sample ID. : 16 CLASS 001 BUBBLER

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 10:46 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:13 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-017

Client Sample ID. : 17 WOMENS RESTROOM

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.04		1	ug/L	15	10/19/2016 10:52 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:15 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-018

Client Sample ID. : 18 MENS RESTROOM

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 10:57 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:26 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-019

Client Sample ID. : 19 CLASS 102 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.01		1	ug/L	15	10/19/2016 11:02 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:27 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-020

Client Sample ID. : 20 CLASS 102 BUBBLER

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 11:07 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:27 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-021

Client Sample ID. : 21 CLASS 102 BATH SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00	P	1	ug/L	15	10/19/2016 11:13 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:30 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-022

Client Sample ID. : 22 CLASS 101 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.22		1	ug/L	15	10/19/2016 11:39 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:31 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-023

Client Sample ID. : 23 CLASS 101 BUBBLER

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 11:44 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:32 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-024

Client Sample ID. : 24 CLASS 101 BATH SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.17		1	ug/L	15	10/19/2016 11:49 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:42 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-025

Client Sample ID. : 25 CLASS 103 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.35		1	ug/L	15	10/19/2016 11:55 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:43 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-026

Client Sample ID. : 26 CLASS 103 BUBBLER

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/20/2016 12:00 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:44 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-027

Client Sample ID. : 27 C103 BATH SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.84		1	ug/L	15	10/20/2016 12:05 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:55 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-028

Client Sample ID. : 28 OFFICE BATH SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	13.4		1	ug/L	15	10/20/2016 12:10 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:58 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-029

Client Sample ID. : 29 WATER COOL HALL

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	12.0		1	ug/L	15	10/20/2016 12:16 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 8:59 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-030

Client Sample ID. : 30 BOYS BATH SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/20/2016 12:42 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:01 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-031

Client Sample ID. : 31 GIRLS BATH SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/20/2016 12:47 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:22 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-032

Client Sample ID. : 32 RM 114 BATH SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.68		1	ug/L	15	10/20/2016 12:52 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:23 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-033

Client Sample ID. : 33 RM 114 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.13		1	ug/L	15	10/20/2016 12:58 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD
104 Erie Blvd
Schenectady, NY 12305
Attn To : Nick Nicholas

Lab No. : 1609M16-034
Client Sample ID. : 34 COOLER HALL
70 MALTA AVE. E.S.

Federal ID :

Collected : 09/17/2016 9:26 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/20/2016 1:03 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:30 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-035

Client Sample ID. : 35 RM 110 BATH SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.17		1	ug/L	15	10/20/2016 1:08 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:32 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-036

Client Sample ID. : 36 RM 110 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.37		1	ug/L	15	10/20/2016 1:14 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:36 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-037

Client Sample ID. : 37 RM 112 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	12.9	M+	1	ug/L	15	10/20/2016 1:19 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:39 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-038

Client Sample ID. : 38 CAFETERIA WATER COOLER

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.13		1	ug/L	15	10/20/2016 1:45 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:41 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-039

Client Sample ID. : 39 CAULDRON HOSE

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.06		1	ug/L	15	10/20/2016 1:50 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:42 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-040

Client Sample ID. : 40 KITCHEN NE

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.71		1	ug/L	15	10/20/2016 1:56 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:43 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-041

Client Sample ID. : 41 KITCHEN SE

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.33		1	ug/L	15	10/20/2016 2:01 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:44 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-042

Client Sample ID. : 42 BATH SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.27		1	ug/L	15	10/20/2016 2:06 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:45 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-043

Client Sample ID. : 43 KITCHEN SINK SW

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.73		1	ug/L	15	10/20/2016 2:12 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:53 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-044

Client Sample ID. : 44 RM 211 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	10.7		1	ug/L	15	10/20/2016 2:17 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:55 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-045

Client Sample ID. : 45 RM 213 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 15.5	*	1	ug/L	15	10/20/2016 2:22 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:56 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-046

Client Sample ID. : 46 RM 212 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	14.6		1	ug/L	15	10/20/2016 2:48 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 9:58 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-047

Client Sample ID. : 47 RM 210 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	★ 39.0	*	1	ug/L	15	10/20/2016 2:54 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with ★ Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:00 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-048

Client Sample ID. : 48 WATER COOLER HALL

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/20/2016 2:59 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:09 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-049

Client Sample ID. : 49 RM 214 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	8.63		1	ug/L	15	10/20/2016 3:04 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:15 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-050

Client Sample ID. : 50 GIRLS BATH RM SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.59		1	ug/L	15	10/20/2016 3:10 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:16 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-051

Client Sample ID. : 51 GIRLS B.R. SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.87		1	ug/L	15	10/20/2016 3:15 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:17 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-052

Client Sample ID. : 52 RM 215 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.13		1	ug/L	15	10/20/2016 3:20 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:18 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-053

Client Sample ID. : 53 BOYS BATHROOM SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.93		1	ug/L	15	10/20/2016 3:25 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:19 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-054

Client Sample ID. : 54 HALLWAY W.C.

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/20/2016 3:52 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:28 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-055

Client Sample ID. : 55 RM 205 BUBBLER

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/20/2016 3:57 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:29 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-056

Client Sample ID. : 56 RM 205 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.35		1	ug/L	15	10/20/2016 4:03 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:32 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-057

Client Sample ID. : 57 RM 203 CLASS BUBBLER

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.33		1	ug/L	15	10/20/2016 4:08 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:33 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-058

Client Sample ID. : 58 RM 203 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.77		1	ug/L	15	10/20/2016 4:13 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:35 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-059

Client Sample ID. : 59 RM 201 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.67		1	ug/L	15	10/20/2016 4:18 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:37 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-060

Client Sample ID. : 60 RM 201 BUBBLER

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/20/2016 4:24 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:40 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-061

Client Sample ID. : 61 RM 202 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/20/2016 4:29 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:41 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-062

Client Sample ID. : 62 RM 202 BUBBLER

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/20/2016 4:55 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:47 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-064

Client Sample ID. : 64BOYS SINK S

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/20/2016 5:06 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD
104 Erie Blvd
Schenectady, NY 12305
Attn To : Nick Nicholas

Lab No. : 1609M16-065
Client Sample ID. : 65 WATER COOLER HALLWAY

70 MALTA AVE. E.S.

Federal ID :

Collected : 09/17/2016 10:52 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/20/2016 5:11 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:54 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-066

Client Sample ID. : 66 GIRLS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.19		1	ug/L	15	10/20/2016 5:17 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:55 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-067

Client Sample ID. : 67 GIRLS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/20/2016 5:22 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 10:56 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-068

Client Sample ID. : 68 GIRLS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/20/2016 5:27 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:01 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-069

Client Sample ID. : 69 AUDITORIUM SOUTH

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.26		1	ug/L	15	10/20/2016 5:33 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:02 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-070

Client Sample ID. : 70 AUDITORIUM NORTH

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.28		1	ug/L	15	10/20/2016 5:59 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:06 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-071

Client Sample ID. : 71 RM 231 BUBBLER

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.60		1	ug/L	15	10/20/2016 6:04 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:07 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-072

Client Sample ID. : 72 RM 231 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.79		1	ug/L	15	10/20/2016 6:10 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:17 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-073

Client Sample ID. : 73 RM 231 BATH SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	10.2		1	ug/L	15	10/20/2016 6:15 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:18 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-074

Client Sample ID. : 74 RM 233 BUBBLER

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.47		1	ug/L	15	10/20/2016 6:20 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:19 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-075

Client Sample ID. : 75 RM 233 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.18		1	ug/L	15	10/20/2016 6:26 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:20 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-076

Client Sample ID. : 76 RM 233 BATH SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	12.7		1	ug/L	15	10/20/2016 6:31 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:21 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-077

Client Sample ID. : 77 RM 230 BATH SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.07		1	ug/L	15	10/20/2016 6:36 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:21 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-078

Client Sample ID. : 78 RM 230 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.84		1	ug/L	15	10/20/2016 7:03 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:22 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-079

Client Sample ID. : 79 RM 230 BUBBLER

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.32		1	ug/L	15	10/20/2016 7:08 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:27 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-080

Client Sample ID. : 80 RM 322 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.01		1	ug/L	15	10/20/2016 7:13 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:29 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-081

Client Sample ID. : 81 RM 320 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.53		1	ug/L	15	10/20/2016 7:19 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:33 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-082

Client Sample ID. : 82 BOYS RM SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.75		1	ug/L	15	10/20/2016 7:24 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:34 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-083

Client Sample ID. : 83 BOYS RM SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.53		1	ug/L	15	10/20/2016 7:29 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:37 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-084

Client Sample ID. : 84 GIRLS RM SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.00		1	ug/L	15	10/20/2016 7:35 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:38 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-085

Client Sample ID. : 85 GIRLS RM SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.78		1	ug/L	15	10/20/2016 7:40 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:48 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-086

Client Sample ID. : 86 HALLWAY COOLER (AUDITORIUM)

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 6:53 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:49 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-087

Client Sample ID. : 87 RM 314 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.79		1	ug/L	15	10/19/2016 6:56 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:51 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-088

Client Sample ID. : 88 RM 315 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 32.7	*	1	ug/L	15	10/19/2016 6:59 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:52 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-089

Client Sample ID. : 89 HALLWAY COOLER

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 7:02 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:54 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-090

Client Sample ID. : 90 RM 310 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	9.63		1	ug/L	15	10/19/2016 7:05 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:56 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-091

Client Sample ID. : 91 RM 312 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	12.2		1	ug/L	15	10/19/2016 7:08 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 11:58 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-092

Client Sample ID. : 92 RM 313 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 42.0	*M+	1	ug/L	15	10/19/2016 7:11 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI CSD

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/17/2016 12:00 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DG99

Lab No. : 1609M16-093

Client Sample ID. : 93 RM 311 CLASS SINK

70 MALTA AVE. E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 17.7	*	1	ug/L	15	10/19/2016 7:28 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/20/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



PACE ANALYTICAL
575 Broad Hollow Road
Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
Website: www.pacelabs.com

QC SUMMARY REPORT

WO#: 1609M16

04-Nov-16

Client: PSI CSD
Project: 70 MALTA AVE E.S.

BatchID: R107066

Sample ID	CalBlank	SampType: MBLK	TestCode: 200.8_DW_R			Units: ug/L		Prep Date:			RunNo: 107066		
Client ID:	PBW	Batch ID: R107066	TestNo: E200.8			Analysis Date: 10/19/2016			SeqNo: 2381694				
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual	
Lead		< 1.00	1.00										

Qualifiers:	*	Value exceeds Maximum Contaminant Level	D	Dilution was required.	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	M	Manual Integration used to determine area response	ND	Not Detected at the Reporting Limit
	O	RSD is greater than RSDlimit	P	Second column confirmation exceeds	R	RPD outside accepted recovery limits
	S	Spike Recovery outside accepted recovery limits	W	Sample container temperature is out of limit as specified		



PACE ANALYTICAL
575 Broad Hollow Road
Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
Website: www.pacelabs.com

Sample Receipt Checklist

Client Name **PSIC**

Date and Time Received: **9/22/2016 12:00:00 PM**

Work Order Number: **1609M16**

RcptNo: **1**

Received by **WendyLaMountain**

Completed by: 

Reviewed by: 

Completed Date: 9/26/2016 2:45:55 PM

Reviewed Date: 10/12/2016 1:02:50 PM

Carrier name: Courier

Chain of custody present?	Yes ☒	No ☐		
Chain of custody signed when relinquished and received?	Yes ☒	No ☐		
Chain of custody agrees with sample labels?	Yes ☒	No ☐		
Are matrices correctly identified on Chain of custody?	Yes ☒	No ☐		
Is it clear what analyses were requested?	Yes ☒	No ☐		
Custody seals intact on sample bottles?	Yes ☐	No ☐	Not Present ☒	
Samples in proper container/bottle?	Yes ☒	No ☐		
Were correct preservatives used and noted?	Yes ☒	No ☐	NA ☐	
Preservative added to bottles:				
Sample Condition?	Intact ☒	Broken ☐	Leaking ☐	
Sufficient sample volume for indicated test?	Yes ☒	No ☐		
Were container labels complete (ID, Pres, Date)?	Yes ☒	No ☐		
All samples received within holding time?	Yes ☒	No ☐		
Was an attempt made to cool the samples?	Yes ☐	No ☐	NA ☒	
All samples received at a temp. of > 0° C to 6.0° C?	Yes ☐	No ☐	NA ☒	
Response when temperature is outside of range:				
Sample Temp. taken and recorded upon receipt?	Yes ☐	No ☒	To °	
Water - Were bubbles absent in VOC vials?	Yes ☐	No ☐	No Vials ☒	
Water - Was there Chlorine Present?	Yes ☐	No ☐	NA ☒	
Water - pH acceptable upon receipt?	Yes ☒	No ☐	No Water ☐	
Are Samples considered acceptable?	Yes ☒	No ☐		
Custody Seals present?	Yes ☐	No ☒		
Airbill or Sticker?	Air Bil ☐	Sticker ☐	Not Present ☒	
Airbill No:				

Case Number:

SDG:

SAS:

Any No response should be detailed in the comments section below, if applicable.

Client Contacted? ☐ Yes ☐ No ☒ NA Person Contacted:
Contact Mode: ☐ Phone: ☐ Fax: ☐ Email: ☐ In Person:

Client Instructions:

Date Contacted:

Contacted By:

Regarding:

Comments:

The first 2 samples listed on the COC were not collected per external COC comments. Sample 63 listed on the COC was not collected per external COC comments.

CorrectiveAction:

WorkOrder :
1609M16

Certifications

STATE	CERTIFICATION #
NEW YORK	10478
NEW JERSEY	NY158
CONNECTICUT	PH-0435
MARYLAND	208
MAS S ACHUS E TTS	M-NY026
NE W HAMPS HIRE	2987
RHODE IS LAND	LAO00340
P E NNS YLVANIA	68-00350

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company:	PSI	Report To:	BILL KOTAS	Attention:	
Address:	104 E 9th Blvd. Schenectady NY	Copy To:		Company Name:	
Email To:	BILL@am.kotas.com 12365			Address:	
Phone:	577-9891	Purchase Order No.:		Pace Quote Reference:	
Fax:		Project Name:	70 Malta Ave E.S.	Pace Project Manager:	
Requested Due Date/TAT:	STANDARD	Project Number:		Pace Profile #:	

Page: _____ of _____
 2080833

REGULATORY AGENCY

☐ NPDES
 ☐ GROUND WATER
 ☐ DRINKING WATER

☐ UST
 ☐ RCRA
 ☐ OTHER _____

Site Location
 STATE: _____

NY

[illegible]

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS			Temp in °C	Received on (Y/N)	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)
① & ② water fountains not working	ADP/PSI Carla Delgado-Ruiz	9/19/16	1145 9/22/16 800	DR JR. JMR	9/19/16 9/22/16	1145 12:00							

ORIGINAL

SAMPLER NAME AND SIGNATURE	
PRINT Name of SAMPLER:	DATE Signed (MM/DD/YYYY):
SIGNATURE of SAMPLER:	

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

F-ALL-Q-020rev.07, 15-May-2007

Section A Section B Section C		Section D	
Required Client Information:		Required Project Information:	
Company: <u>PSI</u>	Report To: <u>BILL KOTAS</u>	Invoice Information:	
Address: <u>704 Erie Blvd.</u>	Copy To:	Attention:	
<u>Shenectady NY 12305</u>		Company Name:	
Enail To: <u>WILLIAM.KOTAS@PSIUSA.COM</u>	Purchase Order No.:	Address:	
Phone: <u>379891</u>	Project Name: <u>To Malta Ave C.S.</u>	Pace Quote Reference:	
Fax:	Project Number:	Pace Project Manager:	
Requested Due Date/TAT: <u>STANDARD 17</u>		Pace Profile #:	
Page: _____ of _____		2080834	
REGULATORY AGENCY		REGULATORY AGENCY	
NPDES ☐ GROUND WATER ☐ DRINKING WATER ☐		NPDES ☐ GROUND WATER ☐ DRINKING WATER ☐	
UST ☐ RCRA ☐ OTHER ☐		UST ☐ RCRA ☐ OTHER ☐	
Site Location		Site Location	
STATE: <u>NY</u>		STATE: <u>NY</u>	

[illegible]

Received on Ice (Y/N)	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: <u>PSI</u>	Report To: <u>Bill Kotas</u>	Attention:		Page: _____ of _____	2080837
Address: <u>104 Erie Blvd.</u>	Copy To:	Company Name:			
<u>Schenectady N.Y. 12305</u>		Address:		REGULATORY AGENCY	
Email: <u>WILLIAM.KOTAS@PSIUSA.COM</u>		Pace Quote Reference:		☐ NPDES ☐ GROUND WATER ☐ DRINKING WATER	
Phone: <u>377-9891</u>	Purchase Order No.:			☐ UST ☐ RCRA ☐ OTHER _____	
Fax:	Project Name: <u>70 Malta Ave E.S.</u>	Pace Project Manager:			
Requested Due Date/TAT: <u>STANDARD</u>	Project Number:			Site Location STATE: <u>NY</u>	

[illegible]

ORIGINAL

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER:

SIGNATURE of SAMPLER:

David A. Corke

DATE Signed _____

***Important Note:** By signing this form you are accepting Pace's **NET 30** day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

F-ALL-Q-020rev.07. 15-May-2007

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: PSI	Report To: BILL KOTAS	Attention:	Company Name:	Page: _____ of _____	2080838
Address: 104 Erie Blvd.	Copy To:		Address:	REGULATORY AGENCY	
Schenectady NY 12305			Purchase Order No.:	☐ NPDES ☐ GROUND WATER ☐ DRINKING WATER	
bill@psi.com kotas@psi.com			Project Name: 70 Malta Ave E.S.	☐ UST ☐ RCRA ☐ OTHER	
Phone: 377-9891 Fax:			Pace Project Manager:	Site Location	
Requested Due Date/TAT: STANDARD			Pace Profile #:	STATE: NY	

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE DW WW P SL OL WP AR TS OT	SAMPLE TYPE (G=GRAB C=COMP) (see valid codes to left)	COLLECTED				SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives								Analysis Test ↑	Y / N ↑	Requested Analysis Filtered (Y/N)												Residual Chlorine (Y/N)	Pace Project No./ Lab I.D. 1609 M16																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
				COMPOSITE START	COMPOSITE END/GRAB	DATE	TIME			Unpreserved	H ₂ SO ₄	HNO ₃	HCl	NaOH	Na ₂ S ₂ O ₃	Methanol	Other																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
1	37 Rm 112 class sink			9/17	9:36				1	X																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																									

ORIGINAL		SAMPLER NAME AND SIGNATURE	
		PRINT Name of SAMPLER: Danish A. Garko	DATE Signed (MM/DD/YY): 9/17/16
		SIGNATURE of SAMPLER: <i>[Signature]</i>	

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Requested Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: <u>PSJ</u>	Report To: <u>BILL KOTTS</u>	Attention:		Page: _____ of _____	2080839
Address: <u>141 Epe Blvd.</u>	Copy To:	Company Name:			
<u>Shenectady N.Y 12305</u>		Address:			
Email: <u>William.Kotts@PSIUSA.com</u>	Purchase Order No.:	Pace Quote Reference:			
Phone: <u>377-9891</u>	Project Name: <u>70 Moha Ave E.S.</u>	Pace Project Manager:			
Fax:	Project Number:	Pace Profile #:			
Requested Due Date/TAT: <u>STANDARD</u>					

[illegible]

ORIGINAL

PRINT Name of SAMPLER:
SIGNATURE of SAMPLER:

Daniel A-Gayle	DATE (MM)
<i>[Signature]</i>	

or any invoices not paid within 30 days.

***Important Note:** By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

F-ALL-Q-020rev.07, 15-May-2007

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: PSI	Report To: BILL ROTAS	Attention:	Page: of		
Address: 104 Etna Blvd.	Copy To:	Company Name:	2080840		
City: Schenectady NY 12305	Purchase Order No.:	Address:	REGULATORY AGENCY		
Employee: WILLIAM ROTAS @ PSI@PSI.COM	Project Name: 70 Mafta Ave.	State: NY	☐ NPDES ☐ GROUND WATER ☐ DRINKING WATER ☐ UST ☐ RCRA ☐ OTHER		
Phone: 377-9891 Fax:	Project Number:	Site Location	Pace Project No./ Lab I.D.		
Requested Due Date/TAT: STANDARD		STATE:	160A M16		

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE Drinking Water DW Waste Water WW Product P Soil/Solid SL Oil OL Wipe WP Air TS Tissue OT Other	SAMPLE ID (A-Z, 0-9 / -) Sample IDs MUST BE UNIQUE	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives							Analysis Test Y / N	DATE	TIME	SAMPLE CONDITIONS																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																						
						COMPOSITE START	COMPOSITE END/GRAB			Unpreserved	H ₂ SO ₄	HNO ₃	HCl	NaOH	Na ₂ S ₂ O ₃	Methanol				Other	Accepted By / Affiliation	Date	Time	Ambient	N	Y																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
1	61 RM 202 Class Sink	DW		DW			DATE	TIME	DATE	TIME																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																

SAMPLER NAME AND SIGNATURE		Temp in °C		Received on		Custody		Sealed Cooler		Samples Intact	
PRINT Name of SAMPLER: Daniel A. Gerke											
SIGNATURE of SAMPLER: [Signature]											
DATE Signed (MM/DD/YY): 9/17/10											

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: PSI	Report To: BILL ROTAS	Attention:	Page: of		
Address: 1104 Erie Blvd., Schenectady N.Y. 12306	Copy To:	Company Name:	2080841		
Email: WILLIAM.ROTAS@PSIUSA.COM	Purchase Order No.:	Address:	REGULATORY AGENCY		
Phone: 372.9891 Fax:	Project Name: 70 Malta Ave.	Pace Quote Reference:	☐ NPDES ☐ GROUND WATER ☐ DRINKING WATER ☐ UST ☐ RCRA ☐ OTHER		
Requested Due Date/TAT: STANDARD	Project Number:	Pace Project Manager:	Site Location	STATE: NY	

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE Drinking Water DW Water WWT Waste Water WW Product P Soil/Solid SL Oil OL Wipe WP Air AR Tissue TS Other OT	SAMPLE TYPE (G=GRAB C=COMP) (see valid codes to left)	COLLECTED				SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives								Analysis Test Y/N	Requested Analysis Filtered (Y/N)												Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																	
				COMPOSITE START	COMPOSITE END/GRAB	DATE	TIME			Unpreserved	H ₂ SO ₄	HNO ₃	HCl	NaOH	Na ₂ S ₂ O ₃	Methanol	Other		Y																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														

ORIGINAL		SAMPLER NAME AND SIGNATURE		Temp in °C	Received on	Custody	Sealed Cooler	Samples Intact
		PRINT Name of SAMPLER: David A. Gorko	DATE Signed (MM/DD/YYYY): 9/17/16					

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: PSI	Report To: BILL KOTAS	Attention:	Company Name:	Page: _____ of _____	2080842
Address: 104 Erie Blvd.	Copy To:		Address:	REGULATORY AGENCY	
Phone: 377-9841	Purchase Order No.:		City: _____ State: _____	RCRA ☐ NPDES ☐ GROUND WATER ☐ DRINKING WATER ☐ OTHER ☐	
Requested Due Date: STANDARD	Project Name: 70 Malta Ave E.S.		Pace Quote Reference:	Site Location: NY STATE: _____	
	Project Number:		Pace Project Manager:		

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE Drinking Water Water Waste Water Product Soil/Solid Oil Wipe Air Tissue Other	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives							Analysis Test ↑	Y/N	Requested Analysis Filtered (Y/N)												Pace Project No./ Lab I.D.																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																							
				COMPOSITE START	COMPOSITE END/GRAB			DATE	TIME	DATE	TIME	DATE	TIME	DATE			TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE		TIME	DATE	TIME																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																				
1	85 Girls Rm Sink	Drinking Water	GRAB			9/17	11:38																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													

ORIGINAL	
SAMPLER NAME AND SIGNATURE	DATE Signed (MM/DD/YY):
PRINT Name of SAMPLER: Daniel A. Gerke	9/17/10
SIGNATURE of SAMPLER: <i>[Signature]</i>	

October 18, 2016

Bill Kotas
PSI
104 Erie Blvd
Schenectady, NY 12305

RE: Project: BS CSD - 70 Malta Ave REV
Pace Project No.: 10364811

Dear Bill Kotas:

Enclosed are the analytical results for sample(s) received by the laboratory on October 04, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

Samples, in the electronic data deliverable (EDD) that accompanied this report, were flagged yellow if they exceeded the NYSDOH 15 ppb action level.

The space designated for the sampler on the chain of custody (COC) indicates if these samples were collected by Pace Analytical or were collected by the school district and just relinquished to Pace Analytical.

This report was revised on October 18, 2016 to reference the NYSDOH action level in the cover letter.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Amanda Albrecht
amanda.albrecht@pacelabs.com
Project Manager



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

October 18, 2016
Page 2

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: BS CSD - 70 Malta Ave REV

Pace Project No.: 10364811

Minnesota Certification IDs

1700 Elm Street SE Suite 200, Minneapolis, MN 55414

Alaska Certification UST-107

525 N 8th Street, Salina, KS 67401

A2LA Certification #: 2926.01

Alaska Certification #: UST-078

Alaska Certification #MN00064

Alabama Certification #40770

Arizona Certification #: AZ-0014

Arkansas Certification #: 88-0680

California Certification #: 01155CA

Colorado Certification #Pace

Connecticut Certification #: PH-0256

EPA Region 8 Certification #: 8TMS-L

Florida/NELAP Certification #: E87605

Guam Certification #:14-008r

Georgia Certification #: 959

Georgia EPD #: Pace

Idaho Certification #: MN00064

Hawaii Certification #MN00064

Illinois Certification #: 200011

Indiana Certification#C-MN-01

Iowa Certification #: 368

Kansas Certification #: E-10167

Kentucky Dept of Envi. Protection - DW #90062

Kentucky Dept of Envi. Protection - WW #:90062

Louisiana DEQ Certification #: 3086

Louisiana DHH #: LA140001

Maine Certification #: 2013011

Maryland Certification #: 322

Michigan DEPH Certification #: 9909

Minnesota Certification #: 027-053-137

Mississippi Certification #: Pace

Montana Certification #: MT0092

Nevada Certification #: MN_00064

Nebraska Certification #: Pace

New Jersey Certification #: MN-002

New York Certification #: 11647

North Carolina Certification #: 530

North Carolina State Public Health #: 27700

North Dakota Certification #: R-036

Ohio EPA #: 4150

Ohio VAP Certification #: CL101

Oklahoma Certification #: 9507

Oregon Certification #: MN200001

Oregon Certification #: MN300001

Pennsylvania Certification #: 68-00563

Puerto Rico Certification

Saipan (CNMI) #:MP0003

South Carolina #:74003001

Texas Certification #: T104704192

Tennessee Certification #: 02818

Utah Certification #: MN000642013-4

Virginia DGS Certification #: 251

Virginia/VELAP Certification #: Pace

Washington Certification #: C486

West Virginia Certification #: 382

West Virginia DHHR #:9952C

Wisconsin Certification #: 999407970

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: BS CSD - 70 Malta Ave REV

Pace Project No.: 10364811

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10364811001	MA001 Gym RM 19	Water	09/25/16 13:36	10/04/16 10:00
10364811002	MA002 Gym RM 21	Water	09/25/16 13:38	10/04/16 10:00
10364811003	MA003 & Kitchen	Water	09/25/16 13:42	10/04/16 10:00
10364811004	MA004 Library Sink	Water	09/25/16 13:46	10/04/16 10:00
10364811005	MA005 Boys 2nd Floor	Water	09/25/16 00:00	10/04/16 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: BS CSD - 70 Malta Ave REV

Pace Project No.: 10364811

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10364811001	MA001 Gym RM 19	EPA 200.8	RJS	1	PASI-M
10364811002	MA002 Gym RM 21	EPA 200.8	RJS	1	PASI-M
10364811003	MA003 & Kitchen	EPA 200.8	RJS	1	PASI-M
10364811004	MA004 Library Sink	EPA 200.8	RJS	1	PASI-M
10364811005	MA005 Boys 2nd Floor	EPA 200.8	RJS	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - 70 Malta Ave REV

Pace Project No.: 10364811

Sample: MA001 Gym RM 19		Lab ID: 10364811001	Collected: 09/25/16 13:36	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	15.3	ug/L	0.10	1		10/06/16 20:09	7439-92-1	
Sample: MA002 Gym RM 21		Lab ID: 10364811002	Collected: 09/25/16 13:38	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	20.4	ug/L	0.10	1		10/06/16 20:27	7439-92-1	
Sample: MA003 & Kitchen		Lab ID: 10364811003	Collected: 09/25/16 13:42	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	11.6	ug/L	0.10	1		10/06/16 20:30	7439-92-1	
Sample: MA004 Library Sink		Lab ID: 10364811004	Collected: 09/25/16 13:46	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.7	ug/L	0.10	1		10/06/16 20:33	7439-92-1	
Sample: MA005 Boys 2nd Floor		Lab ID: 10364811005	Collected: 09/25/16 00:00	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.82	ug/L	0.10	1		10/06/16 20:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: BS CSD - 70 Malta Ave REV

Pace Project No.: 10364811

QC Batch:	439382	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	ICPMS Metals, Drinking Water
Associated Lab Samples:	10364811001, 10364811002, 10364811003, 10364811004, 10364811005		

METHOD BLANK:	2387317	Matrix:	Water
Associated Lab Samples:	10364811001, 10364811002, 10364811003, 10364811004, 10364811005		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/06/16 20:03	

LABORATORY CONTROL SAMPLE: 2387318						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	110	110	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2389428 2389429												
Parameter	Units	10364811001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	15.3	100	100	114	112	99	96	70-130	2	20	

MATRIX SPIKE SAMPLE: 2389430								
Parameter	Units	10364808035 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers	
Lead	ug/L	2.8	100	103	100	70-130		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: BS CSD - 70 Malta Ave REV
Pace Project No.: 10364811

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

LABORATORIES

PASI-M Pace Analytical Services - Minneapolis

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: BS CSD - 70 Malta Ave REV

Pace Project No.: 10364811

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10364811001	MA001 Gym RM 19	EPA 200.8	439382		
10364811002	MA002 Gym RM 21	EPA 200.8	439382		
10364811003	MA003 & Kitchen	EPA 200.8	439382		
10364811004	MA004 Library Sink	EPA 200.8	439382		
10364811005	MA005 Boys 2nd Floor	EPA 200.8	439382		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

[illegible]

	Document Name: Sample Condition Upon Receipt Form	Document Revised: 02Aug2016 Page 1 of 2
	Document No.: F-MN-L-213-rev.17	Issuing Authority: Pace Minnesota Quality Office

Sample Condition Upon Receipt	Client Name: <u>PSI</u>	Project #: WO# : 10364811
		

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client
☐ Commercial ☐ Pace ☐ Speedee ☐ Other: _____
Tracking Number: 7773 8098 0199

Custody Seal on Cooler/Box Present? ☒ Yes ☐ No Seals Intact? ☒ Yes ☐ No Optional: Proj. Due Date: _____ Proj. Name: _____

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☒ None ☐ Other: _____ Temp Blank? ☐ Yes ☒ No

Thermometer Used: ☒ 151401163 ☐ 151401164 ☐ B88A912167504 ☐ B88A0143310098 Type of Ice: ☐ Wet ☐ Blue ☒ None ☐ Samples on ice, cooling process has begun

Cooler Temp Read (°C): 17.8 Cooler Temp Corrected (°C): 18.0 Biological Tissue Frozen? ☐ Yes ☐ No ☒ N/A
Temp should be above freezing to 6°C Correction Factor: +0.2 Date and Initials of Person Examining Contents: BC 10/4/16

USDA Regulated Soil (☒ N/A, water sample)
Did samples originate in a quarantine zone within the United States: AL, AR, AZ, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX or VA (check maps)? ☐ Yes ☐ No Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? ☐ Yes ☐ No
If Yes to either question, fill out a Regulated Soil Checklist (F-MN-Q-338) and include with SCUR/COC paperwork.

	COMMENTS:
Chain of Custody Present? ☒ Yes ☐ No ☐ N/A	1.
Chain of Custody Filled Out? ☒ Yes ☐ No ☐ N/A	2.
Chain of Custody Relinquished? ☐ Yes ☐ No ☐ N/A	3.
Sampler Name and/or Signature on COC? ☒ Yes ☐ No ☐ N/A	4.
Samples Arrived within Hold Time? ☒ Yes ☐ No ☐ N/A	5.
Short Hold Time Analysis (<72 hr)? ☐ Yes ☒ No ☐ N/A	6.
Rush Turn Around Time Requested? ☐ Yes ☒ No ☐ N/A	7.
Sufficient Volume? ☒ Yes ☐ No ☐ N/A	8.
Correct Containers Used? ☒ Yes ☐ No ☐ N/A	9.
-Pace Containers Used? ☒ Yes ☐ No ☐ N/A	
Containers Intact? ☐ Yes ☐ No ☐ N/A	10.
Filtered Volume Received for Dissolved Tests? <u>BC 10/4/16</u> ☒ Yes ☐ No ☒ N/A	11. Note if sediment is visible in the dissolved container
Sample Labels Match COC? ☒ Yes ☐ No ☐ N/A	12.
-Includes Date/Time/ID/Analysis Matrix: <u>WT</u>	
All containers needing acid/base preservation have been checked? ☒ Yes ☐ No ☐ N/A	13. ☒ HNO ₃ ☐ H ₂ SO ₄ ☐ NaOH ☐ HCl
All containers needing preservation are found to be in compliance with EPA recommendation? ☒ Yes ☐ No ☐ N/A	Sample # <u>1.1</u>
(HNO ₃ , H ₂ SO ₄ , HCl<2; NaOH >9 Sulfide, NaOH>12 Cyanide) Exceptions: VOA, Coliform, TOC, Oil and Grease, DRO/8015 (water) DOC ☐ Yes ☐ No ☒ N/A	Initial when completed: _____ Lot # of added preservative: _____
Headspace in VOA Vials (>6mm)? ☐ Yes ☐ No ☒ N/A	14.
Trip Blank Present? ☐ Yes ☐ No ☒ N/A	15.
Trip Blank Custody Seals Present? ☐ Yes ☐ No ☒ N/A	
Pace Trip Blank Lot # (if purchased): _____	

CLIENT NOTIFICATION/RESOLUTION Field Data Required? ☐ Yes ☐ No

Person Contacted: _____ Date/Time: _____

Comments/Resolution: Temp OK

Project Manager Review: _____ **Date:** 10/05/16

Note: Whenever there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEHNR Certification Office (i.e out of hold, incorrect preservative, out of temp, incorrect containers).

Appendix F

Laboratory Analysis Results for:

Gordon Creek Elementary

50 Wood Rd, Ballston Spa, NY 12020

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 7:40 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-001

Client Sample ID. : 1 BATHROOM SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 7:31 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 7:41 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-002

Client Sample ID. : 2 KITCHEN SINK (ADJ TO W/IN FRIDGE)

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 7:34 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 7:42 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-003

Client Sample ID. : 3 KITCHEN SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 7:37 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 7:44 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-004

Client Sample ID. : 4 CAULDRON HOSE

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 7:40 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 7:46 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-005

Client Sample ID. : 5 K SINK (BUFFET TABLE) PREP

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 7:43 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 7:47 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-006

Client Sample ID. : 6 K SINK (MEAT CUTTER)

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 7:46 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 7:48 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-007

Client Sample ID. : 7 K SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 7:48 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 7:49 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-008

Client Sample ID. : 8 K SINK (DISH WASHING)

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 8:03 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 7:54 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-009

Client Sample ID. : 9 HALLWAY WATER FOUNT BOYS

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 8:06 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 7:55 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-010

Client Sample ID. : 10 HALLWAY WATER FOUNT GIRLS

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 8:09 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 7:57 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-011

Client Sample ID. : 11 BOYS BATH SINK (LEFT)

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 8:12 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 7:58 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-012

Client Sample ID. : 12 BOY BATH SINK CTR

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 8:15 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:09 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-013

Client Sample ID. : 13 BOY BATH SINK RIGHT

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 8:18 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:10 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-014

Client Sample ID. : 14 GIRLS BATH SINK LEFT

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 8:21 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:11 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-015

Client Sample ID. : 15 GIRLS BATH SINK CTR

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.01		1	ug/L	15	10/19/2016 8:24 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:12 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-016

Client Sample ID. : 16 GIRLS BATH SINK RIGHT

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.88		1	ug/L	15	10/19/2016 8:38 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:19 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-017

Client Sample ID. : 17 RM 129 CLASS SINK INT BELS

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 8:41 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:20 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-018

Client Sample ID. : 18 RM 129 CLASS SINK EXT

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 8:44 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:21 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-019

Client Sample ID. : 19 RM 129 BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.93		1	ug/L	15	10/19/2016 8:47 PM	

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:24 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-020

Client Sample ID. : 20 RM 102 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 8:50 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:25 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-021

Client Sample ID. : 21 RM 102 BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 8:53 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:26 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-022

Client Sample ID. : 22 RM 102 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.41		1	ug/L	15	10/19/2016 8:56 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:30 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-023

Client Sample ID. : 23 RM 104 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 8:58 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:31 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-024

Client Sample ID. : 24 RM 104 BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:13 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:43 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-025

Client Sample ID. : 25 CLASS 104 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:16 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:45 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-026

Client Sample ID. : 26 CLASS 108 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:19 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:46 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-027

Client Sample ID. : 27 CLASS 108 BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:22 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:47 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-028

Client Sample ID. : 28 CLASS 108 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:25 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:51 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-029

Client Sample ID. : 29 CLASS 110 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:28 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 8:52 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-030

Client Sample ID. : 30 CLASS 110 BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:31 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:00 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-033

Client Sample ID. : 33 RM 109 BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:33 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:01 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-034

Client Sample ID. : 34 RM 109 CLASSS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:48 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:02 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-035

Client Sample ID. : 35 RM 107 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:51 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:03 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-036

Client Sample ID. : 36 RM 107 BATH

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:54 PM	

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:13 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-037

Client Sample ID. : 37 RM 107 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 9:57 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:15 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-038

Client Sample ID. : 38 RM 103 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 10:00 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water

Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:16 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-039

Client Sample ID. : 39 RM 103 BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 10:03 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:17 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-040

Client Sample ID. : 40 RM 103 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/19/2016 10:06 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:19 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-041

Client Sample ID. : 41 RM 101 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.00	M+	1	ug/L	15	10/28/2016 7:44 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:20 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-042

Client Sample ID. : 42 RM 101 BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.63		1	ug/L	15	10/28/2016 7:26 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:21 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-043

Client Sample ID. : 43 RM 101 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 7:29 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:26 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-044

Client Sample ID. : 44 FACULTY BATH

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 7:32 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:27 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-045

Client Sample ID. : 45 UNISEX BATH

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 7:35 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:30 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-046

Client Sample ID. : 46 RM 127 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 7:38 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:31 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-047

Client Sample ID. : 47 RM 125 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 7:41 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:34 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-048

Client Sample ID. : 48 BOYS BATH ENT.

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 8:02 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:44 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-049

Client Sample ID. : 49 BOYS BATH

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00	M-	1	ug/L	15	10/28/2016 8:22 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:45 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-050

Client Sample ID. : 50 GIRLS BATH

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 8:04 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:46 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-051

Client Sample ID. : 51 GIRLS BATH ENT.

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 8:07 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:48 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-052

Client Sample ID. : 52 WATER COOLER TALL

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 8:10 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:49 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-053

Client Sample ID. : 53 WATER COOLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 8:13 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:51 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-054

Client Sample ID. : 54 RM 112 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.60		1	ug/L	15	10/28/2016 8:16 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:52 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-055

Client Sample ID. : 55 RM 112 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.15		1	ug/L	15	10/28/2016 8:19 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:53 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-056

Client Sample ID. : 56 RM 114 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.12		1	ug/L	15	10/28/2016 8:37 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:54 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-057

Client Sample ID. : 57 RM 114 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.46	M+	1	ug/L	15	10/28/2016 8:57 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:56 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-058

Client Sample ID. : 58 RM 118 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 8:40 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:57 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-059

Client Sample ID. : 59 RM 118 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 8:43 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 9:58 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-060

Client Sample ID. : 60 RM 118 BATH

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 8:45 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:09 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-061

Client Sample ID. : 61 RM 120 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 8:48 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:10 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-062

Client Sample ID. : 62 RM 120 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.02		1	ug/L	15	10/28/2016 8:51 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:11 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-063

Client Sample ID. : 63 RM 120 BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 8:54 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:13 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-064

Client Sample ID. : 64 RM 122 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 9:12 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:14 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-065

Client Sample ID. : 65 RM 122 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00	M+	1	ug/L	15	10/28/2016 9:32 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:15 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-066

Client Sample ID. : 66 RM 122 BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 9:15 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:17 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-067

Client Sample ID. : 67 RM 121 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.57		1	ug/L	15	10/28/2016 9:18 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:18 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-068

Client Sample ID. : 68 RM 121 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 9:21 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:19 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-069

Client Sample ID. : 69 RM 121 BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 9:23 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:21 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-070

Client Sample ID. : 70 RM 119 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.25		1	ug/L	15	10/28/2016 9:26 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:22 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-071

Client Sample ID. : 71 RM 119 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 9:29 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:23 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-072

Client Sample ID. : 72 RM 119 BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 9:47 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:37 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-073

Client Sample ID. : 73 RM 117 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 10:07 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:38 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-074

Client Sample ID. : 74 RM 117 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 9:50 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:39 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-075

Client Sample ID. : 75 RM 117 BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 9:53 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:43 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-076

Client Sample ID. : 76 RM 113 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.05		1	ug/L	15	10/28/2016 9:56 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:44 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-077

Client Sample ID. : 77 RM 113 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.30		1	ug/L	15	10/28/2016 9:59 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:46 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-078

Client Sample ID. : 78 RM 111 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 10:01 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 10:47 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-079

Client Sample ID. : 79 RM 111 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 10:04 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 11:45 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-080

Client Sample ID. : 80 RM 212 BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	11.5		1	ug/L	15	10/28/2016 10:22 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 11:46 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-081

Client Sample ID. : 81 RM 212 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.60		1	ug/L	15	10/28/2016 10:42 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 11:47 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-082

Client Sample ID. : 82 RM 212 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.15		1	ug/L	15	10/28/2016 10:25 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 11:50 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-083

Client Sample ID. : 83 RM 214 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.10		1	ug/L	15	10/28/2016 10:28 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 11:51 AM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-084

Client Sample ID. : 84 RM 214 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.91		1	ug/L	15	10/28/2016 10:31 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:03 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-085

Client Sample ID. : 85 RM 216 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.98		1	ug/L	15	10/28/2016 10:34 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:04 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-086

Client Sample ID. : 86 RM 216 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.73		1	ug/L	15	10/28/2016 10:37 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:06 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-087

Client Sample ID. : 87 RM 218 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 10:40 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:07 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-088

Client Sample ID. : 88 RM 218 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 10:57 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:09 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-089

Client Sample ID. : 89 RM 222 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00	M+	1	ug/L	15	10/28/2016 11:18 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:10 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-090

Client Sample ID. : 90 RM 222 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.22		1	ug/L	15	10/28/2016 11:00 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:12 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-091

Client Sample ID. : 91 RM 223 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 11:03 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:13 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-092

Client Sample ID. : 92 RM 223 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 11:06 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:15 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-093

Client Sample ID. : 93 RM 219 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.38		1	ug/L	15	10/28/2016 11:09 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:16 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-094

Client Sample ID. : 94 RM 219 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 11:12 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:18 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-095

Client Sample ID. : 95 RM 217 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.70		1	ug/L	15	10/28/2016 11:15 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:19 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-096

Client Sample ID. : 96 RM 217 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.89		1	ug/L	15	10/28/2016 11:32 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:26 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-097

Client Sample ID. : 97 RM 215 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.34		1	ug/L	15	10/28/2016 11:53 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:27 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-098

Client Sample ID. : 98 RM 215 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.09		1	ug/L	15	10/28/2016 11:35 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:32 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-099

Client Sample ID. : 99 WATER FOUNTAIN

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 11:38 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:33 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-100

Client Sample ID. : 100 WATER FOUNTAIN TALL

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 11:41 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:34 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-101

Client Sample ID. : 101 GIRLS BATH SINK ENT

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 11:44 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:35 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-102

Client Sample ID. : 102 GIRLS BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 11:47 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:36 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-103

Client Sample ID. : 103 BOYS BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/28/2016 11:50 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:45 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-105

Client Sample ID. : 105 RM 225 CLASS SINK W

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.16		1	ug/L	15	10/29/2016 12:07 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:46 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-106

Client Sample ID. : 106 RM 225 CLASS S. SOUTH

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.02	M+	1	ug/L	15	10/29/2016 12:28 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:47 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-107

Client Sample ID. : 107 GIRLS BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 12:10 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 12:48 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-108

Client Sample ID. : 108 GIRLS BATH SINK ENT

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 12:13 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:01 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-109

Client Sample ID. : 109 GIRLS BATH SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 12:16 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:02 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-110

Client Sample ID. : 110 GIRLS BATH SINK ENT

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 12:19 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:04 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-111

Client Sample ID. : 111 RM 201 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 12:22 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:05 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-112

Client Sample ID. : 112 RM 201 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.75		1	ug/L	15	10/29/2016 12:25 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:06 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-113

Client Sample ID. : 113 RM 203 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.72		1	ug/L	15	10/29/2016 12:43 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:07 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-114

Client Sample ID. : 114 RM 203 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00	M+	1	ug/L	15	10/29/2016 1:03 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:09 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-115

Client Sample ID. : 115 RM 207 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.38		1	ug/L	15	10/29/2016 12:46 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:10 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-116

Client Sample ID. : 116 RM 207 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 12:48 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:11 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-117

Client Sample ID. : 117 RM 209 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 12:51 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:12 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-118

Client Sample ID. : 118 RM 209 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 12:54 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:13 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-119

Client Sample ID. : 119 RM 210 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.20		1	ug/L	15	10/29/2016 12:57 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:14 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-120

Client Sample ID. : 120 RM 210 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.17		1	ug/L	15	10/29/2016 1:00 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:27 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-121

Client Sample ID. : 121 RM 208 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 1:18 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:28 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-122

Client Sample ID. : 122 RM 208 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 1:38 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:32 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-123

Client Sample ID. : 123 RM 204 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.31		1	ug/L	15	10/29/2016 1:21 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:40 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-124

Client Sample ID. : 124 RM 204 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 1:24 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:42 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-125

Client Sample ID. : 125 RM 202 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.79		1	ug/L	15	10/29/2016 1:27 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:43 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-126

Client Sample ID. : 126 RM 202 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 1:29 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:45 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-127

Client Sample ID. : 127 RM 228 CLASS SINK

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.37		1	ug/L	15	10/29/2016 1:32 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:46 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-128

Client Sample ID. : 128 RM 228 BUBBLER

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 1:35 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:49 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-129

Client Sample ID. : 129 UNISEX BATH

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 1:53 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:50 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-130

Client Sample ID. : 130 FACULTY BATH

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00	M+	1	ug/L	15	10/29/2016 2:10 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.


S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:51 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-131

Client Sample ID. : 131 TEACHERS LOUNGE

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 1:56 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:53 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-132

Client Sample ID. : 132 WATER FOUNTAIN TALL

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 1:59 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 1:54 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-133

Client Sample ID. : 133 WATER FOUNTAIN

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 2:02 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 2:27 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-134

Client Sample ID. : 134 CAFETERIA STEAM TABLE

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.00		1	ug/L	15	10/29/2016 2:05 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Distribution

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

PSI

104 Erie Blvd

Schenectady, NY 12305

Attn To : Nick Nicholas

Federal ID :

Collected : 09/18/2016 2:32 PM Point No

Received : 09/22/2016 12:00 PM Location:

Collected By : DF99

Lab No. : 1609M60-135

Client Sample ID. : 135 EYE WASH/SINK CAFETERIA

GORDON CREEK E.S.

Analytical Method: E200.8 : IOC

Analyst: CM

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.72		1	ug/L	15	10/29/2016 2:08 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with * Exceed Regulatory Limit(s). Limit noted.

Date Reported : 11/3/2016



Project Manager : Wayne Bryce

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



PACE ANALYTICAL
575 Broad Hollow Road
Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
Website: www.pacelabs.com

QC SUMMARY REPORT

WO#: 1609M60

04-Nov-16

Client: PSI

Project: GORDON CREEK E.S.

BatchID: R107066

Sample ID	CalBlank	SampType: MBLK	TestCode: 200.8_DW_R	Units: ug/L	Prep Date:	RunNo: 107066
Client ID:	PBW	Batch ID: R107066	TestNo: E200.8	Analysis Date: 10/19/2016	SeqNo: 2381694	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead		< 1.00	1.00			

Qualifiers:	* Value exceeds Maximum Contaminant Level	D Dilution was required.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	M Manual Integration used to determine area response	ND Not Detected at the Reporting Limit
	O RSD is greater than RSDlimit	P Second column confirmation exceeds	R RPD outside accepted recovery limits
	S Spike Recovery outside accepted recovery limits	W Sample container temperature is out of limit as specified	



PACE ANALYTICAL
575 Broad Hollow Road
Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
Website: www.pacelabs.com

QC SUMMARY REPORT

WO#: 1609M60

04-Nov-16

Client: PSI

Project: GORDON CREEK E.S.

BatchID: R107103

Sample ID	CalBlank	SampType: MBLK	TestCode: 200.8_DW_R	Units: ug/L	Prep Date:	RunNo: 107103
Client ID:	PBW	Batch ID: R107103	TestNo: E200.8	Analysis Date: 10/28/2016	SeqNo: 2384047	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead		< 1.00	1.00			

Qualifiers:	* Value exceeds Maximum Contaminant Level	D Dilution was required.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	M Manual Integration used to determine area response	ND Not Detected at the Reporting Limit
	O RSD is greater than RSDlimit	P Second column confirmation exceeds	R RPD outside accepted recovery limits
	S Spike Recovery outside accepted recovery limits	W Sample container temperature is out of limit as specified	



PACE ANALYTICAL
575 Broad Hollow Road
Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
Website: www.pacelabs.com

Sample Receipt Checklist

Client Name **PSIC**

Date and Time Received: **9/22/2016 12:00:00 PM**

Work Order Number: **1609M60**

RcptNo: **1**

Received by **WendyLaMountain**

Completed by:

Reviewed by:

Completed Date: 9/27/2016 9:56:17 AM

Reviewed Date:

Carrier name: Courier

Chain of custody present?	Yes ☒	No ☐		
Chain of custody signed when relinquished and received?	Yes ☒	No ☐		
Chain of custody agrees with sample labels?	Yes ☒	No ☐		
Are matrices correctly identified on Chain of custody?	Yes ☒	No ☐		
Is it clear what analyses were requested?	Yes ☒	No ☐		
Custody seals intact on sample bottles?	Yes ☐	No ☐	Not Present	☒
Samples in proper container/bottle?	Yes ☒	No ☐		
Were correct preservatives used and noted?	Yes ☒	No ☐	NA	☐
Preservative added to bottles:				
Sample Condition?	Intact ☒	Broken ☐	Leaking	☐
Sufficient sample volume for indicated test?	Yes ☒	No ☐		
Were container labels complete (ID, Pres, Date)?	Yes ☒	No ☐		
All samples received within holding time?	Yes ☒	No ☐		
Was an attempt made to cool the samples?	Yes ☐	No ☐	NA	☒
All samples received at a temp. of > 0° C to 6.0° C?	Yes ☐	No ☐	NA	☒
Response when temperature is outside of range:				
Sample Temp. taken and recorded upon receipt?	Yes ☐	No ☒	To	°
Water - Were bubbles absent in VOC vials?	Yes ☐	No ☐	No Vials	☒
Water - Was there Chlorine Present?	Yes ☐	No ☐	NA	☒
Water - pH acceptable upon receipt?	Yes ☐	No ☐	No Water	☒
Are Samples considered acceptable?	Yes ☒	No ☐		
Custody Seals present?	Yes ☐	No ☒		
Airbill or Sticker?	Air Bil ☐	Sticker ☐	Not Present	☒
Airbill No:				

Case Number:

SDG:

SAS:

Any No response should be detailed in the comments section below, if applicable.

Client Contacted? ☐ Yes ☐ No ☒ NA Person Contacted:
Contact Mode: ☐ Phone: ☐ Fax: ☐ Email: ☐ In Person:
Client Instructions:
Date Contacted: Contacted By:
Regarding:
Comments:
samples 31, 32, and 104 listed on the COC were not collected per external COC comments.
CorrectiveAction:

WorkOrder :
1609M60

Certifications

STATE	CERTIFICATION #
NEW YORK	10478
NEW JERSEY	NY158
CONNECTICUT	PH-0435
MARYLAND	208
MAS S ACHUS E TTS	M-NY026
NE W HAMPS HIRE	2987
RHODE IS LAND	LAO00340
P E NNS YLVANIA	68-00350

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: RSI	Report To: Bill Kotas	Attention:	Company Name:	Page: 2080843	of
Address: 104 Erie Blvd.	Copy To:		Address:	REGULATORY AGENCY	
City/State/Zip: Schenectady NY 12305			Pace Quote Reference:	☐ NPDES ☐ GROUND WATER ☐ DRINKING WATER	
Email: WILLIAM.KOTAS@RUSA.COM			Pace Project Manager:	☐ LST ☐ RCRA ☐ OTHER	
Phone: 377-9991 Fax:	Project Name: Gordon Creek E.S.		Pace Profile #:	Site Location	
Requested Due Date/TAT: STANDARD	Project Number:			STATE: NY	

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE Drinking Water WT Water WW Waste Water Product P Soil/Solid OL Oil WP Wipe AR Air TS Tissue OT Other	SAMPLE TYPE (G=GRAB C=COMP) (see valid codes to left)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives Unpreserved H ₂ SO ₄ HNO ₃ HCl NaOH Na ₂ S ₂ O ₃ Methanol Other	Analysis Test ↑ Y/N	Requested Analysis Filtered (Y/N)										Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														
				COMPOSITE START	COMPOSITE END/GRAB					DATE	TIME	DATE	TIME																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																						
1	Bathroom sink (bag to with grab)	WW		9/18	7:40		1																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												

ORIGINAL	
SAMPLER NAME AND SIGNATURE	
PRINT Name of SAMPLER: Dan A. Gerke	DATE Signed (MM/DD/YY): 9/18/16
SIGNATURE of SAMPLER: <i>[Signature]</i>	

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoice not paid within 30 days.

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: PSI	Report To: Bill Kotas	Attention:		Page: _____ of _____	2080844
Address: 104 Erie Blvd.	Copy To:	Company Name:			
Schenectady NY 12305		Address:			
Email: WILLIAM.KOTAS@PSIUSA.COM	Purchase Order No.:	Pace Quote Reference:			
Phone: 377-9891	Project Name: Gordon Creek E.S.	Pace Project Manager:			
Fax:	Project Number:	Pace Profile #:			
Requested Due Date/TAT: STANDARD					

[illegible]

ORIGINAL

PRINT Name of SAMPLER:
SIGNATURE of SAMPLER:

DATE Signed
(MM/DD/YY): 2/18/16

Received on Ice (Y/N)	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



www.pacelabs.com

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: PSI	Report To: Bill Rottas	Attention:	Company Name:	Page: 2080845	of
Address: 104 Ene Blvd.	Copy To:	Company Name:	Address:	REGULATORY AGENCY	
City/State/Zip: Chenactedady NY 12305	Purchase Order No.:	Address:	NPDES ☐ GROUND WATER ☐ DRINKING WATER		
Phone: 518.401.1010	Project Name: Gordon Creek E.S.	Pace Quote Reference:	UST ☐ RCRA ☐ OTHER ☐		
Fax: 377-9891	Project Number:	Pace Project Manager:	Site Location STATE: NY		
Requested Due Date/TAT: STANDARD		Pace Profile #:			

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives							Analysis Test ☒	Temp in °C	Received on	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)
				COMPOSITE START	COMPOSITE END/GRAB			H ₂ SO ₄	HNO ₃	HCl	NaOH	Na ₂ S ₂ O ₃	Methanol	Other					
1	25 Class 104 Bubler	Drinking Water	GR	DATE	TIME	DATE	TIME												
2	26 Class 108 Class Sink	Water		9/18	8:43														
3	27 Class 108 Bath Sink	Waste Water			8:45														
4	28 Class 108 Bubler	Product			8:46														
5	29 Class 110 Class Sink	Soil/Solid			8:47														
6	30 Class 110 Bath Sink	Oil			8:51														
7	31 Class 110 Bubler	Wipe			8:52														
8	32 RM 109 Bubler	Air																	
9	33 RM 109 Bath Sink	Tissue			9:00														
10	34 RM 109 Class Sink	Other			9:01														
11	35 RM 107 Bubler				9:02														
12	36 RM 107 Bath				9:03														
ADDITIONAL COMMENTS		RELINQUISHED BY / AFFILIATION		DATE		TIME		ACCEPTED BY / AFFILIATION		DATE		TIME		SAMPLE CONDITIONS					
* 31 no bubler in		PSI		9/18/16		11:45		Cin. Nollman		9/18/16		11:45		N W Y					
RM 110		Cin. Nollman/Case		9/18/16		15:00		800		9/19/19									
* 32 no rm 109 bubler										9/21/16		12:00		N N Y					

ORIGINAL		SAMPLER NAME AND SIGNATURE	
PRINT Name of SAMPLER:	Daniel A. Gerke	DATE Signed (MM/DD/YY):	9/18/16
SIGNATURE of SAMPLER:	<i>[Signature]</i>		

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

[illegible]

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company:	PSI	Report To:	Bill Kotas	Attention:	
Address:	104 Erie Blvd.	Copy To:		Company Name:	
City:	Schenectady NY 12305			Address:	
Phone:	518-377-9891	Purchase Order No.:		Pace Quote Reference:	
Fax:		Project Name:	Gordon Creek E.S.	Pace Project Manager:	
Requested Due Date/TAT:	STANDARD	Project Number:		Pace Profile #:	
REGULATORY AGENCY			REGULATORY AGENCY		
☐ NPDES ☐ GROUND WATER ☐ DRINKING WATER ☐ UST ☐ RCRA ☐ OTHER			☐ NPDES ☐ GROUND WATER ☐ DRINKING WATER ☐ UST ☐ RCRA ☐ OTHER		
Site Location		NY STATE:			

[illegible]

ORIGINAL

PR NAME AND SIGNATURE

PRINT Name of SAMPLER:

SIGNATURE of SAMPLER:

DATE	DATE SIGNED
10/10/2019	A. Gerke

Received on Ice (Y/N)	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)

***Important Note:** By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

F-ALL-Q-020rev.07, 15-May-2007

Section A Requested Client Information: Company: <u>PSI</u> Address: <u>104 Erie Blvd.</u> <u>Shenectady NY 12305</u> Attention: <u>Mr. Robert B. Bickel</u> Phone: <u>315-9891</u> Fax: _____ Requested Due Date/TAT: <u>STANDARD</u>		Section B Required Project Information: Report To: <u>Bill Kotter</u> Copy To: _____ Purchase Order No.: _____ Project Name: <u>Gordon Creek E.S.</u> Project Number: _____		Section C Invoice Information: Attention: _____ Company Name: _____ Address: _____ Pace Quote Reference: _____ Pace Project Manager: _____ Pace Profile #: _____		Page: _____ of _____ 2080848 REGULATORY AGENCY ☐ NPDES ☐ GROUND WATER ☐ DRINKING WATER ☐ LST ☐ RCRA ☐ OTHER _____ Site Location: <u>NY</u> STATE: _____	

[illegible]

Temp in °C	Received on Ice (Y/N)	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: PSI	Report To: BILL KOTHS	Attention:		Page: _____ of _____	2080849
Address: 104 E 7th Blvd. Schenectady NY 12305	Copy To:	Company Name:			
William. KOTHKE@PSIUSA.COM Email To:		Address:		REGULATORY AGENCY ☐ NPDES ☐ GROUND WATER ☐ DRINKING WATER ☐ UST ☐ RCRA ☐ OTHER _____	
Phone: 377-9891	Purchase Order No.:	Pace Quote Reference:		Site Location	
Fax:	Project Name: Gordons Creek P.S.	Pace Project Manager:		STATE:	NY
Requested Due Date/TAT: STANDARD	Project Number:	Pace Profile #:			

[illegible]

ORIGINAL

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER:

PRINT Name of SAMPLER:

Dear Gerke

DATE Signed
(MM/DD/YY):DATE Signed
(MM/DD/YY):

***Important Note:** By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

F-ALL-Q-020rev.07, 15-May-2007

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Requested Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company:	PSI	Report To:	BILL KOTAS	Attention:	
Address:	104 Erie Blvd.	Copy To:		Company Name:	
	Shenectady NY 12305			Address:	
Email:	WILLIAM.KOTAS@PSI.USA.COM	Purchase Order No.:		Pace Quote Reference:	
Phone:	377-9891	Project Name:	Gordon Creek E.S.	Pace Project Manager:	
Fax:		Project Number:		Pace Profile #:	
Requested Due Date/TAT: STANDARD					

[illegible]

ORIGINAL

R NAME AND SIGNATURE PRINT NAME of SAMPLER: <u>Dana A. Gerke</u> SIGNATURE of SAMPLER: <u>[Signature]</u>	DATE Signed	Temp in °C	Received on	Custody	Samples Intact
	(MM/DD/YY):		(Y/N)	(Y/N)	(Y/N)
	9/18/16				

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: PSI	Report To: Bill Kotas	Attention:	Company Name:	Page: _____ of _____	
Address: 104 Erie Blvd.	Copy To:		Address:	2082500	
Schenectady NY 12305			Pace Quote Reference:		
WILLIAM KOTAS @PSIUSA.COM			Pace Project Manager:		
Phone: 377-9891 Fax:			Pace Profile #:		
Requested Due Date/TAT: STANDARD					

Section D Required Client Information		Section E Requested Analysis Filtered (Y/N)		Section F Requested Analysis Filtered (Y/N)	
Item #	Matrix Codes MATRIX / CODE Drinking Water Waste Water Product Soil/Solid Oil Wipe Air Tissue Other	Matrix Code (see valid codes to left)	Sample Type (G=GRAB C=COMP)	Collected COMPOSITE START COMPOSITE END/GRAB	Requested Analysis Filtered (Y/N)
1	97 RM 215 Class sink	97	GRAB	9/18/16 12:26	
2	98 RM 215 Rubbler	98	GRAB	9/18/16 12:27	
3	99 water fountain	99	GRAB	9/18/16 12:32	
4	100 water fountain Tall	100	GRAB	9/18/16 12:33	
5	101 Girls Bath sink ent	101	GRAB	9/18/16 12:34	
6	102 Girls Bath sink	102	GRAB	9/18/16 12:35	
7	103 Boys Bath sink	103	GRAB	9/18/16 12:36	
8	104 Boys Bath sink ent	104	GRAB	9/18/16 12:45	
9	105 RM 225 class sink w	105	GRAB	9/18/16 12:46	
10	106 RM 225 class s. south	106	GRAB	9/18/16 12:47	
11	107 Girls Bath sink	107	GRAB	9/18/16 12:48	
12	108 Girls Bath sink ent	108	GRAB	9/18/16 12:49	
Additional Comments: NO FLOW Relinquished By / Affiliation: PSI Date: 9/18/16 Time: 11:45 Accepted By / Affiliation: Carli Nollan Date: 9/18/16 Time: 11:45 Signature of Sampler: Carli Nollan Date: 9/18/16 Time: 11:45					

Section G Required Client Information		Section H Requested Analysis Filtered (Y/N)		Section I Requested Analysis Filtered (Y/N)	
Item #	Matrix Codes MATRIX / CODE Drinking Water Waste Water Product Soil/Solid Oil Wipe Air Tissue Other	Matrix Code (see valid codes to left)	Sample Type (G=GRAB C=COMP)	Collected COMPOSITE START COMPOSITE END/GRAB	Requested Analysis Filtered (Y/N)
1	97 RM 215 Class sink	97	GRAB	9/18/16 12:26	
2	98 RM 215 Rubbler	98	GRAB	9/18/16 12:27	
3	99 water fountain	99	GRAB	9/18/16 12:32	
4	100 water fountain Tall	100	GRAB	9/18/16 12:33	
5	101 Girls Bath sink ent	101	GRAB	9/18/16 12:34	
6	102 Girls Bath sink	102	GRAB	9/18/16 12:35	
7	103 Boys Bath sink	103	GRAB	9/18/16 12:36	
8	104 Boys Bath sink ent	104	GRAB	9/18/16 12:45	
9	105 RM 225 class sink w	105	GRAB	9/18/16 12:46	
10	106 RM 225 class s. south	106	GRAB	9/18/16 12:47	
11	107 Girls Bath sink	107	GRAB	9/18/16 12:48	
12	108 Girls Bath sink ent	108	GRAB	9/18/16 12:49	
Additional Comments: NO FLOW Relinquished By / Affiliation: PSI Date: 9/18/16 Time: 11:45 Accepted By / Affiliation: Carli Nollan Date: 9/18/16 Time: 11:45 Signature of Sampler: Carli Nollan Date: 9/18/16 Time: 11:45					



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: PSI	Report To: BILL KOTHS	Attention:		Company Name:	
Address: 104 Erie Blvd	Copy To:	Company Name:		Address:	
Schenectady NY 12305	Purchase Order No.:	Pace Quote Reference:		Pace Project Manager:	
104 Erie Blvd	Project Name: Gordon Creek E.S.	Pace Profile #:		Site Location STATE: NV	
Phone: 377-9891	Requested Due Date: 10/1/2007				
Fax:					
REGULATORY AGENCY		REGULATORY AGENCY		REGULATORY AGENCY	
NPDES ☐ GROUND WATER ☐ DRINKING WATER		UST ☐ RCRA ☐ OTHER ☐			
Page: of		2082400			

ITEM #	Matrix Codes MATRIX / CODE Drinking Water Waste Water Product Soil/Solid Oil Wipe Air Tissue Other	SAMPLE ID (A-Z, 0-9 / -)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives H ₂ SO ₄ HNO ₃ HCl NaOH Na ₂ S ₂ O ₃ Methanol Other	Analysis Test ☒	Requested Analysis Filtered (Y/N)	Temp in °C	Received on	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)	
				COMPOSITE START	COMPOSITE END/GRAB										
1		109 Girls Bath sink	DO	DATE	TIME	DATE	TIME								
2		110 Girls Bath sink ent		9/18/2007	1301										
3		111 RM 201 bubbler			1302										
4		112 RM 201 Class sink			1303										
5		113 RM 203 bubbler			1306										
6		114 RM 203 Class sink			1307										
7		115 RM 207 bubbler			1309										
8		116 RM 207 Class sink			1310										
9		117 RM 209 bubbler			1311										
10		118 RM 209 Class sink			1312										
11		119 RM 210 bubbler			1313										
12		120 RM 210 Class sink			1314										
ADDITIONAL COMMENTS															
PSI 9/19/07 1145 CEN Northman/PSI 9/18/16 1145															
CEN Northman/PSI 9/19/07 1145 800 1200															

ORIGINAL		SAMPLE NAME AND SIGNATURE		DATE Signed (MM/DD/YY): 9/18/16	
		PRINT Name of SAMPLER: Danish A. Fortke			
		SIGNATURE of SAMPLER: [Signature]			

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

Section A Requested Client Information: Company: <u>PSL</u> Address: <u>104 E. 1st St.</u> <u>Schenectady, NY 12305</u> Email: <u>WILLIAM.KOTAS@PSLUSA.COM</u> Phone: <u>377-9891</u> Fax: _____ Requested Due Date/TAT: <u>STANDARD</u>		Section B Required Project Information: Report To: <u>BILL KOTAS</u> Copy To: _____ Address: _____ Purchase Order No.: _____ Project Name: <u>Gordon Creek E.S.</u> Project Number: _____		Section C Invoice Information: Attention: _____ Company Name: _____ Address: _____ Pace Quote Reference: _____ Pace Project Manager: _____ Pace Profile #: _____	
Section D Regulatory Agency Information: NPDES ☐ GROUND WATER ☐ DRINKING WATER ☐ UST ☐ RCRA ☐ OTHER ☐		REGULATORY AGENCY: _____		Page: _____ of _____ 2082399	
Site Location: <u>NY</u> STATE: _____					

[illegible]

Temp in °C	Received on ice (Y/N)	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: PSI	Report To: BILL KOTAS	Attention:	Company Name:	Page: 2082398	of
Address: 104 EIR BLVD.	Copy To:	Company Name:	Address:	REGULATORY AGENCY	
City: Schenectady NY 12305	Purchase Order No.:	Pace Quote Reference:	Address:	☐ NPDES ☐ GROUND WATER ☐ DRINKING WATER	
City: WILLIAM, KOTAS & ASSOCIATES	Project Name: Gordon Creek ES.	Pace Project Manager:	Address:	☐ UST ☐ RCRA ☐ OTHER	
Phone: 377-9891	Project Number:	Pace Profile #:	Site Location	STATE: NY	
Requested Due Date/TAT: STANDARD					

ITEM #	Section D Required Client Information	Matrix Codes MATRIX CODE Drinking Water Waste Water Product Soil/Solid Oil Wipe Air Tissue Other	SAMPLE TYPE (G=GRAB C=COMP) (see valid codes to left)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives Unpreserved H ₂ SO ₄ HCl NaOH Na ₂ O ₃ Methanol Other	Analysis Test Y/N	Requested Analysis Filtered (Y/N)	Pace Project No./ Lab I.D.
				COMPOSITE START	COMPOSITE END/GRAB						
1	133 Water fountain	DW	GR	DATE	TIME	DATE	TIME				1609460
2	134 Caterer storage table	WW	GR	9/18	1354	9/18	1427				
3	135 Eye wash/sink-captop	SL	GR	9/18	1432	9/18	1432				
4		WP									
5		OL									
6		AR									
7		TS									
8		OT									
9											
10											
11											
12											

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	Bill Kotas PSI	9/19/16	1145	Ken Nelson/Mace	9/19/16	1145	Sealed Coolery N N
	Ken Nelson/Mace	9/19/16	1600	800	9/19/16	1200	Received on Ice (Y/N) " " " "
							Custody (Y/N) " " " "
							Sealed Coolery (Y/N) " " " "
							Samples Intact (Y/N) " " " "

ORIGINAL		SAMPLER NAME AND SIGNATURE		Temp in °C	Received on	Custody	Sealed Coolery	Samples Intact
		PRINT Name of SAMPLER: Daniel A. Becker						
		SIGNATURE of SAMPLER: [Signature]		DATE Signed (MM/DD/YYYY): 9/18/16				

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

Appendix G

Laboratory Analysis Results for:

Wood Road Elementary

300 Wood Rd, Ballston Spa, NY 12020

October 17, 2016

Bill Kotas
PSI
104 Erie Blvd
Schenectady, NY 12305

RE: Project: BS CSD - Wood Road E.S.
Pace Project No.: 10364697

Dear Bill Kotas:

Enclosed are the analytical results for sample(s) received by the laboratory on October 04, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

Samples, in the electronic data deliverable (EDD) that accompanied this report, were flagged yellow if they exceeded the NYSDOH 15 ppb action level.

The space designated for the sampler on the chain of custody (COC) indicates if these samples were collected by Pace Analytical or were collected by the school district and just relinquished to Pace Analytical.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Amanda Albrecht
amanda.albrecht@pacelabs.com
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Minnesota Certification IDs

1700 Elm Street SE Suite 200, Minneapolis, MN 55414

Alaska Certification UST-107

525 N 8th Street, Salina, KS 67401

A2LA Certification #: 2926.01

Alaska Certification #: UST-078

Alaska Certification #MN00064

Alabama Certification #40770

Arizona Certification #: AZ-0014

Arkansas Certification #: 88-0680

California Certification #: 01155CA

Colorado Certification #Pace

Connecticut Certification #: PH-0256

EPA Region 8 Certification #: 8TMS-L

Florida/NELAP Certification #: E87605

Guam Certification #:14-008r

Georgia Certification #: 959

Georgia EPD #: Pace

Idaho Certification #: MN00064

Hawaii Certification #MN00064

Illinois Certification #: 200011

Indiana Certification#C-MN-01

Iowa Certification #: 368

Kansas Certification #: E-10167

Kentucky Dept of Envi. Protection - DW #90062

Kentucky Dept of Envi. Protection - WW #:90062

Louisiana DEQ Certification #: 3086

Louisiana DHH #: LA140001

Maine Certification #: 2013011

Maryland Certification #: 322

Michigan DEPH Certification #: 9909

Minnesota Certification #: 027-053-137

Mississippi Certification #: Pace

Montana Certification #: MT0092

Nevada Certification #: MN_00064

Nebraska Certification #: Pace

New Jersey Certification #: MN-002

New York Certification #: 11647

North Carolina Certification #: 530

North Carolina State Public Health #: 27700

North Dakota Certification #: R-036

Ohio EPA #: 4150

Ohio VAP Certification #: CL101

Oklahoma Certification #: 9507

Oregon Certification #: MN200001

Oregon Certification #: MN300001

Pennsylvania Certification #: 68-00563

Puerto Rico Certification

Saipan (CNMI) #:MP0003

South Carolina #:74003001

Texas Certification #: T104704192

Tennessee Certification #: 02818

Utah Certification #: MN000642013-4

Virginia DGS Certification #: 251

Virginia/VELAP Certification #: Pace

Washington Certification #: C486

West Virginia Certification #: 382

West Virginia DHHR #:9952C

Wisconsin Certification #: 999407970

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10364697001	WR001	Water	09/24/16 07:29	10/04/16 10:00
10364697002	WR002	Water	09/24/16 07:30	10/04/16 10:00
10364697003	WR003	Water	09/24/16 07:31	10/04/16 10:00
10364697004	WR004	Water	09/24/16 07:32	10/04/16 10:00
10364697005	WR005	Water	09/24/16 07:34	10/04/16 10:00
10364697006	WR006	Water	09/24/16 07:38	10/04/16 10:00
10364697007	WR007	Water	09/24/16 07:38	10/04/16 10:00
10364697008	WR008	Water	09/24/16 07:39	10/04/16 10:00
10364697009	WR009	Water	09/24/16 07:40	10/04/16 10:00
10364697010	WR010	Water	09/24/16 07:41	10/04/16 10:00
10364697011	WR011	Water	09/24/16 07:42	10/04/16 10:00
10364697012	WR012	Water	09/24/16 07:44	10/04/16 10:00
10364697013	WR013	Water	09/24/16 07:46	10/04/16 10:00
10364697014	WR014	Water	09/24/16 07:47	10/04/16 10:00
10364697015	WR015	Water	09/24/16 13:54	10/04/16 10:00
10364697016	WR016 - Dripping Faucet	Water	09/24/16 07:50	10/04/16 10:00
10364697017	WR017	Water	09/24/16 07:51	10/04/16 10:00
10364697018	WR018	Water	09/24/16 08:05	10/04/16 10:00
10364697019	WR019	Water	09/24/16 08:07	10/04/16 10:00
10364697020	WR020	Water	09/24/16 08:15	10/04/16 10:00
10364697021	WR021	Water	09/24/16 08:15	10/04/16 10:00
10364697022	WR022	Water	09/24/16 08:17	10/04/16 10:00
10364697023	WR023	Water	09/24/16 08:17	10/04/16 10:00
10364697024	WR024	Water	09/24/16 08:21	10/04/16 10:00
10364697025	WR025	Water	09/24/16 08:36	10/04/16 10:00
10364697026	WR026	Water	09/24/16 08:38	10/04/16 10:00
10364697027	WR027	Water	09/24/16 08:39	10/04/16 10:00
10364697028	WR028	Water	09/24/16 08:40	10/04/16 10:00
10364697029	WR029	Water	09/24/16 08:41	10/04/16 10:00
10364697030	WR030	Water	09/24/16 08:42	10/04/16 10:00
10364697031	WR031	Water	09/24/16 08:43	10/04/16 10:00
10364697032	WR032	Water	09/24/16 08:44	10/04/16 10:00
10364697033	WR033	Water	09/24/16 08:45	10/04/16 10:00
10364697034	WR034	Water	09/24/16 08:46	10/04/16 10:00
10364697035	WR035	Water	09/24/16 08:47	10/04/16 10:00
10364697036	WR036	Water	09/24/16 08:48	10/04/16 10:00
10364697037	WR037	Water	09/24/16 08:49	10/04/16 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10364697038	WR038	Water	09/24/16 08:52	10/04/16 10:00
10364697039	WR039	Water	09/24/16 08:53	10/04/16 10:00
10364697040	WR040	Water	09/24/16 08:57	10/04/16 10:00
10364697041	WR041	Water	09/24/16 08:58	10/04/16 10:00
10364697042	WR042	Water	09/24/16 08:59	10/04/16 10:00
10364697043	WR043	Water	09/24/16 09:00	10/04/16 10:00
10364697044	WR044	Water	09/24/16 09:01	10/04/16 10:00
10364697045	WR045	Water	09/24/16 09:02	10/04/16 10:00
10364697046	WR046	Water	09/24/16 09:03	10/04/16 10:00
10364697047	WR047	Water	09/24/16 09:12	10/04/16 10:00
10364697048	WR048	Water	09/24/16 09:13	10/04/16 10:00
10364697049	WR049	Water	09/24/16 09:29	10/04/16 10:00
10364697050	WR050	Water	09/24/16 09:30	10/04/16 10:00
10364697051	WR051	Water	09/24/16 09:32	10/04/16 10:00
10364697052	WR052	Water	09/24/16 09:34	10/04/16 10:00
10364697053	WR053 *	Water	09/24/16 11:04	10/04/16 10:00
10364697054	WR054	Water	09/24/16 09:33	10/04/16 10:00
10364697055	WR055	Water	09/24/16 09:41	10/04/16 10:00
10364697056	WR056	Water	09/24/16 09:42	10/04/16 10:00
10364697057	WR057	Water	09/24/16 09:43	10/04/16 10:00
10364697058	WR058	Water	09/24/16 09:44	10/04/16 10:00
10364697059	WR059	Water	09/24/16 09:46	10/04/16 10:00
10364697060	WR060	Water	09/24/16 09:47	10/04/16 10:00
10364697061	WR061	Water	09/24/16 09:49	10/04/16 10:00
10364697062	WR062	Water	09/24/16 09:50	10/04/16 10:00
10364697063	WR063	Water	09/24/16 09:51	10/04/16 10:00
10364697064	WR064	Water	09/24/16 09:54	10/04/16 10:00
10364697065	WR065	Water	09/24/16 10:15	10/04/16 10:00
10364697066	WR066	Water	09/24/16 10:16	10/04/16 10:00
10364697067	WR067	Water	09/24/16 10:25	10/04/16 10:00
10364697068	WR068	Water	09/24/16 10:26	10/04/16 10:00
10364697069	WR069	Water	09/24/16 10:41	10/04/16 10:00
10364697070	WR070	Water	09/24/16 10:42	10/04/16 10:00
10364697071	WR071	Water	09/24/16 10:43	10/04/16 10:00
10364697072	WR072	Water	09/24/16 10:44	10/04/16 10:00
10364697073	WR073	Water	09/24/16 10:57	10/04/16 10:00
10364697074	WR074	Water	09/24/16 10:58	10/04/16 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10364697075	WR075	Water	09/24/16 11:00	10/04/16 10:00
10364697076	WR076	Water	09/24/16 11:01	10/04/16 10:00
10364697077	WR077	Water	09/24/16 11:02	10/04/16 10:00
10364697078	WR078	Water	09/24/16 11:09	10/04/16 10:00
10364697079	WR079	Water	09/24/16 11:10	10/04/16 10:00
10364697080	WR080	Water	09/24/16 11:11	10/04/16 10:00
10364697081	WR081	Water	09/24/16 11:12	10/04/16 10:00
10364697082	WR082	Water	09/24/16 11:13	10/04/16 10:00
10364697083	WR083	Water	09/24/16 11:14	10/04/16 10:00
10364697084	WR084	Water	09/24/16 11:18	10/04/16 10:00
10364697085	WR085	Water	09/24/16 11:23	10/04/16 10:00
10364697086	WR086	Water	09/24/16 11:24	10/04/16 10:00
10364697087	WR087	Water	09/24/16 11:25	10/04/16 10:00
10364697088	WR088	Water	09/24/16 11:26	10/04/16 10:00
10364697089	WR089	Water	09/24/16 11:22	10/04/16 10:00
10364697090	WR090	Water	09/24/16 11:32	10/04/16 10:00
10364697091	WR091	Water	09/24/16 11:33	10/04/16 10:00
10364697092	WR092	Water	09/24/16 11:34	10/04/16 10:00
10364697093	WR093	Water	09/24/16 11:36	10/04/16 10:00
10364697094	WR094	Water	09/24/16 11:37	10/04/16 10:00
10364697095	WR095	Water	09/24/16 11:38	10/04/16 10:00
10364697096	WR096	Water	09/24/16 11:47	10/04/16 10:00
10364697097	WR097	Water	09/24/16 12:02	10/04/16 10:00
10364697098	WR098	Water	09/24/16 12:03	10/04/16 10:00
10364697099	WR099	Water	09/24/16 12:07	10/04/16 10:00
10364697100	WR100	Water	09/24/16 12:08	10/04/16 10:00
10364697101	WR101	Water	09/24/16 12:09	10/04/16 10:00
10364697102	WR102	Water	09/24/16 12:10	10/04/16 10:00
10364697103	WR103	Water	09/24/16 12:11	10/04/16 10:00
10364697104	WR104	Water	09/24/16 12:12	10/04/16 10:00
10364697105	WR105	Water	09/24/16 12:13	10/04/16 10:00
10364697106	WR106	Water	09/24/16 12:14	10/04/16 10:00
10364697107	WR107	Water	09/24/16 12:15	10/04/16 10:00
10364697108	WR108	Water	09/24/16 12:16	10/04/16 10:00
10364697109	WR109	Water	09/24/16 12:27	10/04/16 10:00
10364697110	WR110	Water	09/24/16 12:28	10/04/16 10:00
10364697111	WR111	Water	09/24/16 12:29	10/04/16 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10364697112	WR112	Water	09/24/16 12:30	10/04/16 10:00
10364697113	WR113	Water	09/24/16 12:36	10/04/16 10:00
10364697114	WR114	Water	09/24/16 12:37	10/04/16 10:00
10364697115	WR115	Water	09/24/16 12:38	10/04/16 10:00
10364697116	WR116	Water	09/24/16 12:40	10/04/16 10:00
10364697117	WR117	Water	09/24/16 12:41	10/04/16 10:00
10364697118	WR118	Water	09/24/16 12:44	10/04/16 10:00
10364697119	WR119	Water	09/24/16 12:45	10/04/16 10:00
10364697121	WR121	Water	09/24/16 13:02	10/04/16 10:00
10364697122	WR122	Water	09/24/16 13:03	10/04/16 10:00
10364697123	WR123	Water	09/24/16 13:04	10/04/16 10:00
10364697124	WR124	Water	09/24/16 13:05	10/04/16 10:00
10364697125	WR125	Water	09/24/16 13:07	10/04/16 10:00
10364697126	WR126	Water	09/24/16 13:08	10/04/16 10:00
10364697127	WR127	Water	09/24/16 13:10	10/04/16 10:00
10364697128	WR128	Water	09/24/16 13:14	10/04/16 10:00
10364697129	WR129	Water	09/24/16 13:14	10/04/16 10:00
10364697130	WR130	Water	09/24/16 13:18	10/04/16 10:00
10364697131	WR131	Water	09/24/16 13:19	10/04/16 10:00
10364697132	WR132	Water	09/24/16 13:20	10/04/16 10:00
10364697133	WR133	Water	09/24/16 13:22	10/04/16 10:00
10364697134	WR134	Water	09/24/16 13:23	10/04/16 10:00
10364697135	WR135	Water	09/24/16 13:24	10/04/16 10:00
10364697136	WR136	Water	09/24/16 13:26	10/04/16 10:00
10364697138	WR138	Water	09/24/16 13:32	10/04/16 10:00
10364697139	WR139	Water	09/24/16 13:38	10/04/16 10:00
10364697140	WR140	Water	09/24/16 13:41	10/04/16 10:00
10364697141	WR141	Water	09/24/16 13:42	10/04/16 10:00
10364697142	WR142	Water	09/24/16 13:44	10/04/16 10:00
10364697143	WR143	Water	09/24/16 13:13	10/04/16 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10364697001	WR001	EPA 200.8	RJS	1	PASI-M
10364697002	WR002	EPA 200.8	RJS	1	PASI-M
10364697003	WR003	EPA 200.8	RJS	1	PASI-M
10364697004	WR004	EPA 200.8	RJS	1	PASI-M
10364697005	WR005	EPA 200.8	RJS	1	PASI-M
10364697006	WR006	EPA 200.8	RJS	1	PASI-M
10364697007	WR007	EPA 200.8	TT3	1	PASI-M
10364697008	WR008	EPA 200.8	RJS	1	PASI-M
10364697009	WR009	EPA 200.8	RJS	1	PASI-M
10364697010	WR010	EPA 200.8	RJS	1	PASI-M
10364697011	WR011	EPA 200.8	RJS	1	PASI-M
10364697012	WR012	EPA 200.8	RJS	1	PASI-M
10364697013	WR013	EPA 200.8	TT3	1	PASI-M
10364697014	WR014	EPA 200.8	RJS	1	PASI-M
10364697015	WR015	EPA 200.8	RJS	1	PASI-M
10364697016	WR016 - Dripping Faucet	EPA 200.8	RJS	1	PASI-M
10364697017	WR017	EPA 200.8	RJS	1	PASI-M
10364697018	WR018	EPA 200.8	RJS	1	PASI-M
10364697019	WR019	EPA 200.8	RJS	1	PASI-M
10364697020	WR020	EPA 200.8	RJS	1	PASI-M
10364697021	WR021	EPA 200.8	RJS	1	PASI-M
10364697022	WR022	EPA 200.8	RJS	1	PASI-M
10364697023	WR023	EPA 200.8	RJS	1	PASI-M
10364697024	WR024	EPA 200.8	RJS	1	PASI-M
10364697025	WR025	EPA 200.8	RJS	1	PASI-M
10364697026	WR026	EPA 200.8	RJS	1	PASI-M
10364697027	WR027	EPA 200.8	RJS	1	PASI-M
10364697028	WR028	EPA 200.8	RJS	1	PASI-M
10364697029	WR029	EPA 200.8	RJS	1	PASI-M
10364697030	WR030	EPA 200.8	RJS	1	PASI-M
10364697031	WR031	EPA 200.8	RJS	1	PASI-M
10364697032	WR032	EPA 200.8	RJS	1	PASI-M
10364697033	WR033	EPA 200.8	RJS	1	PASI-M
10364697034	WR034	EPA 200.8	RJS	1	PASI-M
10364697035	WR035	EPA 200.8	RJS	1	PASI-M
10364697036	WR036	EPA 200.8	TT3	1	PASI-M
10364697037	WR037	EPA 200.8	RJS	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10364697038	WR038	EPA 200.8	RJS	1	PASI-M
10364697039	WR039	EPA 200.8	RJS	1	PASI-M
10364697040	WR040	EPA 200.8	RJS	1	PASI-M
10364697041	WR041	EPA 200.8	RJS	1	PASI-M
10364697042	WR042	EPA 200.8	RJS	1	PASI-M
10364697043	WR043	EPA 200.8	RJS	1	PASI-M
10364697044	WR044	EPA 200.8	RJS	1	PASI-M
10364697045	WR045	EPA 200.8	RJS	1	PASI-M
10364697046	WR046	EPA 200.8	RJS	1	PASI-M
10364697047	WR047	EPA 200.8	RJS	1	PASI-M
10364697048	WR048	EPA 200.8	RJS	1	PASI-M
10364697049	WR049	EPA 200.8	RJS	1	PASI-M
10364697050	WR050	EPA 200.8	RJS	1	PASI-M
10364697051	WR051	EPA 200.8	RJS	1	PASI-M
10364697052	WR052	EPA 200.8	RJS	1	PASI-M
10364697053	WR053 *	EPA 200.8	RJS	1	PASI-M
10364697054	WR054	EPA 200.8	RJS	1	PASI-M
10364697055	WR055	EPA 200.8	RJS	1	PASI-M
10364697056	WR056	EPA 200.8	RJS	1	PASI-M
10364697057	WR057	EPA 200.8	RJS	1	PASI-M
10364697058	WR058	EPA 200.8	RJS	1	PASI-M
10364697059	WR059	EPA 200.8	RJS	1	PASI-M
10364697060	WR060	EPA 200.8	RJS	1	PASI-M
10364697061	WR061	EPA 200.8	RJS	1	PASI-M
10364697062	WR062	EPA 200.8	RJS	1	PASI-M
10364697063	WR063	EPA 200.8	RJS	1	PASI-M
10364697064	WR064	EPA 200.8	RJS	1	PASI-M
10364697065	WR065	EPA 200.8	RJS	1	PASI-M
10364697066	WR066	EPA 200.8	RJS	1	PASI-M
10364697067	WR067	EPA 200.8	RJS	1	PASI-M
10364697068	WR068	EPA 200.8	RJS	1	PASI-M
10364697069	WR069	EPA 200.8	RJS	1	PASI-M
10364697070	WR070	EPA 200.8	RJS	1	PASI-M
10364697071	WR071	EPA 200.8	RJS	1	PASI-M
10364697072	WR072	EPA 200.8	RJS	1	PASI-M
10364697073	WR073	EPA 200.8	RJS	1	PASI-M
10364697074	WR074	EPA 200.8	RJS	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10364697075	WR075	EPA 200.8	RJS	1	PASI-M
10364697076	WR076	EPA 200.8	RJS	1	PASI-M
10364697077	WR077	EPA 200.8	RJS	1	PASI-M
10364697078	WR078	EPA 200.8	RJS	1	PASI-M
10364697079	WR079	EPA 200.8	RJS	1	PASI-M
10364697080	WR080	EPA 200.8	RJS	1	PASI-M
10364697081	WR081	EPA 200.8	RJS	1	PASI-M
10364697082	WR082	EPA 200.8	RJS	1	PASI-M
10364697083	WR083	EPA 200.8	RJS	1	PASI-M
10364697084	WR084	EPA 200.8	RJS	1	PASI-M
10364697085	WR085	EPA 200.8	RJS	1	PASI-M
10364697086	WR086	EPA 200.8	RJS	1	PASI-M
10364697087	WR087	EPA 200.8	RJS	1	PASI-M
10364697088	WR088	EPA 200.8	RJS	1	PASI-M
10364697089	WR089	EPA 200.8	RJS	1	PASI-M
10364697090	WR090	EPA 200.8	RJS	1	PASI-M
10364697091	WR091	EPA 200.8	RJS	1	PASI-M
10364697092	WR092	EPA 200.8	RJS	1	PASI-M
10364697093	WR093	EPA 200.8	RJS	1	PASI-M
10364697094	WR094	EPA 200.8	RJS	1	PASI-M
10364697095	WR095	EPA 200.8	RJS	1	PASI-M
10364697096	WR096	EPA 200.8	RJS	1	PASI-M
10364697097	WR097	EPA 200.8	RJS	1	PASI-M
10364697098	WR098	EPA 200.8	RJS	1	PASI-M
10364697099	WR099	EPA 200.8	RJS	1	PASI-M
10364697100	WR100	EPA 200.8	RJS	1	PASI-M
10364697101	WR101	EPA 200.8	RJS	1	PASI-M
10364697102	WR102	EPA 200.8	RJS	1	PASI-M
10364697103	WR103	EPA 200.8	RJS	1	PASI-M
10364697104	WR104	EPA 200.8	RJS	1	PASI-M
10364697105	WR105	EPA 200.8	RJS	1	PASI-M
10364697106	WR106	EPA 200.8	RJS	1	PASI-M
10364697107	WR107	EPA 200.8	RJS	1	PASI-M
10364697108	WR108	EPA 200.8	RJS	1	PASI-M
10364697109	WR109	EPA 200.8	RJS	1	PASI-M
10364697110	WR110	EPA 200.8	RJS	1	PASI-M
10364697111	WR111	EPA 200.8	RJS	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10364697112	WR112	EPA 200.8	RJS	1	PASI-M
10364697113	WR113	EPA 200.8	RJS	1	PASI-M
10364697114	WR114	EPA 200.8	RJS	1	PASI-M
10364697115	WR115	EPA 200.8	RJS	1	PASI-M
10364697116	WR116	EPA 200.8	RJS	1	PASI-M
10364697117	WR117	EPA 200.8	RJS	1	PASI-M
10364697118	WR118	EPA 200.8	RJS	1	PASI-M
10364697119	WR119	EPA 200.8	RJS	1	PASI-M
10364697121	WR121	EPA 200.8	TT3	1	PASI-M
10364697122	WR122	EPA 200.8	TT3	1	PASI-M
10364697123	WR123	EPA 200.8	TT3	1	PASI-M
10364697124	WR124	EPA 200.8	TT3	1	PASI-M
10364697125	WR125	EPA 200.8	TT3	1	PASI-M
10364697126	WR126	EPA 200.8	TT3	1	PASI-M
10364697127	WR127	EPA 200.8	TT3	1	PASI-M
10364697128	WR128	EPA 200.8	TT3	1	PASI-M
10364697129	WR129	EPA 200.8	TT3	1	PASI-M
10364697130	WR130	EPA 200.8	TT3	1	PASI-M
10364697131	WR131	EPA 200.8	TT3	1	PASI-M
10364697132	WR132	EPA 200.8	TT3	1	PASI-M
10364697133	WR133	EPA 200.8	TT3	1	PASI-M
10364697134	WR134	EPA 200.8	TT3	1	PASI-M
10364697135	WR135	EPA 200.8	TT3	1	PASI-M
10364697136	WR136	EPA 200.8	TT3	1	PASI-M
10364697138	WR138	EPA 200.8	TT3	1	PASI-M
10364697139	WR139	EPA 200.8	TT3	1	PASI-M
10364697140	WR140	EPA 200.8	TT3	1	PASI-M
10364697141	WR141	EPA 200.8	TT3	1	PASI-M
10364697142	WR142	EPA 200.8	TT3	1	PASI-M
10364697143	WR143	EPA 200.8	TT3	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR001		Lab ID: 10364697001		Collected: 09/24/16 07:29		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.69	ug/L	0.10	1		10/05/16 20:45	7439-92-1		
Sample: WR002		Lab ID: 10364697002		Collected: 09/24/16 07:30		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.7	ug/L	0.10	1		10/05/16 20:57	7439-92-1		
Sample: WR003		Lab ID: 10364697003		Collected: 09/24/16 07:31		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	8.3	ug/L	0.10	1		10/05/16 21:00	7439-92-1		
Sample: WR004		Lab ID: 10364697004		Collected: 09/24/16 07:32		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	6.5	ug/L	0.10	1		10/05/16 21:03	7439-92-1		
Sample: WR005		Lab ID: 10364697005		Collected: 09/24/16 07:34		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	13.0	ug/L	0.10	1		10/05/16 21:06	7439-92-1		
Sample: WR006		Lab ID: 10364697006		Collected: 09/24/16 07:38		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.6	ug/L	0.10	1		10/05/16 21:15	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR007		Lab ID: 10364697007		Collected: 09/24/16 07:38		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS		Analytical Method: EPA 200.8			Preparation Method: EPA 200.8				
Lead	4.2	ug/L	0.10	1	10/12/16 09:30	10/12/16 16:56	7439-92-1		
Sample: WR008		Lab ID: 10364697008		Collected: 09/24/16 07:39		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	10.4	ug/L	0.10	1		10/05/16 21:18	7439-92-1		
Sample: WR009		Lab ID: 10364697009		Collected: 09/24/16 07:40		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	18.7	ug/L	0.10	1		10/05/16 21:21	7439-92-1		
Sample: WR010		Lab ID: 10364697010		Collected: 09/24/16 07:41		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	22.6	ug/L	0.10	1		10/05/16 21:24	7439-92-1		
Sample: WR011		Lab ID: 10364697011		Collected: 09/24/16 07:42		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	30.0	ug/L	0.10	1		10/05/16 21:27	7439-92-1		
Sample: WR012		Lab ID: 10364697012		Collected: 09/24/16 07:44		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.32	ug/L	0.10	1		10/05/16 21:30	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR013		Lab ID: 10364697013	Collected: 09/24/16 07:46	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8						
Lead	3.2	ug/L	0.10	1	10/12/16 09:30	10/12/16 17:06	7439-92-1	
Sample: WR014		Lab ID: 10364697014	Collected: 09/24/16 07:47	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.1	ug/L	0.10	1		10/05/16 21:33	7439-92-1	
Sample: WR015		Lab ID: 10364697015	Collected: 09/24/16 13:54	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.43	ug/L	0.10	1		10/05/16 21:36	7439-92-1	
Sample: WR016 - Dripping Faucet		Lab ID: 10364697016	Collected: 09/24/16 07:50	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.0	ug/L	0.10	1		10/05/16 21:39	7439-92-1	
Sample: WR017		Lab ID: 10364697017	Collected: 09/24/16 07:51	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.60	ug/L	0.10	1		10/05/16 21:42	7439-92-1	
Sample: WR018		Lab ID: 10364697018	Collected: 09/24/16 08:05	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	ND	ug/L	0.10	1		10/05/16 21:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR019		Lab ID: 10364697019	Collected: 09/24/16 08:07	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.17	ug/L	0.10	1		10/05/16 21:54	7439-92-1	
Sample: WR020		Lab ID: 10364697020	Collected: 09/24/16 08:15	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.46	ug/L	0.10	1		10/05/16 21:57	7439-92-1	
Sample: WR021		Lab ID: 10364697021	Collected: 09/24/16 08:15	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.30	ug/L	0.10	1		10/05/16 22:09	7439-92-1	
Sample: WR022		Lab ID: 10364697022	Collected: 09/24/16 08:17	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.26	ug/L	0.10	1		10/05/16 22:27	7439-92-1	
Sample: WR023		Lab ID: 10364697023	Collected: 09/24/16 08:17	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.16	ug/L	0.10	1		10/05/16 22:30	7439-92-1	
Sample: WR024		Lab ID: 10364697024	Collected: 09/24/16 08:21	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.25	ug/L	0.10	1		10/05/16 22:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR025		Lab ID: 10364697025		Collected: 09/24/16 08:36		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.12	ug/L	0.10	1		10/05/16 22:36	7439-92-1		
Sample: WR026		Lab ID: 10364697026		Collected: 09/24/16 08:38		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.24	ug/L	0.10	1		10/05/16 22:39	7439-92-1		
Sample: WR027		Lab ID: 10364697027		Collected: 09/24/16 08:39		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.10	ug/L	0.10	1		10/05/16 22:42	7439-92-1		
Sample: WR028		Lab ID: 10364697028		Collected: 09/24/16 08:40		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.19	ug/L	0.10	1		10/05/16 22:45	7439-92-1		
Sample: WR029		Lab ID: 10364697029		Collected: 09/24/16 08:41		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	ND	ug/L	0.10	1		10/05/16 22:48	7439-92-1		
Sample: WR030		Lab ID: 10364697030		Collected: 09/24/16 08:42		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.20	ug/L	0.10	1		10/05/16 22:51	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR031		Lab ID: 10364697031	Collected: 09/24/16 08:43	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.16	ug/L	0.10	1		10/05/16 22:54	7439-92-1	
Sample: WR032		Lab ID: 10364697032	Collected: 09/24/16 08:44	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.24	ug/L	0.10	1		10/05/16 23:03	7439-92-1	
Sample: WR033		Lab ID: 10364697033	Collected: 09/24/16 08:45	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.17	ug/L	0.10	1		10/05/16 23:06	7439-92-1	
Sample: WR034		Lab ID: 10364697034	Collected: 09/24/16 08:46	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.25	ug/L	0.10	1		10/05/16 23:09	7439-92-1	
Sample: WR035		Lab ID: 10364697035	Collected: 09/24/16 08:47	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.25	ug/L	0.10	1		10/05/16 23:12	7439-92-1	
Sample: WR036		Lab ID: 10364697036	Collected: 09/24/16 08:48	Received: 10/04/16 10:00	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8						
Lead	0.17	ug/L	0.10	1	10/12/16 09:30	10/12/16 17:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR037		Lab ID: 10364697037		Collected: 09/24/16 08:49		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.23	ug/L	0.10	1		10/05/16 23:15	7439-92-1		
Sample: WR038		Lab ID: 10364697038		Collected: 09/24/16 08:52		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.25	ug/L	0.10	1		10/05/16 23:18	7439-92-1		
Sample: WR039		Lab ID: 10364697039		Collected: 09/24/16 08:53		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.30	ug/L	0.10	1		10/05/16 23:21	7439-92-1		
Sample: WR040		Lab ID: 10364697040		Collected: 09/24/16 08:57		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.11	ug/L	0.10	1		10/05/16 23:24	7439-92-1		
Sample: WR041		Lab ID: 10364697041		Collected: 09/24/16 08:58		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.94	ug/L	0.10	1		10/08/16 01:25	7439-92-1		
Sample: WR042		Lab ID: 10364697042		Collected: 09/24/16 08:59		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.78	ug/L	0.10	1		10/08/16 01:37	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR043		Lab ID: 10364697043		Collected: 09/24/16 09:00		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.70	ug/L	0.10	1		10/08/16 01:40	7439-92-1		
Sample: WR044		Lab ID: 10364697044		Collected: 09/24/16 09:01		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.63	ug/L	0.10	1		10/08/16 01:43	7439-92-1		
Sample: WR045		Lab ID: 10364697045		Collected: 09/24/16 09:02		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.52	ug/L	0.10	1		10/08/16 01:46	7439-92-1		
Sample: WR046		Lab ID: 10364697046		Collected: 09/24/16 09:03		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.54	ug/L	0.10	1		10/08/16 01:55	7439-92-1		
Sample: WR047		Lab ID: 10364697047		Collected: 09/24/16 09:12		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.60	ug/L	0.10	1		10/08/16 01:58	7439-92-1		
Sample: WR048		Lab ID: 10364697048		Collected: 09/24/16 09:13		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.37	ug/L	0.10	1		10/08/16 02:01	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR049		Lab ID: 10364697049		Collected: 09/24/16 09:29		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.28	ug/L	0.10	1		10/08/16 02:04	7439-92-1		
Sample: WR050		Lab ID: 10364697050		Collected: 09/24/16 09:30		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.10	ug/L	0.10	1		10/08/16 02:07	7439-92-1		
Sample: WR051		Lab ID: 10364697051		Collected: 09/24/16 09:32		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.44	ug/L	0.10	1		10/08/16 02:10	7439-92-1		
Sample: WR052		Lab ID: 10364697052		Collected: 09/24/16 09:34		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.68	ug/L	0.10	1		10/08/16 02:13	7439-92-1		
Sample: WR053 *		Lab ID: 10364697053		Collected: 09/24/16 11:04		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.20	ug/L	0.10	1		10/08/16 02:16	7439-92-1		
Sample: WR054		Lab ID: 10364697054		Collected: 09/24/16 09:33		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.12	ug/L	0.10	1		10/08/16 02:19	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR055		Lab ID: 10364697055		Collected: 09/24/16 09:41		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.30	ug/L	0.10	1		10/08/16 02:22	7439-92-1		
Sample: WR056		Lab ID: 10364697056		Collected: 09/24/16 09:42		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.13	ug/L	0.10	1		10/08/16 02:31	7439-92-1		
Sample: WR057		Lab ID: 10364697057		Collected: 09/24/16 09:43		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.47	ug/L	0.10	1		10/08/16 02:34	7439-92-1		
Sample: WR058		Lab ID: 10364697058		Collected: 09/24/16 09:44		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.27	ug/L	0.10	1		10/08/16 02:37	7439-92-1		
Sample: WR059		Lab ID: 10364697059		Collected: 09/24/16 09:46		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.15	ug/L	0.10	1		10/08/16 02:40	7439-92-1		
Sample: WR060		Lab ID: 10364697060		Collected: 09/24/16 09:47		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.51	ug/L	0.10	1		10/08/16 02:43	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR061		Lab ID: 10364697061		Collected: 09/24/16 09:49		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.18	ug/L	0.10	1		10/07/16 23:43	7439-92-1		
Sample: WR062		Lab ID: 10364697062		Collected: 09/24/16 09:50		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.20	ug/L	0.10	1		10/07/16 23:55	7439-92-1		
Sample: WR063		Lab ID: 10364697063		Collected: 09/24/16 09:51		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.42	ug/L	0.10	1		10/07/16 23:58	7439-92-1		
Sample: WR064		Lab ID: 10364697064		Collected: 09/24/16 09:54		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.27	ug/L	0.10	1		10/08/16 00:07	7439-92-1		
Sample: WR065		Lab ID: 10364697065		Collected: 09/24/16 10:15		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.9	ug/L	0.10	1		10/08/16 00:10	7439-92-1		
Sample: WR066		Lab ID: 10364697066		Collected: 09/24/16 10:16		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.47	ug/L	0.10	1		10/08/16 00:13	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR067		Lab ID: 10364697067	Collected: 09/24/16 10:25		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	3.8	ug/L	0.10	1		10/08/16 00:16	7439-92-1	
Sample: WR068		Lab ID: 10364697068	Collected: 09/24/16 10:26		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.92	ug/L	0.10	1		10/08/16 00:19	7439-92-1	
Sample: WR069		Lab ID: 10364697069	Collected: 09/24/16 10:41		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.78	ug/L	0.10	1		10/08/16 00:22	7439-92-1	
Sample: WR070		Lab ID: 10364697070	Collected: 09/24/16 10:42		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.12	ug/L	0.10	1		10/08/16 00:25	7439-92-1	
Sample: WR071		Lab ID: 10364697071	Collected: 09/24/16 10:43		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.10	ug/L	0.10	1		10/08/16 00:28	7439-92-1	
Sample: WR072		Lab ID: 10364697072	Collected: 09/24/16 10:44		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.5	ug/L	0.10	1		10/08/16 00:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR073		Lab ID: 10364697073		Collected: 09/24/16 10:57		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.45	ug/L	0.10	1		10/08/16 00:34	7439-92-1		
Sample: WR074		Lab ID: 10364697074		Collected: 09/24/16 10:58		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.67	ug/L	0.10	1		10/08/16 00:43	7439-92-1		
Sample: WR075		Lab ID: 10364697075		Collected: 09/24/16 11:00		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.56	ug/L	0.10	1		10/08/16 00:46	7439-92-1		
Sample: WR076		Lab ID: 10364697076		Collected: 09/24/16 11:01		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.55	ug/L	0.10	1		10/08/16 00:49	7439-92-1		
Sample: WR077		Lab ID: 10364697077		Collected: 09/24/16 11:02		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.84	ug/L	0.10	1		10/08/16 00:52	7439-92-1		
Sample: WR078		Lab ID: 10364697078		Collected: 09/24/16 11:09		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.18	ug/L	0.10	1		10/08/16 00:55	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR079		Lab ID: 10364697079		Collected: 09/24/16 11:10		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.17	ug/L	0.10	1		10/08/16 00:58	7439-92-1		
Sample: WR080		Lab ID: 10364697080		Collected: 09/24/16 11:11		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.43	ug/L	0.10	1		10/08/16 01:01	7439-92-1		
Sample: WR081		Lab ID: 10364697081		Collected: 09/24/16 11:12		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.13	ug/L	0.10	1		10/06/16 03:15	7439-92-1		
Sample: WR082		Lab ID: 10364697082		Collected: 09/24/16 11:13		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.16	ug/L	0.10	1		10/06/16 03:27	7439-92-1		
Sample: WR083		Lab ID: 10364697083		Collected: 09/24/16 11:14		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.58	ug/L	0.10	1		10/06/16 03:30	7439-92-1		
Sample: WR084		Lab ID: 10364697084		Collected: 09/24/16 11:18		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.20	ug/L	0.10	1		10/06/16 03:33	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR085		Lab ID: 10364697085		Collected: 09/24/16 11:23		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.20	ug/L	0.10	1		10/06/16 03:36	7439-92-1		
Sample: WR086		Lab ID: 10364697086		Collected: 09/24/16 11:24		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.32	ug/L	0.10	1		10/06/16 03:39	7439-92-1		
Sample: WR087		Lab ID: 10364697087		Collected: 09/24/16 11:25		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.18	ug/L	0.10	1		10/06/16 03:42	7439-92-1		
Sample: WR088		Lab ID: 10364697088		Collected: 09/24/16 11:26		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.25	ug/L	0.10	1		10/06/16 03:51	7439-92-1		
Sample: WR089		Lab ID: 10364697089		Collected: 09/24/16 11:22		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.31	ug/L	0.10	1		10/06/16 03:54	7439-92-1		
Sample: WR090		Lab ID: 10364697090		Collected: 09/24/16 11:32		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.27	ug/L	0.10	1		10/06/16 03:57	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR091		Lab ID: 10364697091		Collected: 09/24/16 11:33		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.13	ug/L	0.10	1		10/06/16 04:00	7439-92-1		
Sample: WR092		Lab ID: 10364697092		Collected: 09/24/16 11:34		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.48	ug/L	0.10	1		10/06/16 04:03	7439-92-1		
Sample: WR093		Lab ID: 10364697093		Collected: 09/24/16 11:36		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.17	ug/L	0.10	1		10/06/16 04:06	7439-92-1		
Sample: WR094		Lab ID: 10364697094		Collected: 09/24/16 11:37		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.16	ug/L	0.10	1		10/06/16 04:09	7439-92-1		
Sample: WR095		Lab ID: 10364697095		Collected: 09/24/16 11:38		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.39	ug/L	0.10	1		10/06/16 04:12	7439-92-1		
Sample: WR096		Lab ID: 10364697096		Collected: 09/24/16 11:47		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.36	ug/L	0.10	1		10/06/16 04:15	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR097		Lab ID: 10364697097		Collected: 09/24/16 12:02		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.28	ug/L	0.10	1		10/06/16 04:18	7439-92-1		
Sample: WR098		Lab ID: 10364697098		Collected: 09/24/16 12:03		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.13	ug/L	0.10	1		10/06/16 04:27	7439-92-1		
Sample: WR099		Lab ID: 10364697099		Collected: 09/24/16 12:07		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	ND	ug/L	0.10	1		10/06/16 04:30	7439-92-1		
Sample: WR100		Lab ID: 10364697100		Collected: 09/24/16 12:08		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	4.9	ug/L	0.10	1		10/06/16 04:33	7439-92-1		
Sample: WR101		Lab ID: 10364697101		Collected: 09/24/16 12:09		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.4	ug/L	0.10	1		10/06/16 04:45	7439-92-1		
Sample: WR102		Lab ID: 10364697102		Collected: 09/24/16 12:10		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.84	ug/L	0.10	1		10/06/16 18:40	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR103		Lab ID: 10364697103		Collected: 09/24/16 12:11		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.74	ug/L	0.10	1		10/06/16 18:43	7439-92-1		
Sample: WR104		Lab ID: 10364697104		Collected: 09/24/16 12:12		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.96	ug/L	0.10	1		10/06/16 18:46	7439-92-1		
Sample: WR105		Lab ID: 10364697105		Collected: 09/24/16 12:13		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.82	ug/L	0.10	1		10/06/16 18:49	7439-92-1		
Sample: WR106		Lab ID: 10364697106		Collected: 09/24/16 12:14		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.56	ug/L	0.10	1		10/06/16 18:52	7439-92-1		
Sample: WR107		Lab ID: 10364697107		Collected: 09/24/16 12:15		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.68	ug/L	0.10	1		10/06/16 18:55	7439-92-1		
Sample: WR108		Lab ID: 10364697108		Collected: 09/24/16 12:16		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.53	ug/L	0.10	1		10/06/16 18:58	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR109		Lab ID: 10364697109	Collected: 09/24/16 12:27		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.48	ug/L	0.10	1		10/06/16 19:01	7439-92-1	
Sample: WR110		Lab ID: 10364697110	Collected: 09/24/16 12:28		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.97	ug/L	0.10	1		10/06/16 19:04	7439-92-1	
Sample: WR111		Lab ID: 10364697111	Collected: 09/24/16 12:29		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.1	ug/L	0.10	1		10/06/16 19:07	7439-92-1	
Sample: WR112		Lab ID: 10364697112	Collected: 09/24/16 12:30		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.1	ug/L	0.10	1		10/06/16 19:15	7439-92-1	
Sample: WR113		Lab ID: 10364697113	Collected: 09/24/16 12:36		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.3	ug/L	0.10	1		10/06/16 19:19	7439-92-1	
Sample: WR114		Lab ID: 10364697114	Collected: 09/24/16 12:37		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	6.1	ug/L	0.10	1		10/06/16 19:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR115		Lab ID: 10364697115		Collected: 09/24/16 12:38		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	3.4	ug/L	0.10	1		10/06/16 19:24	7439-92-1		
Sample: WR116		Lab ID: 10364697116		Collected: 09/24/16 12:40		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.52	ug/L	0.10	1		10/06/16 19:27	7439-92-1		
Sample: WR117		Lab ID: 10364697117		Collected: 09/24/16 12:41		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.36	ug/L	0.10	1		10/06/16 19:30	7439-92-1		
Sample: WR118		Lab ID: 10364697118		Collected: 09/24/16 12:44		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.26	ug/L	0.10	1		10/06/16 19:33	7439-92-1		
Sample: WR119		Lab ID: 10364697119		Collected: 09/24/16 12:45		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.46	ug/L	0.10	1		10/06/16 19:36	7439-92-1		
Sample: WR121		Lab ID: 10364697121		Collected: 09/24/16 13:02		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.26	ug/L	0.10	1		10/05/16 17:00	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR122		Lab ID: 10364697122	Collected: 09/24/16 13:03		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.22	ug/L	0.10	1		10/05/16 17:06	7439-92-1	
Sample: WR123		Lab ID: 10364697123	Collected: 09/24/16 13:04		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.26	ug/L	0.10	1		10/05/16 17:07	7439-92-1	
Sample: WR124		Lab ID: 10364697124	Collected: 09/24/16 13:05		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	ND	ug/L	0.10	1		10/05/16 17:08	7439-92-1	
Sample: WR125		Lab ID: 10364697125	Collected: 09/24/16 13:07		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.37	ug/L	0.10	1		10/05/16 17:10	7439-92-1	
Sample: WR126		Lab ID: 10364697126	Collected: 09/24/16 13:08		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	0.51	ug/L	0.10	1		10/05/16 17:11	7439-92-1	
Sample: WR127		Lab ID: 10364697127	Collected: 09/24/16 13:10		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	ND	ug/L	0.10	1		10/05/16 17:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR128		Lab ID: 10364697128		Collected: 09/24/16 13:14		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.9	ug/L	0.10	1		10/05/16 17:17	7439-92-1		
Sample: WR129		Lab ID: 10364697129		Collected: 09/24/16 13:14		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.3	ug/L	0.10	1		10/05/16 17:18	7439-92-1		
Sample: WR130		Lab ID: 10364697130		Collected: 09/24/16 13:18		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.1	ug/L	0.10	1		10/05/16 17:19	7439-92-1		
Sample: WR131		Lab ID: 10364697131		Collected: 09/24/16 13:19		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.87	ug/L	0.10	1		10/05/16 17:21	7439-92-1		
Sample: WR132		Lab ID: 10364697132		Collected: 09/24/16 13:20		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.29	ug/L	0.10	1		10/05/16 17:24	7439-92-1		
Sample: WR133		Lab ID: 10364697133		Collected: 09/24/16 13:22		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.5	ug/L	0.10	1		10/05/16 17:25	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR134		Lab ID: 10364697134		Collected: 09/24/16 13:23		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.6	ug/L	0.10	1		10/05/16 17:26	7439-92-1		
Sample: WR135		Lab ID: 10364697135		Collected: 09/24/16 13:24		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	6.6	ug/L	0.10	1		10/05/16 17:28	7439-92-1		
Sample: WR136		Lab ID: 10364697136		Collected: 09/24/16 13:26		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.31	ug/L	0.10	1		10/05/16 17:29	7439-92-1		
Sample: WR138		Lab ID: 10364697138		Collected: 09/24/16 13:32		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.7	ug/L	0.10	1		10/05/16 17:35	7439-92-1		
Sample: WR139		Lab ID: 10364697139		Collected: 09/24/16 13:38		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	3.2	ug/L	0.10	1		10/05/16 17:36	7439-92-1		
Sample: WR140		Lab ID: 10364697140		Collected: 09/24/16 13:41		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	5.5	ug/L	0.10	1		10/05/16 17:37	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Sample: WR141		Lab ID: 10364697141		Collected: 09/24/16 13:42		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	3.5	ug/L	0.10	1		10/06/16 07:11	7439-92-1

Sample: WR142		Lab ID: 10364697142		Collected: 09/24/16 13:44	Received: 10/04/16 10:00	Matrix: Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	9.3	ug/L	0.10	1		10/06/16 07:13	7439-92-1

Sample: WR143		Lab ID: 10364697143		Collected: 09/24/16 13:13		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	0.17	ug/L	0.10	1		10/06/16 07:15	7439-92-1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

QC Batch:	439118	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	ICPMS Metals, Drinking Water
Associated Lab Samples:	10364697041, 10364697042, 10364697043, 10364697044, 10364697045, 10364697046, 10364697047, 10364697048, 10364697049, 10364697050, 10364697051, 10364697052, 10364697053, 10364697054, 10364697055, 10364697056, 10364697057, 10364697058, 10364697059, 10364697060		

METHOD BLANK: 2385069

Matrix: Water

Associated Lab Samples: 10364697041, 10364697042, 10364697043, 10364697044, 10364697045, 10364697046, 10364697047, 10364697048, 10364697049, 10364697050, 10364697051, 10364697052, 10364697053, 10364697054, 10364697055, 10364697056, 10364697057, 10364697058, 10364697059, 10364697060

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/08/16 01:19	

LABORATORY CONTROL SAMPLE: 2385070

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	106	106	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2391473 2391474

Parameter	Units	10364697041 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	0.94	100	100	95.2	109	94	108	70-130	14	20	

MATRIX SPIKE SAMPLE: 2391475

Parameter	Units	10364697060 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	0.51	100	111	110	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

QC Batch:	439120	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	ICPMS Metals, Drinking Water
Associated Lab Samples:	10364697061, 10364697062, 10364697063, 10364697064, 10364697065, 10364697066, 10364697067, 10364697068, 10364697069, 10364697070, 10364697071, 10364697072, 10364697073, 10364697074, 10364697075, 10364697076, 10364697077, 10364697078, 10364697079, 10364697080		

METHOD BLANK: 2385073

Matrix: Water

Associated Lab Samples: 10364697061, 10364697062, 10364697063, 10364697064, 10364697065, 10364697066, 10364697067, 10364697068, 10364697069, 10364697070, 10364697071, 10364697072, 10364697073, 10364697074, 10364697075, 10364697076, 10364697077, 10364697078, 10364697079, 10364697080

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/07/16 23:37	

LABORATORY CONTROL SAMPLE: 2385074

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	106	106	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2391420 2391421

Parameter	Units	10364697061 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	0.18	100	100	100	113	100	113	70-130	12	20	

MATRIX SPIKE SAMPLE: 2391422

Parameter	Units	10364697080 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	0.43	100	113	112	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

QC Batch: 440200 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET
Associated Lab Samples: 10364697007, 10364697013, 10364697036

METHOD BLANK: 2393729 Matrix: Water

Associated Lab Samples: 10364697007, 10364697013, 10364697036

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/12/16 16:47	

LABORATORY CONTROL SAMPLE: 2393730

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	101	101	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2393731 2393732

Parameter	Units	10364697007 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	4.2	100	100	97.0	102	93	98	70-130	5	20	

MATRIX SPIKE SAMPLE: 2393733

Parameter	Units	10365090028 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	30.1	100	129	99	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

LABORATORIES

PASI-M Pace Analytical Services - Minneapolis

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10364697001	WR001	EPA 200.8	439115		
10364697002	WR002	EPA 200.8	439115		
10364697003	WR003	EPA 200.8	439115		
10364697004	WR004	EPA 200.8	439115		
10364697005	WR005	EPA 200.8	439115		
10364697006	WR006	EPA 200.8	439115		
10364697008	WR008	EPA 200.8	439115		
10364697009	WR009	EPA 200.8	439115		
10364697010	WR010	EPA 200.8	439115		
10364697011	WR011	EPA 200.8	439115		
10364697012	WR012	EPA 200.8	439115		
10364697014	WR014	EPA 200.8	439115		
10364697015	WR015	EPA 200.8	439115		
10364697016	WR016 - Dripping Faucet	EPA 200.8	439115		
10364697017	WR017	EPA 200.8	439115		
10364697018	WR018	EPA 200.8	439115		
10364697019	WR019	EPA 200.8	439115		
10364697020	WR020	EPA 200.8	439115		
10364697021	WR021	EPA 200.8	439117		
10364697022	WR022	EPA 200.8	439117		
10364697023	WR023	EPA 200.8	439117		
10364697024	WR024	EPA 200.8	439117		
10364697025	WR025	EPA 200.8	439117		
10364697026	WR026	EPA 200.8	439117		
10364697027	WR027	EPA 200.8	439117		
10364697028	WR028	EPA 200.8	439117		
10364697029	WR029	EPA 200.8	439117		
10364697030	WR030	EPA 200.8	439117		
10364697031	WR031	EPA 200.8	439117		
10364697032	WR032	EPA 200.8	439117		
10364697033	WR033	EPA 200.8	439117		
10364697034	WR034	EPA 200.8	439117		
10364697035	WR035	EPA 200.8	439117		
10364697037	WR037	EPA 200.8	439117		
10364697038	WR038	EPA 200.8	439117		
10364697039	WR039	EPA 200.8	439117		
10364697040	WR040	EPA 200.8	439117		
10364697041	WR041	EPA 200.8	439118		
10364697042	WR042	EPA 200.8	439118		
10364697043	WR043	EPA 200.8	439118		
10364697044	WR044	EPA 200.8	439118		
10364697045	WR045	EPA 200.8	439118		
10364697046	WR046	EPA 200.8	439118		
10364697047	WR047	EPA 200.8	439118		
10364697048	WR048	EPA 200.8	439118		
10364697049	WR049	EPA 200.8	439118		
10364697050	WR050	EPA 200.8	439118		
10364697051	WR051	EPA 200.8	439118		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10364697052	WR052	EPA 200.8	439118		
10364697053	WR053 *	EPA 200.8	439118		
10364697054	WR054	EPA 200.8	439118		
10364697055	WR055	EPA 200.8	439118		
10364697056	WR056	EPA 200.8	439118		
10364697057	WR057	EPA 200.8	439118		
10364697058	WR058	EPA 200.8	439118		
10364697059	WR059	EPA 200.8	439118		
10364697060	WR060	EPA 200.8	439118		
10364697061	WR061	EPA 200.8	439120		
10364697062	WR062	EPA 200.8	439120		
10364697063	WR063	EPA 200.8	439120		
10364697064	WR064	EPA 200.8	439120		
10364697065	WR065	EPA 200.8	439120		
10364697066	WR066	EPA 200.8	439120		
10364697067	WR067	EPA 200.8	439120		
10364697068	WR068	EPA 200.8	439120		
10364697069	WR069	EPA 200.8	439120		
10364697070	WR070	EPA 200.8	439120		
10364697071	WR071	EPA 200.8	439120		
10364697072	WR072	EPA 200.8	439120		
10364697073	WR073	EPA 200.8	439120		
10364697074	WR074	EPA 200.8	439120		
10364697075	WR075	EPA 200.8	439120		
10364697076	WR076	EPA 200.8	439120		
10364697077	WR077	EPA 200.8	439120		
10364697078	WR078	EPA 200.8	439120		
10364697079	WR079	EPA 200.8	439120		
10364697080	WR080	EPA 200.8	439120		
10364697081	WR081	EPA 200.8	439121		
10364697082	WR082	EPA 200.8	439121		
10364697083	WR083	EPA 200.8	439121		
10364697084	WR084	EPA 200.8	439121		
10364697085	WR085	EPA 200.8	439121		
10364697086	WR086	EPA 200.8	439121		
10364697087	WR087	EPA 200.8	439121		
10364697088	WR088	EPA 200.8	439121		
10364697089	WR089	EPA 200.8	439121		
10364697090	WR090	EPA 200.8	439121		
10364697091	WR091	EPA 200.8	439121		
10364697092	WR092	EPA 200.8	439121		
10364697093	WR093	EPA 200.8	439121		
10364697094	WR094	EPA 200.8	439121		
10364697095	WR095	EPA 200.8	439121		
10364697096	WR096	EPA 200.8	439121		
10364697097	WR097	EPA 200.8	439121		
10364697098	WR098	EPA 200.8	439121		
10364697099	WR099	EPA 200.8	439121		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: BS CSD - Wood Road E.S.

Pace Project No.: 10364697

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10364697100	WR100	EPA 200.8	439121		
10364697101	WR101	EPA 200.8	439122		
10364697102	WR102	EPA 200.8	439122		
10364697103	WR103	EPA 200.8	439122		
10364697104	WR104	EPA 200.8	439122		
10364697105	WR105	EPA 200.8	439122		
10364697106	WR106	EPA 200.8	439122		
10364697107	WR107	EPA 200.8	439122		
10364697108	WR108	EPA 200.8	439122		
10364697109	WR109	EPA 200.8	439122		
10364697110	WR110	EPA 200.8	439122		
10364697111	WR111	EPA 200.8	439122		
10364697112	WR112	EPA 200.8	439122		
10364697113	WR113	EPA 200.8	439122		
10364697114	WR114	EPA 200.8	439122		
10364697115	WR115	EPA 200.8	439122		
10364697116	WR116	EPA 200.8	439122		
10364697117	WR117	EPA 200.8	439122		
10364697118	WR118	EPA 200.8	439122		
10364697119	WR119	EPA 200.8	439122		
10364697121	WR121	EPA 200.8	439123		
10364697122	WR122	EPA 200.8	439123		
10364697123	WR123	EPA 200.8	439123		
10364697124	WR124	EPA 200.8	439123		
10364697125	WR125	EPA 200.8	439123		
10364697126	WR126	EPA 200.8	439123		
10364697127	WR127	EPA 200.8	439123		
10364697128	WR128	EPA 200.8	439123		
10364697129	WR129	EPA 200.8	439123		
10364697130	WR130	EPA 200.8	439123		
10364697131	WR131	EPA 200.8	439123		
10364697132	WR132	EPA 200.8	439123		
10364697133	WR133	EPA 200.8	439123		
10364697134	WR134	EPA 200.8	439123		
10364697135	WR135	EPA 200.8	439123		
10364697136	WR136	EPA 200.8	439123		
10364697138	WR138	EPA 200.8	439123		
10364697139	WR139	EPA 200.8	439123		
10364697140	WR140	EPA 200.8	439123		
10364697141	WR141	EPA 200.8	439129		
10364697142	WR142	EPA 200.8	439129		
10364697143	WR143	EPA 200.8	439129		
10364697007	WR007	EPA 200.8	440200	EPA 200.8	440647
10364697013	WR013	EPA 200.8	440200	EPA 200.8	440647
10364697036	WR036	EPA 200.8	440200	EPA 200.8	440647

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

10344697

Section A Required Client Information: Company: PSI Address: 104 Ene Blvd - Schenectady NY 12305 Email: WILLIAM.KOTAS@PSIUSA.COM Phone: 518.392.1111 Fax: 518.392.1111 Requested Due Date/TAT:		Section B Required Project Information: Report To: Bill Rotas Copy To: Purchase Order No.: Project Manager: BSCSD WOOD ROAD E.S. Project Number:		Section C Invoice Information: Attention: Company Name: Address: Pace Quote Reference: Pace Project Manager: Pace Profile #:	
Page: 1 of 12 2082397		REGULATORY AGENCY ☒ NPDES ☐ GROUND WATER ☒ DRINKING WATER ☐ UST ☐ RCRA ☐ OTHER Site Location: NY STATE:			

ITEM #	Section D Required Client Information		Section E Matrix Codes		Section F Sample ID		Section G Matrix Code		Section H Sample Type		Section I Collection		Section J Preservatives		Section K Analysis Test		Section L Requested Analysis Filtered (Y/N)		Section M Pace Project No./ Lab I.D.	
	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code	Matrix Code
1	WR001	WR001	WR001	WR001	WR001	WR001	WR001	WR001	WR001	WR001	WR001	WR001	WR001	WR001	WR001	WR001	WR001	WR001	WR001	WR001
2	WR002	WR002	WR002	WR002	WR002	WR002	WR002	WR002	WR002	WR002	WR002	WR002	WR002	WR002	WR002	WR002	WR002	WR002	WR002	WR002
3	WR003	WR003	WR003	WR003	WR003	WR003	WR003	WR003	WR003	WR003	WR003	WR003	WR003	WR003	WR003	WR003	WR003	WR003	WR003	WR003
4	WR004	WR004	WR004	WR004	WR004	WR004	WR004	WR004	WR004	WR004	WR004	WR004	WR004	WR004	WR004	WR004	WR004	WR004	WR004	WR004
5	WR005	WR005	WR005	WR005	WR005	WR005	WR005	WR005	WR005	WR005	WR005	WR005	WR005	WR005	WR005	WR005	WR005	WR005	WR005	WR005
6	WR006	WR006	WR006	WR006	WR006	WR006	WR006	WR006	WR006	WR006	WR006	WR006	WR006	WR006	WR006	WR006	WR006	WR006	WR006	WR006
7	WR007	WR007	WR007	WR007	WR007	WR007	WR007	WR007	WR007	WR007	WR007	WR007	WR007	WR007	WR007	WR007	WR007	WR007	WR007	WR007
8	WR008	WR008	WR008	WR008	WR008	WR008	WR008	WR008	WR008	WR008	WR008	WR008	WR008	WR008	WR008	WR008	WR008	WR008	WR008	WR008
9	WR009	WR009	WR009	WR009	WR009	WR009	WR009	WR009	WR009	WR009	WR009	WR009	WR009	WR009	WR009	WR009	WR009	WR009	WR009	WR009
10	WR010	WR010	WR010	WR010	WR010	WR010	WR010	WR010	WR010	WR010	WR010	WR010	WR010	WR010	WR010	WR010	WR010	WR010	WR010	WR010
11	WR011	WR011	WR011	WR011	WR011	WR011	WR011	WR011	WR011	WR011	WR011	WR011	WR011	WR011	WR011	WR011	WR011	WR011	WR011	WR011
12	WR012	WR012	WR012	WR012	WR012	WR012	WR012	WR012	WR012	WR012	WR012	WR012	WR012	WR012	WR012	WR012	WR012	WR012	WR012	WR012

Section N Relinquished By / Affiliation Date: 9/27/16 Time: 15:45 Signature: [Signature]		Section O Accepted By / Affiliation Date: 9/27/16 Time: 16:45 Signature: [Signature]		Section P Sample Conditions Date: 9/27/16 Time: 16:45 Signature: [Signature]	
Section Q Relinquished By / Affiliation Date: 9/27/16 Time: 15:45 Signature: [Signature]		Section R Accepted By / Affiliation Date: 9/27/16 Time: 16:45 Signature: [Signature]		Section S Sample Conditions Date: 9/27/16 Time: 16:45 Signature: [Signature]	
Section T Relinquished By / Affiliation Date: 9/27/16 Time: 15:45 Signature: [Signature]		Section U Accepted By / Affiliation Date: 9/27/16 Time: 16:45 Signature: [Signature]		Section V Sample Conditions Date: 9/27/16 Time: 16:45 Signature: [Signature]	
Section W Relinquished By / Affiliation Date: 9/27/16 Time: 15:45 Signature: [Signature]		Section X Accepted By / Affiliation Date: 9/27/16 Time: 16:45 Signature: [Signature]		Section Y Sample Conditions Date: 9/27/16 Time: 16:45 Signature: [Signature]	
Section Z Relinquished By / Affiliation Date: 9/27/16 Time: 15:45 Signature: [Signature]		Section AA Accepted By / Affiliation Date: 9/27/16 Time: 16:45 Signature: [Signature]		Section AB Sample Conditions Date: 9/27/16 Time: 16:45 Signature: [Signature]	

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company:	PSI	Report To:	Bill Kotas	Page:	4 of 12
Address:	164 Erie Blvd.	Copy To:			
Schenectady N.Y. 12305		Address:		REGULATORY AGENCY	
Email: M. KOTAS@PSIUSA.COM		Purchase Order No.:		☐ NPDES	☐ GROUND WATER
Phone:				☐ UST	☒ DRINKING WATER
Fax:		Project Manager:	DESJ Wood Rd. ES.	☐ RCRA	☐ OTHER
Requested Due Date/TAT:		Project Number:		Site Location	
				STATE:	NY

[illegible]

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page: 5 of 12
2082409

REGULATORY AGENCY
☐ NPDES ☐ GROUND WATER ☒ DRINKING WATER
☐ UST ☐ RCRA ☐ OTHER
 Site Location: NY
 STATE: NY

Section A
Required Client Information:

Company: PSI
 Address: 104 Erie Blvd
 City: Schenectady NY 12305
 Email: info@psicorp.com
 Phone: 518 382 1234
 Fax: 518 382 1234
 Requested Due Date/TAT: 9/24/16

Section B
Required Project Information:

Report To: Bill Kofas
 Copy To: Bill Kofas
 Purchase Order No.: 10408
 Project Name: Wood Road P.S.
 Project Number: 10408

Section C
Invoice Information:

Attention: Bill Kofas
 Company Name: PSI
 Address: 104 Erie Blvd
 City: Schenectady NY 12305
 Email: info@psicorp.com
 Phone: 518 382 1234
 Fax: 518 382 1234
 Requested Due Date/TAT: 9/24/16

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Analysis Test ↑	V/N	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab ID.
				COMPOSITE START	COMPOSITE END/GRAB								
1	WR049	DW	DW	DATE	TIME	DATE	TIME						049
2	WR050	WT	WT	DATE	TIME	DATE	TIME						050
3	WR051	WW	WW	DATE	TIME	DATE	TIME						051
4	WR052	P	P	DATE	TIME	DATE	TIME						052
5	WR053	SL	SL	DATE	TIME	DATE	TIME						053
6	WR054	OL	OL	DATE	TIME	DATE	TIME						054
7	WR055	WP	WP	DATE	TIME	DATE	TIME						055
8	WR056	AR	AR	DATE	TIME	DATE	TIME						056
9	WR057	TS	TS	DATE	TIME	DATE	TIME						057
10	WR058	OT	OT	DATE	TIME	DATE	TIME						058
11	WR059			DATE	TIME	DATE	TIME						059
12	WR060			DATE	TIME	DATE	TIME						060
ADDITIONAL COMMENTS WR 053 missing handle unable to draw sample fixed													
RELINQUISHED BY / AFFILIATION Bill Kofas PSI DATE: 9/24/16 TIME: 15:45 SIGNATURE: [Signature]													
ACCEPTED BY / AFFILIATION Bill Kofas PSI DATE: 9/24/16 TIME: 15:45 SIGNATURE: [Signature]													
TEMP IN °C 25 20.1 18.9 18.5 18.8 19.0													
SAMPLE CONDITIONS Received on: <u>9/24/16</u> Custody (Y/N): <u>N</u> Sealed Cooler (Y/N): <u>N</u> Samples Intact (Y/N): <u>Y</u>													

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company:	psl	Report To:	BILL KOTAS	Attention:	
Address:	104 EGLE BLVD SCHENECTADY NY 12303	Copy To:		Company Name:	
Email:	WILLIAM.KOTAS@PSI.USA.COM	Purchase Order No.:		Address:	
Phone:		Project Manager:	PSI D WOOD RD. ES.	Pace Quote Reference:	
Fax:		Project Number:		Pace Project Manager:	
Requested Due Date/TAT:					

Page:	6 of 12
2082408	

REGULATORY AGENCY	
☐ NPDES	☐ GROUND WATER
☐ UST	☒ DRINKING WATER
☐ RCRA	☐ OTHER

Site Location	NY
STATE	

[illegible]

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: PSI	Report To: Brill Kotas	Company Name:	Attention:	Page: 7 of 12	
Address: 104 Erie Blvd.	Copy To:	Address:			
City: Schenectady, NY 12305	Purchase Order No.:	Pace Quote Reference:			2082407
Email: WILLIAM.KOTAS@KUS.COM	Project Name: BSCD Wood Road ES	Pace Project Manager:			
Phone:	Project Number:				
Requested Due Date/TAT:					

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	MATRIX CODE (see valid codes to left)	# OF CONTAINERS	Preservatives	Analysis Test	Y/N	Requested Analysis Filtered (Y/N)		Pace Project No./ Lab I.D.
			COMPOSITE START	COMPOSITE END/GRAB							DATE	TIME	
1	WR073	DW	9/24	10:57	G	WR073	1						073
2	WR074	WT		10:58									074
3	WR075	WW		11:00									075
4	WR076	P		11:01									076
5	WR077	SL		11:02									077
6	WR078	OL		11:09									078
7	WR079	WP		11:10									079
8	WR080	AR		11:11									080
9	WR081	TS		11:12									081
10	WR082	OT		11:13									082
11	WR083			11:14									083
12	WR084			11:18									084

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION		ACCEPTED BY / AFFILIATION		DATE	TIME	SAMPLE CONDITIONS			
	DATE	TIME	DATE	TIME			Received on (Y/N)	Custody (Y/N)	Sealed Cooler (Y/N)	Samples Intact (Y/N)
	9/27/16	15:45	9/27/16	15:45	9/27/16	15:45	25	N	N	Y
	9/27/16	00:00	9/27/16	00:00	9/27/16	00:00	25	N	N	Y

ORIGINAL	
SAMPLER NAME AND SIGNATURE	DATE SIGNED (MM/DD/YY)
PRINT Name of SAMPLER: James Gerke	9/24/16
SIGNATURE of SAMPLER: <i>[Signature]</i>	

Section A Requested Due Date/TAT: _____		Section B Required Client Information:		Section C Invoice Information:	
Company: PSJ	Report To: Bill Kotas	Attention:	Page: 8 of 12	2082404	
Address: 104 Erie Blvd - Schenectady NY 12305	Copy To:	Company Name:	REGULATORY AGENCY		
Email: WILLIAM.M.KOTAKO@PSJUSA.COM	Purchase Order No.:	Address:	☐ NPDES ☐ GROUND WATER ☒ DRINKING WATER ☐ UST ☐ RCRA ☐ OTHER		
Phone: _____	Project Name: BCSB Wood Road e.s.	Pace Quote Reference:	Site Location: NY STATE:		
Fax: _____	Project Number:	Pace Project Manager:			

[illegible]

Section C

Invoice Information:

Page: 9 of 12

[illegible]

Page 50 of 54

Important Note: By signing this form you are accepting Pace's **NET 30** day payment terms and agreeing to late charges of **1.5%** per month for any invoices not paid within 30 days.

F-ALL-Q-020rev.07. 15-May-2007



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information: Company: <u>PSI</u> Address: <u>104 Erie Blvd.</u> <u>Schenectady NY 12305</u> Email: <u>JOE AM. KOTFAUS@PSIUSA.COM</u> Phone: _____ Fax: _____		Section B Required Project Information: Report To: <u>Bill Kotfas</u> Copy To: _____ Purchase Order No.: _____ Project Name: <u>BCEB Wood Rd. ES.</u> Project Number: _____		Section C Invoice Information: Attention: _____ Company Name: _____ Address: _____ Pace Quote Reference: _____ Pace Project Manager: _____ Pace Profile #: _____	
Page: <u>10</u> of <u>12</u> 2082406		REGULATORY AGENCY ☐ NPDES ☐ GROUND WATER ☒ DRINKING WATER ☐ UST ☐ RCRA ☐ OTHER _____		Site Location <u>NY</u> STATE: _____	

[illegible][illegible]

F-ALL-Q-020rev.07, 15-May-2007

CHAIN-OF-CUSTODY / Analytical Request Document
The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.


Section A Required Client Information: Company: <u>PSI</u> Address: <u>104 Erie Blvd.</u> <u>Schenectady NY 12305</u> Email: <u>BOLEMAN.KOTHE@PSIUSA.COM</u> Phone: _____ Fax: _____		Section B Required Project Information: Report To: <u>Bill Kotas</u> Copy To: _____ Address: _____ Purchase Order No.: _____ Project Manager: <u>Wood Rd. ES</u> Project Number: _____		Section C Invoice Information: Attention: _____ Company Name: _____ Address: _____ Pace Quote Reference: _____ Pace Project Manager: _____ Pace Profile #: _____	
Page: <u>12</u> of <u>12</u> 2082402		REGULATORY AGENCY ☐ NPDES ☐ GROUND WATER ☒ DRINKING WATER ☐ UST ☐ RCRA ☐ OTHER _____		Site Location STATE: <u>NY</u>	

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE DW WT Water Waste Water Product Soil/Solid Oil Wipe Air Tissue Other	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives							Y/N	Requested Analysis Filtered (Y/N)	Pace Project No./ Lab I.D.
					COMPOSITE START	COMPOSITE END/GRAB			DATE	TIME	DATE	TIME	DATE	TIME	DATE			
1	SAMPLE ID (A-Z, 0-9 / .) Sample IDs MUST BE UNIQUE		DWG			9/24	1322										133	
2							1323										134	
3							1324										135	
4							1326										136	
5							1328										137	
6							1338										138	
7							1341										139	
8							1342										140	
9							1344										141	
10							1344										142	
11							1343										143	
12																		
ADDITIONAL COMMENTS 410 2nd water fountain																		
SAMPLE CONDITIONS Received on Ice (Y/N) Custody Sealed Cooler (Y/N) Samples Intact (Y/N)																		

***Important Note:** By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

F-ALL-Q-020rev.07, 15-May-2007

	Document Name: Sample Condition Upon Receipt Form	Document Revised: 02Aug2016 Page 1 of 2
	Document No.: F-MN-L-213-rev.17	Issuing Authority: Pace Minnesota Quality Office

Sample Condition Upon Receipt	Client Name: PS I	Project #:	WO# : 10364697  10364697

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client
☐ Commercial ☐ Pace ☐ Speedee ☐ Other:
 Tracking Number: **773 8017 6502, 6025, 4743, 5382, 6437, 5989**

Custody Seal on Cooler/Box Present? ☐ Yes ☒ No Seals Intact? ☐ Yes ☒ No

Packing Material: ☐ Bubble Wrap ☒ Bubble Bags ☐ None ☐ Other: Temp Blank? ☐ Yes ☒ No

Thermometer Used: ☒ 151401163 ☐ 151401164 ☐ B88A912167504 ☐ B88A0143310098 Type of Ice: ☐ Wet ☐ Blue ☒ None ☐ Samples on ice, cooling process has begun

Cooler Temp Read (°C): **19.9, 18.2, 18.3** Cooler Temp Corrected (°C): **20.4, 18.4, 18.5, 19.2, 18.8, 19.8** Biological Tissue Frozen? ☐ Yes ☐ No ☒ N/A
 Temp should be above freezing to 6°C **18.5** Correction Factor: **+0.2** Date and Initials of Person Examining Contents: **BC 10/04/16**

USDA Regulated Soil (☒ N/A, water sample) **18.5, 18.8**
 Did samples originate in a quarantine zone within the United States: AL, AR, AZ, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX or VA (check maps)? ☐ Yes ☐ No Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? ☐ Yes ☐ No

If Yes to either question, fill out a Regulated Soil Checklist (F-MN-Q-338) and include with SCUR/COC paperwork.

	COMMENTS:
Chain of Custody Present? ☒ Yes ☐ No ☐ N/A	1.
Chain of Custody Filled Out? ☒ Yes ☐ No ☐ N/A	2.
Chain of Custody Relinquished? ☒ Yes ☐ No ☐ N/A	3.
Sampler Name and/or Signature on COC? ☒ Yes ☐ No ☐ N/A	4.
Samples Arrived within Hold Time? ☒ Yes ☐ No ☐ N/A	5.
Short Hold Time Analysis (<72 hr)? ☐ Yes ☒ No ☐ N/A	6.
Rush Turn Around Time Requested? ☐ Yes ☒ No ☐ N/A	7.
Sufficient Volume? ☒ Yes ☐ No ☐ N/A	8.
Correct Containers Used? ☒ Yes ☐ No ☐ N/A	9.
-Pace Containers Used? ☒ Yes ☐ No ☐ N/A	
Containers Intact? ☒ Yes ☐ No ☐ N/A	10.
Filtered Volume Received for Dissolved Tests? ☐ Yes ☐ No ☒ N/A	11. Note if sediment is visible in the dissolved container
Sample Labels Match COC? ☒ Yes ☐ No ☐ N/A	12.
-Includes Date/Time/ID/Analysis Matrix: WT	
All containers needing acid/base preservation have been checked? ☒ Yes ☐ No ☐ N/A	13. ☒ HNO ₃ ☐ H ₂ SO ₄ ☐ NaOH ☐ HCl
All containers needing preservation are found to be in compliance with EPA recommendation? ☒ Yes ☐ No ☐ N/A	Sample # 1.1-143.1
(HNO ₃ , H ₂ SO ₄ , HCl<2; NaOH >9 Sulfide, NaOH>12 Cyanide) Exceptions: VOA, Coliform, TOC, Oil and Grease, DRO/8015 (water) DOC ☐ Yes ☐ No ☒ N/A	Initial when completed: Lot # of added preservative:
Headspace in VOA Vials (>6mm)? ☐ Yes ☐ No ☒ N/A	14.
Trip Blank Present? ☐ Yes ☐ No ☒ N/A	15.
Trip Blank Custody Seals Present? ☐ Yes ☐ No ☒ N/A	
Pace Trip Blank Lot # (if purchased):	

CLIENT NOTIFICATION/RESOLUTION

Person Contacted: Date/Time: Field Data Required? ☐ Yes ☐ No
 Comments/Resolution: **Temp OK**

Project Manager Review:

Date: **10/05/16**

Note: Whenever there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEHNR Certification Office (i.e. out of hold, incorrect preservative, out of temp, incorrect containers).

Appendix H

Laboratory Analysis Results for:

Milton Terrace Elementary

100 Wood Rd, Ballston Spa, NY 12020

October 18, 2016

Bill Kotas
PSI
104 Erie Blvd
Schenectady, NY 12305

RE: Project: BS CSD-Milton Terrace E.S. REV
Pace Project No.: 10364690

Dear Bill Kotas:

Enclosed are the analytical results for sample(s) received by the laboratory on October 04, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.


Samples, in the electronic data deliverable (EDD) that accompanied this report, were flagged yellow if they exceeded the NYSDOH 15 ppb action level.

The space designated for the sampler on the chain of custody (COC) indicates if these samples were collected by Pace Analytical or were collected by the school district and just relinquished to Pace Analytical.

This report was revised on October 18, 2016 to reference the NYSDOH action level in the cover letter.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Amanda Albrecht
amanda.albrecht@pacelabs.com
Project Manager



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

October 18, 2016
Page 2

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Minnesota Certification IDs

1700 Elm Street SE Suite 200, Minneapolis, MN 55414

Alaska Certification UST-107

525 N 8th Street, Salina, KS 67401

A2LA Certification #: 2926.01

Alaska Certification #: UST-078

Alaska Certification #MN00064

Alabama Certification #40770

Arizona Certification #: AZ-0014

Arkansas Certification #: 88-0680

California Certification #: 01155CA

Colorado Certification #Pace

Connecticut Certification #: PH-0256

EPA Region 8 Certification #: 8TMS-L

Florida/NELAP Certification #: E87605

Guam Certification #:14-008r

Georgia Certification #: 959

Georgia EPD #: Pace

Idaho Certification #: MN00064

Hawaii Certification #MN00064

Illinois Certification #: 200011

Indiana Certification#C-MN-01

Iowa Certification #: 368

Kansas Certification #: E-10167

Kentucky Dept of Envi. Protection - DW #90062

Kentucky Dept of Envi. Protection - WW #:90062

Louisiana DEQ Certification #: 3086

Louisiana DHH #: LA140001

Maine Certification #: 2013011

Maryland Certification #: 322

Michigan DEPH Certification #: 9909

Minnesota Certification #: 027-053-137

Mississippi Certification #: Pace

Montana Certification #: MT0092

Nevada Certification #: MN_00064

Nebraska Certification #: Pace

New Jersey Certification #: MN-002

New York Certification #: 11647

North Carolina Certification #: 530

North Carolina State Public Health #: 27700

North Dakota Certification #: R-036

Ohio EPA #: 4150

Ohio VAP Certification #: CL101

Oklahoma Certification #: 9507

Oregon Certification #: MN200001

Oregon Certification #: MN300001

Pennsylvania Certification #: 68-00563

Puerto Rico Certification

Saipan (CNMI) #:MP0003

South Carolina #:74003001

Texas Certification #: T104704192

Tennessee Certification #: 02818

Utah Certification #: MN000642013-4

Virginia DGS Certification #: 251

Virginia/VELAP Certification #: Pace

Washington Certification #: C486

West Virginia Certification #: 382

West Virginia DHHR #:9952C

Wisconsin Certification #: 999407970

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10364690001	MT001	Water	09/25/16 07:11	10/04/16 10:00
10364690002	MT002	Water	09/25/16 07:15	10/04/16 10:00
10364690003	MT003	Water	09/25/16 07:21	10/04/16 10:00
10364690004	MT004	Water	09/25/16 07:22	10/04/16 10:00
10364690005	MT005	Water	09/25/16 07:23	10/04/16 10:00
10364690006	MT006	Water	09/25/16 07:25	10/04/16 10:00
10364690007	MT007	Water	09/25/16 07:26	10/04/16 10:00
10364690008	MT008	Water	09/25/16 07:27	10/04/16 10:00
10364690009	MT009	Water	09/25/16 07:30	10/04/16 10:00
10364690010	MT010	Water	09/25/16 07:30	10/04/16 10:00
10364690011	MT011	Water	09/25/16 07:31	10/04/16 10:00
10364690012	MT012	Water	09/25/16 07:32	10/04/16 10:00
10364690013	MT013	Water	09/25/16 07:34	10/04/16 10:00
10364690014	MT014	Water	09/25/16 07:35	10/04/16 10:00
10364690015	MT015	Water	09/25/16 07:36	10/04/16 10:00
10364690016	MT016	Water	09/25/16 07:37	10/04/16 10:00
10364690017	MT017	Water	09/25/16 07:38	10/04/16 10:00
10364690018	MT018	Water	09/25/16 07:39	10/04/16 10:00
10364690019	MT019	Water	09/25/16 07:40	10/04/16 10:00
10364690020	MT020	Water	09/25/16 07:41	10/04/16 10:00
10364690021	MT021	Water	09/25/16 07:42	10/04/16 10:00
10364690022	MT022	Water	09/25/16 07:45	10/04/16 10:00
10364690023	MT023	Water	09/25/16 07:46	10/04/16 10:00
10364690024	MT024	Water	09/25/16 07:47	10/04/16 10:00
10364690025	MT025	Water	09/25/16 07:48	10/04/16 10:00
10364690026	MT026	Water	09/25/16 07:53	10/04/16 10:00
10364690027	MT027	Water	09/25/16 07:54	10/04/16 10:00
10364690028	MT028	Water	09/25/16 07:55	10/04/16 10:00
10364690029	MT029	Water	09/25/16 08:02	10/04/16 10:00
10364690030	MT030	Water	09/25/16 08:03	10/04/16 10:00
10364690031	MT031	Water	09/25/16 08:04	10/04/16 10:00
10364690032	MT032	Water	09/25/16 08:08	10/04/16 10:00
10364690033	MT033	Water	09/25/16 08:09	10/04/16 10:00
10364690034	MT034	Water	09/25/16 08:10	10/04/16 10:00
10364690035	MT035	Water	09/25/16 08:11	10/04/16 10:00
10364690036	MT036	Water	09/25/16 08:18	10/04/16 10:00
10364690037	MT037	Water	09/25/16 08:22	10/04/16 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10364690038	MT038	Water	09/25/16 08:23	10/04/16 10:00
10364690039	MT039	Water	09/25/16 08:24	10/04/16 10:00
10364690040	MT040	Water	09/25/16 08:30	10/04/16 10:00
10364690041	MT041	Water	09/25/16 08:32	10/04/16 10:00
10364690042	MT042 *	Water	09/25/16 08:33	10/04/16 10:00
10364690043	MT043	Water	09/25/16 08:39	10/04/16 10:00
10364690044	MT044	Water	09/25/16 08:40	10/04/16 10:00
10364690045	MT045	Water	09/25/16 08:42	10/04/16 10:00
10364690046	MT046	Water	09/25/16 08:44	10/04/16 10:00
10364690047	MT047	Water	09/25/16 08:48	10/04/16 10:00
10364690048	MT048	Water	09/25/16 08:49	10/04/16 10:00
10364690049	MT049	Water	09/25/16 08:50	10/04/16 10:00
10364690050	MT050	Water	09/25/16 09:15	10/04/16 10:00
10364690051	MT051	Water	09/25/16 09:16	10/04/16 10:00
10364690052	MT052	Water	09/25/16 09:17	10/04/16 10:00
10364690053	MT053	Water	09/25/16 09:20	10/04/16 10:00
10364690054	MT054	Water	09/25/16 09:21	10/04/16 10:00
10364690055	MT055	Water	09/25/16 09:22	10/04/16 10:00
10364690056	MT056	Water	09/25/16 09:26	10/04/16 10:00
10364690057	MT057	Water	09/25/16 09:27	10/04/16 10:00
10364690058	MT058 *	Water	09/25/16 11:02	10/04/16 10:00
10364690059	MT059 *	Water	09/25/16 09:31	10/04/16 10:00
10364690060	MT060	Water	09/25/16 09:32	10/04/16 10:00
10364690061	MT061	Water	09/25/16 09:33	10/04/16 10:00
10364690062	MT062	Water	09/25/16 09:36	10/04/16 10:00
10364690063	MT063	Water	09/25/16 09:37	10/04/16 10:00
10364690064	MT064	Water	09/25/16 09:38	10/04/16 10:00
10364690065	MT065	Water	09/25/16 09:40	10/04/16 10:00
10364690066	MT066	Water	09/25/16 09:41	10/04/16 10:00
10364690067	MT067	Water	09/25/16 09:42	10/04/16 10:00
10364690069	MT069	Water	09/25/16 09:50	10/04/16 10:00
10364690070	MT070	Water	09/25/16 09:52	10/04/16 10:00
10364690071	MT071	Water	09/25/16 09:58	10/04/16 10:00
10364690072	MT072	Water	09/25/16 09:59	10/04/16 10:00
10364690073	MT073	Water	09/25/16 10:00	10/04/16 10:00
10364690074	MT074	Water	09/25/16 10:05	10/04/16 10:00
10364690075	MT075	Water	09/25/16 10:06	10/04/16 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Lab ID	Sample ID	Matrix	Date Collected	Date Received
10364690076	MT076	Water	09/25/16 10:07	10/04/16 10:00
10364690077	MT077	Water	09/25/16 10:12	10/04/16 10:00
10364690078	MT078	Water	09/25/16 10:13	10/04/16 10:00
10364690079	MT079	Water	09/25/16 10:14	10/04/16 10:00
10364690080	MT080	Water	09/25/16 10:20	10/04/16 10:00
10364690081	MT081	Water	09/25/16 10:22	10/04/16 10:00
10364690082	MT082	Water	09/25/16 10:29	10/04/16 10:00
10364690083	MT083	Water	09/25/16 10:30	10/04/16 10:00
10364690084	MT084	Water	09/25/16 10:31	10/04/16 10:00
10364690085	MT085	Water	09/25/16 10:32	10/04/16 10:00
10364690086	MT086	Water	09/25/16 10:33	10/04/16 10:00
10364690087	MT087	Water	09/25/16 10:34	10/04/16 10:00
10364690088	MT088	Water	09/25/16 10:35	10/04/16 10:00
10364690089	MT089	Water	09/25/16 10:44	10/04/16 10:00
10364690090	MT090	Water	09/25/16 10:46	10/04/16 10:00
10364690091	MT091	Water	09/25/16 10:48	10/04/16 10:00
10364690092	MT092	Water	09/25/16 10:50	10/04/16 10:00
10364690093	MT093	Water	09/25/16 10:52	10/04/16 10:00
10364690094	MT094	Water	09/25/16 10:54	10/04/16 10:00
10364690095	MT095	Water	09/25/16 10:56	10/04/16 10:00
10364690096	MT096	Water	09/25/16 11:05	10/04/16 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10364690001	MT001	EPA 200.8	TT3	1	PASI-M
10364690002	MT002	EPA 200.8	TT3	1	PASI-M
10364690003	MT003	EPA 200.8	TT3	1	PASI-M
10364690004	MT004	EPA 200.8	TT3	1	PASI-M
10364690005	MT005	EPA 200.8	TT3	1	PASI-M
10364690006	MT006	EPA 200.8	TT3	1	PASI-M
10364690007	MT007	EPA 200.8	TT3	1	PASI-M
10364690008	MT008	EPA 200.8	TT3	1	PASI-M
10364690009	MT009	EPA 200.8	TT3	1	PASI-M
10364690010	MT010	EPA 200.8	TT3	1	PASI-M
10364690011	MT011	EPA 200.8	TT3	1	PASI-M
10364690012	MT012	EPA 200.8	TT3	1	PASI-M
10364690013	MT013	EPA 200.8	TT3	1	PASI-M
10364690014	MT014	EPA 200.8	TT3	1	PASI-M
10364690015	MT015	EPA 200.8	TT3	1	PASI-M
10364690016	MT016	EPA 200.8	TT3	1	PASI-M
10364690017	MT017	EPA 200.8	TT3	1	PASI-M
10364690018	MT018	EPA 200.8	TT3	1	PASI-M
10364690019	MT019	EPA 200.8	TT3	1	PASI-M
10364690020	MT020	EPA 200.8	TT3	1	PASI-M
10364690021	MT021	EPA 200.8	TT3	1	PASI-M
10364690022	MT022	EPA 200.8	TT3	1	PASI-M
10364690023	MT023	EPA 200.8	TT3	1	PASI-M
10364690024	MT024	EPA 200.8	TT3	1	PASI-M
10364690025	MT025	EPA 200.8	TT3	1	PASI-M
10364690026	MT026	EPA 200.8	TT3	1	PASI-M
10364690027	MT027	EPA 200.8	TT3	1	PASI-M
10364690028	MT028	EPA 200.8	TT3	1	PASI-M
10364690029	MT029	EPA 200.8	TT3	1	PASI-M
10364690030	MT030	EPA 200.8	TT3	1	PASI-M
10364690031	MT031	EPA 200.8	TT3	1	PASI-M
10364690032	MT032	EPA 200.8	TT3	1	PASI-M
10364690033	MT033	EPA 200.8	TT3	1	PASI-M
10364690034	MT034	EPA 200.8	TT3	1	PASI-M
10364690035	MT035	EPA 200.8	TT3	1	PASI-M
10364690036	MT036	EPA 200.8	TT3	1	PASI-M
10364690037	MT037	EPA 200.8	TT3	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10364690038	MT038	EPA 200.8	TT3	1	PASI-M
10364690039	MT039	EPA 200.8	TT3	1	PASI-M
10364690040	MT040	EPA 200.8	TT3	1	PASI-M
10364690041	MT041	EPA 200.8	TT3	1	PASI-M
10364690042	MT042 *	EPA 200.8	TT3	1	PASI-M
10364690043	MT043	EPA 200.8	TT3	1	PASI-M
10364690044	MT044	EPA 200.8	TT3	1	PASI-M
10364690045	MT045	EPA 200.8	TT3	1	PASI-M
10364690046	MT046	EPA 200.8	TT3	1	PASI-M
10364690047	MT047	EPA 200.8	TT3	1	PASI-M
10364690048	MT048	EPA 200.8	TT3	1	PASI-M
10364690049	MT049	EPA 200.8	TT3	1	PASI-M
10364690050	MT050	EPA 200.8	TT3	1	PASI-M
10364690051	MT051	EPA 200.8	TT3	1	PASI-M
10364690052	MT052	EPA 200.8	TT3	1	PASI-M
10364690053	MT053	EPA 200.8	TT3	1	PASI-M
10364690054	MT054	EPA 200.8	TT3	1	PASI-M
10364690055	MT055	EPA 200.8	TT3	1	PASI-M
10364690056	MT056	EPA 200.8	TT3	1	PASI-M
10364690057	MT057	EPA 200.8	TT3	1	PASI-M
10364690058	MT058 *	EPA 200.8	TT3	1	PASI-M
10364690059	MT059 *	EPA 200.8	TT3	1	PASI-M
10364690060	MT060	EPA 200.8	TT3	1	PASI-M
10364690061	MT061	EPA 200.8	TT3	1	PASI-M
10364690062	MT062	EPA 200.8	TT3	1	PASI-M
10364690063	MT063	EPA 200.8	TT3	1	PASI-M
10364690064	MT064	EPA 200.8	TT3	1	PASI-M
10364690065	MT065	EPA 200.8	TT3	1	PASI-M
10364690066	MT066	EPA 200.8	TT3	1	PASI-M
10364690067	MT067	EPA 200.8	TT3	1	PASI-M
10364690069	MT069	EPA 200.8	TT3	1	PASI-M
10364690070	MT070	EPA 200.8	TT3	1	PASI-M
10364690071	MT071	EPA 200.8	TT3	1	PASI-M
10364690072	MT072	EPA 200.8	TT3	1	PASI-M
10364690073	MT073	EPA 200.8	TT3	1	PASI-M
10364690074	MT074	EPA 200.8	TT3	1	PASI-M
10364690075	MT075	EPA 200.8	TT3	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10364690076	MT076	EPA 200.8	TT3	1	PASI-M
10364690077	MT077	EPA 200.8	TT3	1	PASI-M
10364690078	MT078	EPA 200.8	TT3	1	PASI-M
10364690079	MT079	EPA 200.8	TT3	1	PASI-M
10364690080	MT080	EPA 200.8	TT3	1	PASI-M
10364690081	MT081	EPA 200.8	TT3	1	PASI-M
10364690082	MT082	EPA 200.8	TT3	1	PASI-M
10364690083	MT083	EPA 200.8	TT3	1	PASI-M
10364690084	MT084	EPA 200.8	TT3	1	PASI-M
10364690085	MT085	EPA 200.8	TT3	1	PASI-M
10364690086	MT086	EPA 200.8	TT3	1	PASI-M
10364690087	MT087	EPA 200.8	TT3	1	PASI-M
10364690088	MT088	EPA 200.8	TT3	1	PASI-M
10364690089	MT089	EPA 200.8	TT3	1	PASI-M
10364690090	MT090	EPA 200.8	TT3	1	PASI-M
10364690091	MT091	EPA 200.8	TT3	1	PASI-M
10364690092	MT092	EPA 200.8	TT3	1	PASI-M
10364690093	MT093	EPA 200.8	TT3	1	PASI-M
10364690094	MT094	EPA 200.8	TT3	1	PASI-M
10364690095	MT095	EPA 200.8	TT3	1	PASI-M
10364690096	MT096	EPA 200.8	TT3	1	PASI-M

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT001		Lab ID: 10364690001		Collected: 09/25/16 07:11		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	ND	ug/L	0.10	1		10/05/16 18:25	7439-92-1		
Sample: MT002		Lab ID: 10364690002		Collected: 09/25/16 07:15		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.10	ug/L	0.10	1		10/05/16 18:31	7439-92-1		
Sample: MT003		Lab ID: 10364690003		Collected: 09/25/16 07:21		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.1	ug/L	0.10	1		10/05/16 18:32	7439-92-1		
Sample: MT004		Lab ID: 10364690004		Collected: 09/25/16 07:22		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.76	ug/L	0.10	1		10/05/16 18:34	7439-92-1		
Sample: MT005		Lab ID: 10364690005		Collected: 09/25/16 07:23		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.0	ug/L	0.10	1		10/05/16 18:35	7439-92-1		
Sample: MT006		Lab ID: 10364690006		Collected: 09/25/16 07:25		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	5.2	ug/L	0.10	1		10/05/16 18:36	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT007		Lab ID: 10364690007		Collected: 09/25/16 07:26		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	3.7	ug/L	0.10	1		10/05/16 18:40	7439-92-1		
Sample: MT008		Lab ID: 10364690008		Collected: 09/25/16 07:27		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.1	ug/L	0.10	1		10/05/16 18:42	7439-92-1		
Sample: MT009		Lab ID: 10364690009		Collected: 09/25/16 07:30		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	4.7	ug/L	0.10	1		10/05/16 18:43	7439-92-1		
Sample: MT010		Lab ID: 10364690010		Collected: 09/25/16 07:30		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	3.0	ug/L	0.10	1		10/05/16 18:45	7439-92-1		
Sample: MT011		Lab ID: 10364690011		Collected: 09/25/16 07:31		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.1	ug/L	0.10	1		10/05/16 18:46	7439-92-1		
Sample: MT012		Lab ID: 10364690012		Collected: 09/25/16 07:32		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.5	ug/L	0.10	1		10/05/16 18:49	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT013		Lab ID: 10364690013		Collected: 09/25/16 07:34		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	3.7	ug/L	0.10	1		10/05/16 18:50	7439-92-1		
Sample: MT014		Lab ID: 10364690014		Collected: 09/25/16 07:35		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.9	ug/L	0.10	1		10/05/16 18:52	7439-92-1		
Sample: MT015		Lab ID: 10364690015		Collected: 09/25/16 07:36		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.6	ug/L	0.10	1		10/05/16 18:53	7439-92-1		
Sample: MT016		Lab ID: 10364690016		Collected: 09/25/16 07:37		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.9	ug/L	0.10	1		10/05/16 18:59	7439-92-1		
Sample: MT017		Lab ID: 10364690017		Collected: 09/25/16 07:38		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.4	ug/L	0.10	1		10/05/16 19:00	7439-92-1		
Sample: MT018		Lab ID: 10364690018		Collected: 09/25/16 07:39		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.6	ug/L	0.10	1		10/05/16 19:01	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT019		Lab ID: 10364690019		Collected: 09/25/16 07:40		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.9	ug/L	0.10	1		10/05/16 19:03	7439-92-1		
Sample: MT020		Lab ID: 10364690020		Collected: 09/25/16 07:41		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.6	ug/L	0.10	1		10/05/16 19:04	7439-92-1		
Sample: MT021		Lab ID: 10364690021		Collected: 09/25/16 07:42		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.4	ug/L	0.10	1		10/05/16 19:07	7439-92-1		
Sample: MT022		Lab ID: 10364690022		Collected: 09/25/16 07:45		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	4.5	ug/L	0.10	1		10/05/16 19:05	7439-92-1		
Sample: MT023		Lab ID: 10364690023		Collected: 09/25/16 07:46		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.7	ug/L	0.10	1		10/05/16 19:16	7439-92-1		
Sample: MT024		Lab ID: 10364690024		Collected: 09/25/16 07:47		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	16.5	ug/L	0.10	1		10/05/16 19:18	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT025		Lab ID: 10364690025		Collected: 09/25/16 07:48		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	13.4	ug/L	0.10	1		10/05/16 19:19	7439-92-1		
Sample: MT026		Lab ID: 10364690026		Collected: 09/25/16 07:53		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.3	ug/L	0.10	1		10/05/16 19:20	7439-92-1		
Sample: MT027		Lab ID: 10364690027		Collected: 09/25/16 07:54		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.2	ug/L	0.10	1		10/05/16 19:22	7439-92-1		
Sample: MT028		Lab ID: 10364690028		Collected: 09/25/16 07:55		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	3.1	ug/L	0.10	1		10/05/16 19:23	7439-92-1		
Sample: MT029		Lab ID: 10364690029		Collected: 09/25/16 08:02		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	3.5	ug/L	0.10	1		10/05/16 19:25	7439-92-1		
Sample: MT030		Lab ID: 10364690030		Collected: 09/25/16 08:03		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.5	ug/L	0.10	1		10/05/16 19:26	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT031		Lab ID: 10364690031		Collected: 09/25/16 08:04		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.0	ug/L	0.10	1		10/05/16 19:30	7439-92-1		
Sample: MT032		Lab ID: 10364690032		Collected: 09/25/16 08:08		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.2	ug/L	0.10	1		10/05/16 19:33	7439-92-1		
Sample: MT033		Lab ID: 10364690033		Collected: 09/25/16 08:09		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	7.0	ug/L	0.10	1		10/05/16 19:34	7439-92-1		
Sample: MT034		Lab ID: 10364690034		Collected: 09/25/16 08:10		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.5	ug/L	0.10	1		10/05/16 19:36	7439-92-1		
Sample: MT035		Lab ID: 10364690035		Collected: 09/25/16 08:11		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.80	ug/L	0.10	1		10/05/16 19:37	7439-92-1		
Sample: MT036		Lab ID: 10364690036		Collected: 09/25/16 08:18		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	7.1	ug/L	0.10	1		10/05/16 19:38	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT037		Lab ID: 10364690037		Collected: 09/25/16 08:22		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.6	ug/L	0.10	1		10/05/16 19:40	7439-92-1		
Sample: MT038		Lab ID: 10364690038		Collected: 09/25/16 08:23		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	34.5	ug/L	0.10	1		10/05/16 19:41	7439-92-1		
Sample: MT039		Lab ID: 10364690039		Collected: 09/25/16 08:24		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	5.0	ug/L	0.10	1		10/05/16 19:43	7439-92-1		
Sample: MT040		Lab ID: 10364690040		Collected: 09/25/16 08:30		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	9.3	ug/L	0.10	1		10/05/16 19:49	7439-92-1		
Sample: MT041		Lab ID: 10364690041		Collected: 09/25/16 08:32		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.83	ug/L	0.10	1		10/05/16 19:55	7439-92-1		
Sample: MT042 *		Lab ID: 10364690042		Collected: 09/25/16 08:33		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.84	ug/L	0.10	1		10/05/16 19:51	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT043		Lab ID: 10364690043		Collected: 09/25/16 08:39		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.9	ug/L	0.10	1		10/05/16 19:52	7439-92-1		
Sample: MT044		Lab ID: 10364690044		Collected: 09/25/16 08:40		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.96	ug/L	0.10	1		10/05/16 19:54	7439-92-1		
Sample: MT045		Lab ID: 10364690045		Collected: 09/25/16 08:42		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	22.5	ug/L	0.10	1		10/05/16 20:03	7439-92-1		
Sample: MT046		Lab ID: 10364690046		Collected: 09/25/16 08:44		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.3	ug/L	0.10	1		10/05/16 20:05	7439-92-1		
Sample: MT047		Lab ID: 10364690047		Collected: 09/25/16 08:48		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.0	ug/L	0.10	1		10/05/16 20:06	7439-92-1		
Sample: MT048		Lab ID: 10364690048		Collected: 09/25/16 08:49		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.70	ug/L	0.10	1		10/05/16 20:07	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT049		Lab ID: 10364690049		Collected: 09/25/16 08:50		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.5	ug/L	0.10	1		10/05/16 20:09	7439-92-1		
Sample: MT050		Lab ID: 10364690050		Collected: 09/25/16 09:15		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	3.5	ug/L	0.10	1		10/05/16 20:10	7439-92-1		
Sample: MT051		Lab ID: 10364690051		Collected: 09/25/16 09:16		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	11.1	ug/L	0.10	1		10/05/16 20:12	7439-92-1		
Sample: MT052		Lab ID: 10364690052		Collected: 09/25/16 09:17		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.0	ug/L	0.10	1		10/05/16 20:14	7439-92-1		
Sample: MT053		Lab ID: 10364690053		Collected: 09/25/16 09:20		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.5	ug/L	0.10	1		10/05/16 20:16	7439-92-1		
Sample: MT054		Lab ID: 10364690054		Collected: 09/25/16 09:21		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.82	ug/L	0.10	1		10/05/16 20:21	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT055		Lab ID: 10364690055		Collected: 09/25/16 09:22		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.78	ug/L	0.10	1		10/05/16 20:23	7439-92-1		
Sample: MT056		Lab ID: 10364690056		Collected: 09/25/16 09:26		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.1	ug/L	0.10	1		10/05/16 20:24	7439-92-1		
Sample: MT057		Lab ID: 10364690057		Collected: 09/25/16 09:27		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.98	ug/L	0.10	1		10/05/16 20:25	7439-92-1		
Sample: MT058 *		Lab ID: 10364690058		Collected: 09/25/16 11:02		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	6.5	ug/L	0.10	1		10/05/16 20:27	7439-92-1		
Sample: MT059 *		Lab ID: 10364690059		Collected: 09/25/16 09:31		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	4.5	ug/L	0.10	1		10/05/16 20:28	7439-92-1		
Sample: MT060		Lab ID: 10364690060		Collected: 09/25/16 09:32		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.5	ug/L	0.10	1		10/05/16 20:30	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT061		Lab ID: 10364690061		Collected: 09/25/16 09:33		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	3.3	ug/L	0.10	1		10/05/16 20:36	7439-92-1		
Sample: MT062		Lab ID: 10364690062		Collected: 09/25/16 09:36		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.3	ug/L	0.10	1		10/05/16 20:31	7439-92-1		
Sample: MT063		Lab ID: 10364690063		Collected: 09/25/16 09:37		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.6	ug/L	0.10	1		10/05/16 20:42	7439-92-1		
Sample: MT064		Lab ID: 10364690064		Collected: 09/25/16 09:38		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.1	ug/L	0.10	1		10/05/16 20:43	7439-92-1		
Sample: MT065		Lab ID: 10364690065		Collected: 09/25/16 09:40		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.6	ug/L	0.10	1		10/05/16 20:45	7439-92-1		
Sample: MT066		Lab ID: 10364690066		Collected: 09/25/16 09:41		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	3.1	ug/L	0.10	1		10/05/16 20:46	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT067		Lab ID: 10364690067		Collected: 09/25/16 09:42		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.0	ug/L	0.10	1		10/05/16 20:48	7439-92-1		
Sample: MT069		Lab ID: 10364690069		Collected: 09/25/16 09:50		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.49	ug/L	0.10	1		10/05/16 20:49	7439-92-1		
Sample: MT070		Lab ID: 10364690070		Collected: 09/25/16 09:52		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.56	ug/L	0.10	1		10/05/16 20:53	7439-92-1		
Sample: MT071		Lab ID: 10364690071		Collected: 09/25/16 09:58		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.2	ug/L	0.10	1		10/05/16 20:54	7439-92-1		
Sample: MT072		Lab ID: 10364690072		Collected: 09/25/16 09:59		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.5	ug/L	0.10	1		10/05/16 20:57	7439-92-1		
Sample: MT073		Lab ID: 10364690073		Collected: 09/25/16 10:00		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.95	ug/L	0.10	1		10/05/16 20:59	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT074		Lab ID: 10364690074		Collected: 09/25/16 10:05		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.0	ug/L	0.10	1		10/05/16 21:00	7439-92-1		
Sample: MT075		Lab ID: 10364690075		Collected: 09/25/16 10:06		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.1	ug/L	0.10	1		10/05/16 21:01	7439-92-1		
Sample: MT076		Lab ID: 10364690076		Collected: 09/25/16 10:07		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.1	ug/L	0.10	1		10/05/16 21:03	7439-92-1		
Sample: MT077		Lab ID: 10364690077		Collected: 09/25/16 10:12		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	3.0	ug/L	0.10	1		10/05/16 21:04	7439-92-1		
Sample: MT078		Lab ID: 10364690078		Collected: 09/25/16 10:13		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.50	ug/L	0.10	1		10/05/16 21:06	7439-92-1		
Sample: MT079		Lab ID: 10364690079		Collected: 09/25/16 10:14		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.1	ug/L	0.10	1		10/05/16 21:11	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT080		Lab ID: 10364690080		Collected: 09/25/16 10:20		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.7	ug/L	0.10	1		10/05/16 21:12	7439-92-1		
Sample: MT081		Lab ID: 10364690081		Collected: 09/25/16 10:22		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.85	ug/L	0.10	1		10/05/16 21:16	7439-92-1		
Sample: MT082		Lab ID: 10364690082		Collected: 09/25/16 10:29		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	5.0	ug/L	0.10	1		10/05/16 21:14	7439-92-1		
Sample: MT083		Lab ID: 10364690083		Collected: 09/25/16 10:30		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	5.3	ug/L	0.10	1		10/05/16 21:15	7439-92-1		
Sample: MT084		Lab ID: 10364690084		Collected: 09/25/16 10:31		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.33	ug/L	0.10	1		10/05/16 21:26	7439-92-1		
Sample: MT085		Lab ID: 10364690085		Collected: 09/25/16 10:32		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.16	ug/L	0.10	1		10/05/16 21:27	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT086		Lab ID: 10364690086		Collected: 09/25/16 10:33		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	4.5	ug/L	0.10	1		10/05/16 21:29	7439-92-1		
Sample: MT087		Lab ID: 10364690087		Collected: 09/25/16 10:34		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	4.4	ug/L	0.10	1		10/05/16 21:30	7439-92-1		
Sample: MT088		Lab ID: 10364690088		Collected: 09/25/16 10:35		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	3.3	ug/L	0.10	1		10/05/16 21:31	7439-92-1		
Sample: MT089		Lab ID: 10364690089		Collected: 09/25/16 10:44		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	1.9	ug/L	0.10	1		10/05/16 21:33	7439-92-1		
Sample: MT090		Lab ID: 10364690090		Collected: 09/25/16 10:46		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	2.7	ug/L	0.10	1		10/05/16 21:34	7439-92-1		
Sample: MT091		Lab ID: 10364690091		Collected: 09/25/16 10:48		Received: 10/04/16 10:00		Matrix: Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8							
Lead	0.62	ug/L	0.10	1		10/05/16 21:36	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Sample: MT092		Lab ID: 10364690092		Collected: 09/25/16 10:50		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	1.8	ug/L	0.10	1		10/05/16 21:38	7439-92-1

Sample: MT093		Lab ID: 10364690093		Collected: 09/25/16 10:52		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	2.7	ug/L	0.10	1		10/05/16 21:44	7439-92-1

Sample: MT094		Lab ID: 10364690094		Collected: 09/25/16 10:54		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	0.66	ug/L	0.10	1		10/05/16 21:45	7439-92-1

Sample: MT095		Lab ID: 10364690095		Collected: 09/25/16 10:56		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	1.2	ug/L	0.10	1		10/05/16 21:47	7439-92-1

Sample: MT096		Lab ID: 10364690096		Collected: 09/25/16 11:05		Received: 10/04/16 10:00		Matrix: Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	0.18	ug/L	0.10	1		10/05/16 21:48	7439-92-1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

LABORATORIES

PASI-M Pace Analytical Services - Minneapolis

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10364690001	MT001	EPA 200.8	439085		
10364690002	MT002	EPA 200.8	439085		
10364690003	MT003	EPA 200.8	439085		
10364690004	MT004	EPA 200.8	439085		
10364690005	MT005	EPA 200.8	439085		
10364690006	MT006	EPA 200.8	439085		
10364690007	MT007	EPA 200.8	439085		
10364690008	MT008	EPA 200.8	439085		
10364690009	MT009	EPA 200.8	439085		
10364690010	MT010	EPA 200.8	439085		
10364690011	MT011	EPA 200.8	439085		
10364690012	MT012	EPA 200.8	439085		
10364690013	MT013	EPA 200.8	439085		
10364690014	MT014	EPA 200.8	439085		
10364690015	MT015	EPA 200.8	439085		
10364690016	MT016	EPA 200.8	439085		
10364690017	MT017	EPA 200.8	439085		
10364690018	MT018	EPA 200.8	439085		
10364690019	MT019	EPA 200.8	439085		
10364690020	MT020	EPA 200.8	439085		
10364690021	MT021	EPA 200.8	439086		
10364690022	MT022	EPA 200.8	439086		
10364690023	MT023	EPA 200.8	439086		
10364690024	MT024	EPA 200.8	439086		
10364690025	MT025	EPA 200.8	439086		
10364690026	MT026	EPA 200.8	439086		
10364690027	MT027	EPA 200.8	439086		
10364690028	MT028	EPA 200.8	439086		
10364690029	MT029	EPA 200.8	439086		
10364690030	MT030	EPA 200.8	439086		
10364690031	MT031	EPA 200.8	439086		
10364690032	MT032	EPA 200.8	439086		
10364690033	MT033	EPA 200.8	439086		
10364690034	MT034	EPA 200.8	439086		
10364690035	MT035	EPA 200.8	439086		
10364690036	MT036	EPA 200.8	439086		
10364690037	MT037	EPA 200.8	439086		
10364690038	MT038	EPA 200.8	439086		
10364690039	MT039	EPA 200.8	439086		
10364690040	MT040	EPA 200.8	439086		
10364690041	MT041	EPA 200.8	439088		
10364690042	MT042 *	EPA 200.8	439088		
10364690043	MT043	EPA 200.8	439088		
10364690044	MT044	EPA 200.8	439088		
10364690045	MT045	EPA 200.8	439088		
10364690046	MT046	EPA 200.8	439088		
10364690047	MT047	EPA 200.8	439088		
10364690048	MT048	EPA 200.8	439088		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: BS CSD-Milton Terrace E.S. REV

Pace Project No.: 10364690

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10364690049	MT049	EPA 200.8	439088		
10364690050	MT050	EPA 200.8	439088		
10364690051	MT051	EPA 200.8	439088		
10364690052	MT052	EPA 200.8	439088		
10364690053	MT053	EPA 200.8	439088		
10364690054	MT054	EPA 200.8	439088		
10364690055	MT055	EPA 200.8	439088		
10364690056	MT056	EPA 200.8	439088		
10364690057	MT057	EPA 200.8	439088		
10364690058	MT058 *	EPA 200.8	439088		
10364690059	MT059 *	EPA 200.8	439088		
10364690060	MT060	EPA 200.8	439088		
10364690061	MT061	EPA 200.8	439091		
10364690062	MT062	EPA 200.8	439091		
10364690063	MT063	EPA 200.8	439091		
10364690064	MT064	EPA 200.8	439091		
10364690065	MT065	EPA 200.8	439091		
10364690066	MT066	EPA 200.8	439091		
10364690067	MT067	EPA 200.8	439091		
10364690069	MT069	EPA 200.8	439091		
10364690070	MT070	EPA 200.8	439091		
10364690071	MT071	EPA 200.8	439091		
10364690072	MT072	EPA 200.8	439091		
10364690073	MT073	EPA 200.8	439091		
10364690074	MT074	EPA 200.8	439091		
10364690075	MT075	EPA 200.8	439091		
10364690076	MT076	EPA 200.8	439091		
10364690077	MT077	EPA 200.8	439091		
10364690078	MT078	EPA 200.8	439091		
10364690079	MT079	EPA 200.8	439091		
10364690080	MT080	EPA 200.8	439091		
10364690081	MT081	EPA 200.8	439095		
10364690082	MT082	EPA 200.8	439095		
10364690083	MT083	EPA 200.8	439095		
10364690084	MT084	EPA 200.8	439095		
10364690085	MT085	EPA 200.8	439095		
10364690086	MT086	EPA 200.8	439095		
10364690087	MT087	EPA 200.8	439095		
10364690088	MT088	EPA 200.8	439095		
10364690089	MT089	EPA 200.8	439095		
10364690090	MT090	EPA 200.8	439095		
10364690091	MT091	EPA 200.8	439095		
10364690092	MT092	EPA 200.8	439095		
10364690093	MT093	EPA 200.8	439095		
10364690094	MT094	EPA 200.8	439095		
10364690095	MT095	EPA 200.8	439095		
10364690096	MT096	EPA 200.8	439095		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: PSI	Report To: Bill Kotas	Company Name:	Attention:	Company Name:	Attention:
Address: 104 Erie Blvd.	Copy To:	Address:		Address:	
City/State/Zip: Schenectady NY 12305	Purchase Order No.:	Pace Quote Reference:		Pace Quote Reference:	
Email: WILLIAM.KOTAS@PSIUSA.COM	Project Name:	Pace Project Manager:		Pace Project Manager:	
Phone:	Project Number:	Pace Profile #:		Pace Profile #:	
Requested Due Date/TAT:					

Page: **2** of **8**

2082811

REGULATORY AGENCY

☐ NPDES ☒ GROUND WATER ☒ DRINKING WATER
☐ UST ☐ RCRA ☐ OTHER

Site Location: **NY**
 STATE: **NY**

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE Drinking Water DW Water WT Waste Water WW Product P Soil/Solid SL Oil OL Wipe WP Air AR Tissue TS Other OT	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED				SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives								Analysis Test ↑ Y/N ↑	Requested Analysis Filtered (Y/N)												Pace Project No./ Lab I.D.																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																											
					COMPOSITE START	COMPOSITE END/GRAB	DATE	TIME			DATE	TIME	Unpreserved	H ₂ SO ₄	HNO ₃	HCl	NaOH	Na ₂ S ₂ O ₃		Methanol	Other																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																						

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION		ACCEPTED BY / AFFILIATION		DATE	TIME	SAMPLE CONDITIONS											
	DATE	TIME	DATE	TIME			Received on Ice (Y/N)	Sealed Cooler (Y/N)	Samples Intact (Y/N)									
dan m... PSI			degr - pace		9/27/16	15:45												
degr - pace			Brian Cui/PACE		10/04/16	1000												

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: **Daniel Gerke**
 SIGNATURE of SAMPLER: *[Signature]*
 DATE Signed (MM/DD/YYYY): **9/25/16**

ORIGINAL

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page: 3 of 8
2082812

Section A
Required Client Information:
Company: PSI
Address: 164 Erie Blvd.
Chemtody, NY 12305
Email: psiam, kotas@psidst.com
Phone: Fax:
Requested Due Date/TAT:

Section B
Required Project Information:
Report To: Bill Kotas
Copy To:
Purchase Order No.:
Project Name: PSCD Milton Terrace E.S.
Project Number:

Section C
Invoice Information:
Attention:
Company Name:
Address:
Pace Quote Reference:
Pace Project Manager:
Pace Profile #:

REGULATORY AGENCY
☐ NPDES ☐ GROUND WATER ☒ DRINKING WATER
☐ UST ☐ RCRA ☐ OTHER

Site Location: NY
STATE:

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE	Matrix Codes DW WT WW P SL OL WP AR TS OT	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Analysis Test ↑	Y/N	Requested Analysis Filtered (Y/N)												Pace Project No. / Lab I.D.
						COMPOSITE START	COMPOSITE END/GRAB																		
1	MT025			DW	G	DATE	TIME	DATE	TIME																025
2	MT026							9/26	7:48																026
3	MT027								7:53																027
4	MT028								7:54																028
5	MT029								7:55																029
6	MT030								8:02																030
7	MT031								8:03																031
8	MT032								8:04																032
9	MT033								8:08																033
10	MT034								8:09																034
11	MT035								8:10																035
12	MT036								8:11																036
									8:12																

ADDITIONAL COMMENTS

RELINQUISHED BY / AFFILIATION **DATE** **TIME** **ACCEPTED BY / AFFILIATION** **DATE** **TIME** **SAMPLE CONDITIONS**

Paula Calk PST 9/26/16 15:48 Alger 9/27/16 15:45 N N Y

de Jan 9/26/16 0800 Brian Chi/PACE 10/24/16 1000 N N X

Temp in C **Received on** **Custody** **Sealed Cooler** **Samples Intact**

18.7 10/24/16 10/24/16 10/24/16 10/24/16 10/24/16

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: Daniel Gerke **DATE Signed (MM/DD/YYYY):** 9/25/16

SIGNATURE of SAMPLER: [Signature]

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: PSI	Report To: Bill Kates	Attention:		Page: 84 of 8	
Address: 104 Pine Blvd.	Copy To:	Company Name:		Invoice Number: 2082813	
City/State: Shenectady NY 12305	Purchase Order No.:	Address:		REGULATORY AGENCY	
Email: bill.kates@psi-usa.com		Pace Quote Reference:		☐ NPDES ☐ GROUND WATER ☒ DRINKING WATER ☐ UST ☐ RCRA ☐ OTHER	
Phone: 518.444.1000	Project Name: PSI D Milton Terrace E.S.	Pace Project Manager:		Site Location	
Fax:	Project Number:	Pace Profile #:		STATE: NY	
Requested Due Date/TAT:					

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Y/N	Requested Analysis Filtered (Y/N)	Pace Project No./ Lab I.D.
				COMPOSITE START	COMPOSITE END/GRAB						
1	MT037	Drinking Water	GR	DATE	TIME						
2	MT038	Water	GR	9/25	8:22		1	Unpreserved			037
3	MT039	Waste Water	GR	9/25	8:23		1	H ₂ SO ₄			038
4	MT040	Product	GR	9/25	8:24		1	HCl			039
5	MT041	Soil/Solid	GR	9/25	8:30		1	NaOH			040
6	MT042 *	Oil	GR	9/25	8:32		1	HNO ₃			041
7	MT043	Air	GR	9/25	8:33		1	Metanol			042
8	MT044	Wipe	GR	9/25	8:40		1	Na ₂ S ₂ O ₃			043
9	MT045	Other	GR	9/25	8:42		1	Other			044
10	MT046		GR	9/25	8:44		1				045
11	MT047		GR	9/25	8:48		1				046
12	MT048		GR	9/25	8:49		1				047
											048

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION		ACCEPTED BY / AFFILIATION		SAMPLE CONDITIONS	
	DATE	TIME	DATE	TIME	Temp in °C	Received on
* Dripping faucet	9/22/16	15:45	9/22/16	15:45	25.4	N
	9/22/16	0800	9/22/16	1000	70.7	N
					19.2	
					18.1	
					16.2	

ORIGINAL

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: **Daniel Gerke**
 SIGNATURE of SAMPLER: *[Signature]*

DATE Signed (MM/DD/YY): **9/25/16**

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.



Section A Required Client Information: Company: <u>PSI</u> Address: <u>104 Erie Blvd.</u> City/State/Zip: <u>Schenectady NY 12305</u> Email: <u>JEAN.KOTAK@PSIUSA.COM</u> Phone: _____ Fax: _____ Requested Due Date/TAT: _____		Section B Required Project Information: Report To: <u>Bill Kotak</u> Copy To: _____ Purchase Order No.: _____ Project Name: <u>BSD Milton Terrace BS.</u> Project Number: _____		Section C Invoice Information: Attention: _____ Company Name: _____ Address: _____ Pace Quote Reference: _____ Pace Project Manager: _____ Pace Profile #: _____	
Regulatory Agency: ☐ NPDES ☐ GROUND WATER ☒ DRINKING WATER ☐ UST ☐ RCRA ☐ OTHER _____		Site Location: State: <u>NY</u>		Page: <u>5</u> of <u>8</u> 2082814	

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE DW WT WW P SL OL WP AR TS OT	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives Unpreserved H ₂ SO ₄ HCl NaOH Na ₂ S ₂ O ₃ Methanol Other	Analysis Test ↑ Y/N	Requested Analysis Filtered (Y/N)												Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
				COMPOSITE START	COMPOSITE END/GRAB																		
1	MT049		DW			9/25 8:50	1																049
2	MT050					9:15	1																050
3	MT051					9:16	1																051
4	MT052					9:17	1																052
5	MT053					9:20	1																053
6	MT054					9:22	1																054
7	MT055					9:26	1																055
8	MT056					9:27	1																056
9	MT057					11:02	1																057
10	MT058 *					9:31	1																058
11	MT059 →					9:32	1																059
12	MT060						1																060

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
only 1 sink in	WPA	9/27/16	15:45	sign pace	9/27/16	15:45	N N N Y
girls i.e. no #58	sign pace	9/29/16	0800	Brian Chi / PACE	10/04/16	1000	N N N Y
Found in PE affine later							
bubbler steady							
leak							
SAMPLER NAME AND SIGNATURE				Temp in °C			
PRINT Name of SAMPLER: <u>Daniel Gaerke</u>				Received on (Y/N)			
SIGNATURE of SAMPLER: <u>[Signature]</u>				Sealed Cooler (Y/N)			
				Samples Intact (Y/N)			

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information: Company: PSI Address: 104 Erie Blvd City/State/Zip: Schenectady NY 12305 Email: bill.kotas@psi-usa.com Phone: 518.381.1111 Fax: 518.381.1111 Requested Due Date/TAT:		Section B Required Project Information: Report To: Bill Kotas Copy To: Purchase Order No.: Project Name: PSI 20110116 Project Number:		Section C Invoice Information: Attention: Company Name: Address: Pace Quote Reference: Pace Project Manager: Pace Profile #:	
Page: 6 of 8 2082801		REGULATORY AGENCY ☐ NPDES ☐ GROUND WATER ☒ DRINKING WATER ☐ UST ☐ RCRA ☐ OTHER			
Site Location STATE: NY		Site Location STATE: NY			

ITEM #	Section D Required Client Information	Matrix Codes MATRIX I CODE Drinking Water Water Waste Water Product Solid/Solid Oil Wipe Air Tissue Other	SAMPLE TYPE (G=GRAB C=COMP) (see valid codes to left)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives H ₂ SO ₄ HNO ₃ HCl NaOH Na ₂ S ₂ O ₃ Merhandol Other	Analysis Test ↑	Y/N	Requested Analysis Filtered (Y/N)	Pace Project No. / Lab I.D.
				COMPOSITE START	COMPOSITE END/GRAB							
1	MT061	DWG		DATE	TIME							
2	MT062			9/25	9:33							0621
3	MT063				9:36							0622
4	MT064				9:37							0623
5	MT065				9:38							0624
6	MT066				9:40							0625
7	MT067				9:41							0626
8	MT068				9:42							0627
9	MT069				9:50							0628
10	MT070				9:50							0629
11	MT071				9:52							0630
12	MT072				9:58							0631
ADDITIONAL COMMENTS * no 2nd Bath in media center 68												

Relinquished By / Affiliation DATE TIME		Accepted By / Affiliation DATE TIME		SAMPLE CONDITIONS Received on Temp in °C Sealed Cooler (Y/N) Custody (Y/N) Samples Intact (Y/N)	
Relinquished By / Affiliation DATE TIME		Accepted By / Affiliation DATE TIME		SAMPLE CONDITIONS Received on Temp in °C Sealed Cooler (Y/N) Custody (Y/N) Samples Intact (Y/N)	
Relinquished By / Affiliation DATE TIME		Accepted By / Affiliation DATE TIME		SAMPLE CONDITIONS Received on Temp in °C Sealed Cooler (Y/N) Custody (Y/N) Samples Intact (Y/N)	

*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

F-ALL-Q-020rev.07, 15-May-2007

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: PSI	Report To: Bill Kotas	Attention:	Company Name:	Page: 7 of 8	Invoice No: 2082803
Address: 104 Erie Blvd.	Copy To:	Address:	Address:		
City: Schenectady N.Y.		State: NY	City: NY		
Phone: 518.438.8888		Zip: 12304	County: NY		
Fax:		Project Name: PSI SD Milton Terrace B3	Project Manager:		
Requested Due Date/TAT:		Project Number:	Pace Profile #:		

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Analysis Test ↑	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No. / Lab I.D.
				COMPOSITE START	COMPOSITE END/GRAB							
1	MT073	Drinking Water	GR	9/15	10:00		1					073
2	MT074	Water	GR		10:05		1					074
3	MT075	Waste Water	GR		10:06		1					075
4	MT076	Product	GR		10:07		1					076
5	MT077	Solid/Solid	GR		10:12		1					077
6	MT078	Oil	GR		10:13		1					078
7	MT079	Wipe	GR		10:14		1					079
8	MT080	Air	GR		10:20		1					080
9	MT081	Other	GR		10:22		1					081
10	MT082		GR		10:29		1					082
11	MT083		GR		10:30		1					083
12	MT084		GR		10:31		1					084

ADDITIONAL COMMENTS		RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS			
		<i>Bill Kotas</i>	9/22/16	15:15	<i>Bill Kotas</i>	9/27/16	15:15	Temp in °C	Received on	Sealed Cooler	Samples Intact
		<i>Bill Kotas</i>	9/29/16	0800	<i>Brian Ch. / PACE</i>	10/04/16	1000	20.7	N	N	Y
								19.2			
								18.1			
								19.1			

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information: Company: <u>PSI</u> Address: <u>104 Ene Blvd.</u> Email: <u>chenectady@psa.com</u> Phone: <u>716-414-1070</u> Fax: <u>716-414-1070</u> Requested Due Date/TAT: _____		Section B Required Project Information: Report To: <u>Bill Kotas</u> Copy To: _____ Purchase Order No.: _____ Project Name: <u>B3050 Milton Terrace P.S.</u> Project Number: _____		Section C Invoice Information: Attention: _____ Company Name: _____ Address: _____ Pace Quote Reference: _____ Pace Project Manager: _____ Pace Profile #: _____	
Page: <u>8</u> of <u>8</u> 2082802		REGULATORY AGENCY ☐ NPDES ☐ GROUND WATER ☒ DRINKING WATER ☐ UST ☐ RCRA ☐ OTHER _____			
Site Location STATE: <u>NY</u>					

ITEM #	Section D Required Client Information	Matrix Codes MATRIX / CODE	Matrix Codes DW WT WW P SL OL WP AR TS OT	Matrix Code (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives H ₂ SO ₄ HNO ₃ HCl NaOH Na ₂ S ₂ O ₃ Methanol Other	Requested Analysis Filtered (Y/N)	Pace Project No. / Lab I.D.
						COMPOSITE START	COMPOSITE END/GRAB					
1	MT085			DWG			DATE: 9/25 TIME: 10:32		1			085
2	MT086						DATE: 9/25 TIME: 10:33		1			086
3	MT087						DATE: 9/25 TIME: 10:34		1			087
4	MT088						DATE: 9/25 TIME: 10:35		1			088
5	MT089						DATE: 9/25 TIME: 10:40		1			089
6	MT090						DATE: 9/25 TIME: 10:40		1			090
7	MT091						DATE: 9/25 TIME: 10:48		1			091
8	MT092						DATE: 9/25 TIME: 10:50		1			092
9	MT093						DATE: 9/25 TIME: 10:52		1			093
10	MT094						DATE: 9/25 TIME: 10:54		1			094
11	MT095						DATE: 9/25 TIME: 10:56		1			095
12	MT096						DATE: 9/25 TIME: 11:05		1			096

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION		ACCEPTED BY / AFFILIATION		DATE	TIME	SAMPLE CONDITIONS			
	SIGNATURE	DATE	SIGNATURE	DATE			Temp in °C	Received on Ice (Y/N)	Sealed Cooler (Y/N)	Samples Intact (Y/N)
Pace Project No. / Lab I.D. 085 086 087 088 089 090 091 092 093 094 095 096	<u>John Goff</u>	9/27/16	<u>ALG</u>	9/27/16	15:45	15:45	N	N	Y	
	<u>ALG</u>	9/29/16	<u>ALG</u>	9/29/16	08:00	08:00	N	N	Y	
							14.2			
							18.1			
							19.7			

	Document Name:	Document Revised: 02Aug2016
	Sample Condition Upon Receipt Form	Page 1 of 2
	Document No.: F-MN-L-213-rev.17	Issuing Authority: Pace Minnesota Quality Office

Sample Condition Upon Receipt	Client Name: <u>PSI</u>	Project #: WO# : 10364690
	Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Speedee ☐ Other: _____	 10364690

Tracking Number: 773 8017 8197, 7773 8038 5676, 7773 8038 4831, 7773 8017 8109

Custody Seal on Cooler/Box Present? ☐ Yes ☒ No Seals Intact? ☐ Yes ☒ No Optional: Proj. Due Date: _____ Proj. Name: _____

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☒ None ☐ Other: _____ Temp Blank? ☐ Yes ☒ No

Thermometer Used: ☒ 151401163 ☐ 151401164 ☐ B88A912167504 ☐ B88A0143310098 Type of Ice: ☐ Wet ☐ Blue ☒ None ☐ Samples on ice, cooling process has begun

Cooler Temp Read (°C): 10.5, 14.0, 17.1 Cooler Temp Corrected (°C): 10.2, 14.2, 18.1, 19.2 Biological Tissue Frozen? ☐ Yes ☐ No ☒ N/A

Temp should be above freezing to 6°C 19.0 Correction Factor: 10.2 Date and Initials of Person Examining Contents: BC 10/04/16

USDA Regulated Soil (☒ N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, AZ, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX or VA (check maps)? ☐ Yes ☐ No Did samples originate from a foreign source (internationally, including Hawaii and Puerto Rico)? ☐ Yes ☐ No

If Yes to either question, fill out a Regulated Soil Checklist (F-MN-Q-338) and include with SCUR/COC paperwork.

	COMMENTS:
Chain of Custody Present? ☒ Yes ☐ No ☐ N/A	1.
Chain of Custody Filled Out? ☒ Yes ☐ No ☐ N/A	2.
Chain of Custody Relinquished? ☒ Yes ☐ No ☐ N/A	3.
Sampler Name and/or Signature on COC? ☒ Yes ☐ No ☐ N/A	4.
Samples Arrived within Hold Time? ☒ Yes ☐ No ☐ N/A	5.
Short Hold Time Analysis (<72 hr)? ☐ Yes ☒ No ☐ N/A	6.
Rush Turn Around Time Requested? ☐ Yes ☒ No ☐ N/A	7.
Sufficient Volume? ☒ Yes ☐ No ☐ N/A	8.
Correct Containers Used? ☒ Yes ☐ No ☐ N/A	9.
-Pace Containers Used? ☒ Yes ☐ No ☐ N/A	
Containers Intact? ☒ Yes ☐ No ☐ N/A	10.
Filtered Volume Received for Dissolved Tests? ☐ Yes ☐ No ☒ N/A	11. Note if sediment is visible in the dissolved container
Sample Labels Match COC? ☒ Yes ☐ No ☐ N/A	12.
-Includes Date/Time/ID/Analysis Matrix: <u>WT</u>	
All containers needing acid/base preservation have been checked? ☒ Yes ☐ No ☐ N/A	13. ☒ HNO ₃ ☐ H ₂ SO ₄ ☐ NaOH ☐ HCl
All containers needing preservation are found to be in compliance with EPA recommendation? ☒ Yes ☐ No ☐ N/A	Sample # <u>1.0 - 1/1 85.1</u>
(HNO ₃ , H ₂ SO ₄ , HCl<2; NaOH >9 Sulfide, NaOH>12 Cyanide)	
Exceptions: VOA, Coliform, TOC, Oil and Grease, DRO/8015 (water) DOC ☐ Yes ☐ No ☒ N/A	Initial when completed: _____ Lot # of added preservative: _____
Headspace in VOA Vials (>6mm)? ☐ Yes ☐ No ☒ N/A	14.
Trip Blank Present? ☐ Yes ☐ No ☒ N/A	15.
Trip Blank Custody Seals Present? ☐ Yes ☐ No ☒ N/A	
Pace Trip Blank Lot # (if purchased): _____	

CLIENT NOTIFICATION/RESOLUTION

Person Contacted: _____ Date/Time: _____

Comments/Resolution: Temp OK

Field Data Required? ☐ Yes ☐ No

Project Manager Review: _____ **Date:** 10/05/16

Note: Whenever there is a discrepancy affecting North Carolina compliance samples, a copy of this form will be sent to the North Carolina DEHNR Certification Office (i.e. out of hold, incorrect preservative, out of temp, incorrect containers).